

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received DV

Bottle c621,698,815,708,819,696,848

Collected By: RIBANDO

Comment:

Sample BRONX

Sample 3

ID of Source:

Collection 11/12/2001 AT 9:41:00

Submitted 11/12/2001 AT 8:57:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD27638

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Inorganics</u>						
EPA94	Silver	< MDL	ug/L	20.0	12/10/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/10/2001	PAD
SM18	Arsenic	< MDL	ug/L	20	11/28/2001	PAD
EPA94	Barium	< MDL	ug/L	200.0	12/10/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2	12/10/2001	PAD
EPA94	Calcium	6200	ug/L	1000.0	12/10/2001	PAD
EPA94	Cadmium	< MDL	ug/L	2.0	12/10/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/10/2001	PAD
EPA94	Chromium	< MDL	ug/L	10.0	12/10/2001	PAD
EPA94	Copper	< MDL	ug/L	20.0	12/10/2001	PAD
EPA94	Iron	25	ug/L	20.0	12/10/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	11/14/2001	PAD
SM18	Potassium	530	ug/L	100.0	12/19/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/22/2002

Environmental Laboratories

emailed

Original 1/22/2002

NYS ELAP # 10108

Page 1 of 4

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received DV

Bottle c621,698,815,708,819,696,848

Collected By: RIBANDO

Comment:

Sample BRONX

Sample 3

ID of Source:

Collection 11/12/2001 AT 9:41:00

Submitted 11/12/2001 AT 8:57:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD27638

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Magnesium	1300	ug/L	1000.0	12/10/2001	PAD
EPA94	Manganese	25	ug/L	20.0	12/10/2001	PAD
EPA94	Molybdenum	< MDL	ug/L	50.0	12/10/2001	PAD
EPA94	Sodium	7400	ug/L	1000.0	12/10/2001	PAD
EPA94	Nickel	< MDL	ug/L	20.0	12/10/2001	PAD
SM18	Lead	< MDL	ug/L	1.0	11/28/2001	PAD
EPA79	Potable Metals Digestion	Completed			11/15/2001	PAD
EPA94	Antimony	< MDL	ug/L	0.1	12/13/2001	PAD
SM18	Selenium	< MDL	ug/L	2	12/12/2001	PAD
SM18	Tin	< MDL	ug/L	100	12/21/2001	PAD
SM18	Titanium	< MDL	ug/L	100	1/18/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/13/2001	PAD
EPA94	Vanadium	< MDL	ug/L	20.0	12/10/2001	PAD
EPA94	Zinc	< MDL	ug/L	20.0	12/10/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/22/2002

Environmental Laboratories

emailed

Original 1/22/2002

NYS ELAP # 10108

Page 2 of 4

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received DV

Bottle c621,698,815,708,819,696,848

Collected By: RIBANDO

Comment:

Sample BRONX

Sample 3

ID of Source:

Collection 11/12/2001 AT 9:41:00

Submitted 11/12/2001 AT 8:57:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD27638

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
Chlorine Pesticides - 508						
	4,4-DDE	< MDL	ug/L	0.080	11/16/2001	DLV
	Aldrin	< MDL	ug/L	0.010	11/16/2001	DLV
	Chlordane	< MDL	ug/L	0.40	11/16/2001	DLV
	Dieldrin	< MDL	ug/L	0.016	11/16/2001	DLV
	Endrin	< MDL	ug/L	0.020	11/16/2001	DLV
	Heptachlor	< MDL	ug/L	0.020	11/16/2001	DLV
	Heptachlor Epoxide	< MDL	ug/L	0.030	11/16/2001	DLV
	Lindane	< MDL	ug/L	0.030	11/16/2001	DLV
	Methoxychlor	< MDL	ug/L	0.039	11/16/2001	DLV
	PCB's	< MDL	ug/L	0.20	11/16/2001	DLV
	Propachlor	< MDL	ug/L	0.040	11/16/2001	DLV
	Toxaphene	< MDL	ug/L	0.40	11/16/2001	DLV
The recoveries for 4 of the 11 compounds in the LCS Standard were below their acceptance ranges.						
Organic Chemicals - 525.2						
	2,4-Dinitrotoluene	< MDL	ug/L	2.0	11/24/2001	DLV
	2,6-Dinitrotoluene	< MDL	ug/L	2.0	11/24/2001	DLV
	4,4-DDE	< MDL	ug/L	0.80	11/24/2001	DLV
	Acetochlor	< MDL	ug/L	2.0	11/24/2001	DLV
	Alachlor	< MDL	ug/L	0.20	11/24/2001	DLV
	Atrazine	< MDL	ug/L	0.20	11/24/2001	DLV

Approved Pam Dilsizian

QA Officer

Date Approved: 1/22/2002

Environmental Laboratories

emailed

Original 1/22/2002

NYS ELAP # 10108

Page 3 of 4

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received DV

Bottle c621,698,815,708,819,696,848

Collected By: RIBANDO

Comment:

Sample BRONX

Sample 3

ID of Source:

Collection 11/12/2001 AT 9:41:00

Submitted 11/12/2001 AT 8:57:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD27638

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
	Benzo(a)pyrene	< MDL	ug/L	0.20	11/24/2001	DLV
	bis(2-Ethylhexyl)adipate	< MDL	ug/L	0.60	11/24/2001	DLV
	bis(2-Ethylhexyl)phthalate	< MDL	ug/L	0.60	11/24/2001	DLV
	Butachlor	< MDL	ug/L	0.40	11/24/2001	DLV
	EPTC	< MDL	ug/L	1.0	11/24/2001	DLV
	Hexachlorobenzene	< MDL	ug/L	0.10	11/24/2001	DLV
	Hexachlorocyclopentadiene	< MDL	ug/L	0.10	11/24/2001	DLV
	Metolachlor	< MDL	ug/L	0.75	11/24/2001	DLV
	Metribuzin	< MDL	ug/L	0.15	11/24/2001	DLV
	Molinate	< MDL	ug/L	0.90	11/24/2001	DLV
	Simazine	< MDL	ug/L	0.40	11/24/2001	DLV
	Terbacil	< MDL	ug/L	2.0	11/24/2001	DLV

The recoveries for 2 of the 18 compounds in the LCS Standard were below their acceptance ranges. The recoveries for 3 of the 18 compounds in the Spiked Sample were outside of their acceptance ranges. The recovery for 1 of the 3 Surrogate Standards in this sample was above its acceptance range. The breakdown for Endrin in the Breakdown Standard was 68%. The injection port is kept at 280 degrees Celcius which may be contributing to high Endrin Breakdown. An investigation into modifying injection port parameters will be made.

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	1/3/2002	DLV
-------------------------	---	------	----------	-----

A scan of the extract prepared for the 508 analysis, from 35-550 amu using a mass spectrometer, does not reveal the presence of non-target compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/22/2002

Environmental Laboratories

emailed

Original 1/22/2002

NYS ELAP # 10108

Page 4 of 4

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received DV

Bottle c632,859,345,312,855,721,472

Collected By: RIBANDO

Comment:

Sample BRONX

Sample 58

ID of Source:

Collection 11/12/2001 AT 9:15:00

Submitted 11/12/2001 AT 8:57:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD27639

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Inorganics</u>						
EPA94	Silver	< MDL	ug/L	20.0	12/10/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/10/2001	PAD
SM18	Arsenic	< MDL	ug/L	20	11/28/2001	PAD
EPA94	Barium	< MDL	ug/L	200.0	12/10/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2	12/10/2001	PAD
EPA94	Calcium	6200	ug/L	1000.0	12/10/2001	PAD
EPA94	Cadmium	< MDL	ug/L	2.0	12/10/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/10/2001	PAD
EPA94	Chromium	< MDL	ug/L	10.0	12/10/2001	PAD
EPA94	Copper	< MDL	ug/L	20.0	12/10/2001	PAD
EPA94	Iron	26	ug/L	20.0	12/10/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	11/14/2001	PAD
SM18	Potassium	530	ug/L	100.0	12/19/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/22/2002

Environmental Laboratories

emailed

Original 1/22/2002

NYS ELAP # 10108

Page 1 of 4

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received DV

Bottle c632,859,345,312,855,721,472

Collected By: RIBANDO

Comment:

Sample BRONX

Sample 58

ID of Source:

Collection 11/12/2001 AT 9:15:00

Submitted 11/12/2001 AT 8:57:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD27639

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Magnesium	1300	ug/L	1000.0	12/10/2001	PAD
EPA94	Manganese	24	ug/L	20.0	12/10/2001	PAD
EPA94	Molybdenum	< MDL	ug/L	50.0	12/10/2001	PAD
EPA94	Sodium	7200	ug/L	1000.0	12/10/2001	PAD
EPA94	Nickel	< MDL	ug/L	20.0	12/10/2001	PAD
SM18	Lead	< MDL	ug/L	1.0	11/28/2001	PAD
EPA79	Potable Metals Digestion	Completed			11/15/2001	PAD
EPA94	Antimony	< MDL	ug/L	0.1	12/13/2001	PAD
SM18	Selenium	< MDL	ug/L	2	12/12/2001	PAD
SM18	Tin	< MDL	ug/L	100	12/21/2001	PAD
SM18	Titanium	< MDL	ug/L	100	1/18/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/13/2001	PAD
EPA94	Vanadium	< MDL	ug/L	20.0	12/10/2001	PAD
EPA94	Zinc	< MDL	ug/L	20.0	12/10/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/22/2002

Environmental Laboratories

emailed

Original 1/22/2002

NYS ELAP # 10108

Page 2 of 4

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received DV

Bottle c632,859,345,312,855,721,472

Collected By: RIBANDO

Comment:

Sample BRONX

Sample 58

ID of Source:

Collection 11/12/2001 AT 9:15:00

Submitted 11/12/2001 AT 8:57:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD27639

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Organics</u>						
<u>Chlorine Pesticides - 508</u>						
	4,4-DDE	< MDL	ug/L	0.080	11/16/2001	DLV
	Aldrin	< MDL	ug/L	0.010	11/16/2001	DLV
	Chlordane	< MDL	ug/L	0.40	11/16/2001	DLV
	Dieldrin	< MDL	ug/L	0.016	11/16/2001	DLV
	Endrin	< MDL	ug/L	0.020	11/16/2001	DLV
	Heptachlor	< MDL	ug/L	0.020	11/16/2001	DLV
	Heptachlor Epoxide	< MDL	ug/L	0.030	11/16/2001	DLV
	Lindane	< MDL	ug/L	0.030	11/16/2001	DLV
	Methoxychlor	< MDL	ug/L	0.039	11/16/2001	DLV
	PCB's	< MDL	ug/L	0.20	11/16/2001	DLV
	Propachlor	< MDL	ug/L	0.040	11/16/2001	DLV
	Toxaphene	< MDL	ug/L	0.40	11/16/2001	DLV
The recoveries for 4 of the 11 compounds in the LCS Standard were below their acceptance ranges.						
<u>Organic Chemicals - 525.2</u>						
	2,4-Dinitrotoluene	< MDL	ug/L	2.0	11/24/2001	DLV
	2,6-Dinitrotoluene	< MDL	ug/L	2.0	11/24/2001	DLV
	4,4-DDE	< MDL	ug/L	0.80	11/24/2001	DLV
	Acetochlor	< MDL	ug/L	2.0	11/24/2001	DLV
	Alachlor	< MDL	ug/L	0.20	11/24/2001	DLV
	Atrazine	< MDL	ug/L	0.20	11/24/2001	DLV

Approved Pam Dilsizian

QA Officer

Date Approved: 1/22/2002

Environmental Laboratories

emailed

Original 1/22/2002

NYS ELAP # 10108

Page 3 of 4

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received DV

Bottle c632,859,345,312,855,721,472

Collected By: RIBANDO

Comment:

Sample BRONX

Sample 58

ID of Source:

Collection 11/12/2001 AT 9:15:00

Submitted 11/12/2001 AT 8:57:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD27639

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
	Benzo(a)pyrene	< MDL	ug/L	0.20	11/24/2001	DLV
	bis(2-Ethylhexyl)adipate	< MDL	ug/L	0.60	11/24/2001	DLV
	bis(2-Ethylhexyl)phthalate	< MDL	ug/L	0.60	11/24/2001	DLV
	Butachlor	< MDL	ug/L	0.40	11/24/2001	DLV
	EPTC	< MDL	ug/L	1.0	11/24/2001	DLV
	Hexachlorobenzene	< MDL	ug/L	0.10	11/24/2001	DLV
	Hexachlorocyclopentadiene	< MDL	ug/L	0.10	11/24/2001	DLV
	Metolachlor	< MDL	ug/L	0.75	11/24/2001	DLV
	Metribuzin	< MDL	ug/L	0.15	11/24/2001	DLV
	Molinate	< MDL	ug/L	0.90	11/24/2001	DLV
	Simazine	< MDL	ug/L	0.40	11/24/2001	DLV
	Terbacil	< MDL	ug/L	2.0	11/24/2001	DLV

The recoveries for 2 of the 18 compounds in the LCS Standard were below their acceptance ranges. The recoveries for 3 of the 18 compounds in the Spiked Sample were outside of their acceptance ranges. The breakdown for Endrin in the Breakdown Standard was 68%. The injection port is kept at 280 degrees Celcius which may be contributing to high Endrin Breakdown. An investigation into modifying injection port parameters will be made.

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	1/3/2002	DLV
-------------------------	---	------	----------	-----

A scan of the extract prepared for the 508 analysis, from 35-550 amu using a mass spectrometer, does not reveal the presence of non-target compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/22/2002

Environmental Laboratories

emailed

Original 1/22/2002

NYS ELAP # 10108

Page 4 of 4