

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley
Received BH
Bottle p1146,q290
Collected By: LAB
Comment:

Sample FIELD BLANK

Sample FBD
ID of Source:
Collection 11/24/2001 AT
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AD28750

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	< MDL	ug/L		12/12/2001	DLV

The GCMS scan from 35 to 550 amu does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/10/2002

Environmental Laboratories

emailed

Copy 1/10/2002

NYS ELAP # 10108

Page 1 of 1

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received BH
Bottle p1146,q290
Collected By: LAB
Comment:

Sample FIELD BLANK

Sample FB 11/24/01
ID of Source:
Collection 11/24/2001 AT
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AD28750

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	< MDL	ug/L		12/12/2001	DLV

The GCMS scan from 35 to 550 amu does not reveal the presence of unusual compounds.

Approved Pam Dilsizian QA Officer

Date Approved: 12/12/2001

Environmental Laboratories

emailed Original 12/12/2001

NYS ELAP # 10108

Page 1 of 1

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received BH

Bottle c705,p1218,1219,q1016,1011

Collected By: TIGLAO

Comment:

Sample 3

Sample 3

ID of Source:

Collection 11/24/2001 AT 8:45:00

Submitted 11/24/2001 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD28751

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	12/19/2001	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Barium	13.8	ug/L	0.1	12/19/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Chromium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Copper	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Lead	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Manganese	23.9	ug/L	1.0	12/19/2001	PAD
EPA94	Nickel	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Selenium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Silver	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Zinc	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/20/2001	PAD
EPA94	Iron	24	ug/L	20.0	12/20/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	12/5/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/31/2002

Environmental Laboratories

emailed

Original 1/31/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received BH

Bottle c705,p1218,1219,q1016,1011

Collected By: TIGLAO

Comment:

Sample 3

Sample 3

ID of Source:

Collection 11/24/2001 AT 8:45:00

Submitted 11/24/2001 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD28751

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA'79	Potable Metals Digestion	Completed			12/5/2001	PAD
SM18	Tin	< MDL	ug/L	100	1/2/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

< MDL

ug/L

12/12/2001

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/31/2002

Environmental Laboratories

emailed

Original 1/31/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received BH

Bottle c546,p1116,824,q958,974

Collected By: TIGLAO

Comment:

Sample 58

Sample 58

ID of Source:

Collection 11/24/2001 AT 8:32:00

Submitted 11/24/2001 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD28752

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	12/19/2001	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Barium	13.8	ug/L	0.1	12/19/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Chromium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Copper	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Lead	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Manganese	20.6	ug/L	1.0	12/19/2001	PAD
EPA94	Nickel	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Selenium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Silver	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Zinc	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/20/2001	PAD
EPA94	Iron	30	ug/L	20.0	12/20/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	12/5/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received BH
Bottle c546,p1116,824,q958,974
Collected By: TIGLAO
Comment:

Sample 58

Sample 58
ID of Source:
Collection 11/24/2001 AT 8:32:00
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AD28752

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA'79	Potable Metals Digestion	Completed			12/5/2001	PAD
SM18	Tin	< MDL	ug/L	100	1/2/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	< MDL	ug/L	12/12/2001	DLV
-------------------------	-------	------	------------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received BH
Bottle c547,614,968,963,616
Collected By: BOLTON
Comment:

Sample 36273

Sample 18640
ID of Source:
Collection 11/23/2001 AT 8:15:00
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AD28753

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	12/19/2001	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Barium	14.2	ug/L	0.1	12/19/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Chromium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Copper	6.3	ug/L	1.0	12/19/2001	PAD
EPA94	Lead	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Manganese	19.8	ug/L	1.0	12/19/2001	PAD
EPA94	Nickel	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Selenium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Silver	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Zinc	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/20/2001	PAD
EPA94	Iron	26	ug/L	20.0	12/20/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	12/5/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received BH
Bottle c547,614,968,963,616
Collected By: BOLTON
Comment:

Sample 36273

Sample 18640
ID of Source:
Collection 11/23/2001 AT 8:15:00
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AD28753

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA'79	Potable Metals Digestion	Completed			12/5/2001	PAD
SM18	Tin	< MDL	ug/L	100	1/2/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	< MDL	ug/L	12/12/2001	DLV
-------------------------	-------	------	------------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received BH

Bottle c727,p963,891,q557,979

Collected By: MOHAN

Comment:

Sample 36276

Sample 23350

ID of Source:

Collection 11/23/2001 AT 9:43:00

Submitted 11/24/2001 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD28754

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Inorganics</u>						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	12/19/2001	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Barium	14.5	ug/L	0.1	12/19/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Chromium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Copper	10.1	ug/L	1.0	12/19/2001	PAD
EPA94	Lead	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Manganese	35.3	ug/L	1.0	12/19/2001	PAD
EPA94	Nickel	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Selenium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Silver	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Zinc	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/20/2001	PAD
EPA94	Iron	38	ug/L	20.0	12/20/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	12/5/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received BH

Bottle c727,p963,891,q557,979

Collected By: MOHAN

Comment:

Sample 36276

Sample 23350

ID of Source:

Collection 11/23/2001 AT 9:43:00

Submitted 11/24/2001 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD28754

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA'79	Potable Metals Digestion	Completed			12/5/2001	PAD
SM18	Tin	< MDL	ug/L	100	1/2/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

< MDL

ug/L

12/12/2001

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds, except for bis(2-Ethylhexyl)phthalate at an estimated level of 2.7 ug/L.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received BH
Bottle c761,1149,1148,982,981
Collected By: AHMAD
Comment:

Sample 36281

Sample 32750
ID of Source:
Collection 11/23/2001 AT 8:53:00
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AD28755

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	12/19/2001	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Barium	13.8	ug/L	0.1	12/19/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Chromium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Copper	6.1	ug/L	1.0	12/19/2001	PAD
EPA94	Lead	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Manganese	23.6	ug/L	1.0	12/19/2001	PAD
EPA94	Nickel	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Selenium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Silver	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Zinc	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/20/2001	PAD
EPA94	Iron	30	ug/L	20.0	12/20/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	12/5/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received BH
Bottle c761,1149,1148,982,981
Collected By: AHMAD
Comment:

Sample 36281

Sample 32750
ID of Source:
Collection 11/23/2001 AT 8:53:00
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AD28755

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA'79	Potable Metals Digestion	Completed			12/5/2001	PAD
SM18	Tin	< MDL	ug/L	100	1/2/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	< MDL	ug/L	12/12/2001	DLV
-------------------------	-------	------	------------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Sample 36292

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received BH

Bottle c726,1132,1138,573,341

Collected By: KAGZI

Comment:

Sample 46350

ID of Source:

Collection 11/23/2001 AT

Submitted 11/24/2001 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD28756

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	12/19/2001	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Barium	13.7	ug/L	0.1	12/19/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Chromium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Copper	6.1	ug/L	1.0	12/19/2001	PAD
EPA94	Lead	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Manganese	20.9	ug/L	1.0	12/19/2001	PAD
EPA94	Nickel	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Selenium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Silver	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Zinc	3.0	ug/L	2.0	12/19/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/20/2001	PAD
EPA94	Iron	28	ug/L	20.0	12/20/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	12/5/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Sample 36292

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368

Dr. Ian Hurley

Received BH

Bottle c726,1132,1138,573,341

Collected By: KAGZI

Comment:

Sample 46350

ID of Source:

Collection 11/23/2001 AT

Submitted 11/24/2001 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD28756

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA'79	Potable Metals Digestion	Completed			12/5/2001	PAD
SM18	Tin	< MDL	ug/L	100	1/2/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	< MDL	ug/L	12/12/2001	DLV
-------------------------	-------	------	------------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received BH
Bottle c731,882,441,581,560
Collected By: GERTSIK
Comment:

Sample 36295

Sample 51450

ID of Source:
Collection 11/23/2001 AT
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.:

Source Code:

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AD28757

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	12/19/2001	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Barium	14.0	ug/L	0.1	12/19/2001	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Chromium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Copper	12.3	ug/L	1.0	12/19/2001	PAD
EPA94	Lead	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Manganese	19.7	ug/L	1.0	12/19/2001	PAD
EPA94	Nickel	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Selenium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Silver	< MDL	ug/L	2.0	12/19/2001	PAD
EPA94	Thallium	< MDL	ug/L	1.0	12/19/2001	PAD
EPA94	Zinc	2.5	ug/L	2.0	12/19/2001	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	12/20/2001	PAD
EPA94	Iron	24	ug/L	20.0	12/20/2001	PAD
EPA79	Mercury	< MDL	ug/L	0.40	12/5/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley
Received BH
Bottle c731,882,441,581,560
Collected By: GERTSIK
Comment:

Sample 36295

Sample 51450
ID of Source:
Collection 11/23/2001 AT
Submitted 11/24/2001 AT 9:40:00
Sample Type: POT_DW
PWS No.: Source Code:

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AD28757

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	12/20/2001	PAD
EPA'79	Potable Metals Digestion	Completed			12/5/2001	PAD
SM18	Tin	< MDL	ug/L	100	1/2/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	< MDL	ug/L	12/12/2001	DLV
-------------------------	-------	------	------------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 1/2/2002

Environmental Laboratories

emailed

Original 1/2/2002

NYS ELAP # 10108

Page 2 of 2