

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received LK

Bottle C0447,P407,421,427,Q285,288,2

Collected By: KRAUSE

Comment:

Sample CATLEFF

ID of Source:

Collection 10/27/2001 AT 7:40:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26470

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Inorganics</u>						
EPA94	Beryllium	< MDL	ug/L	2	11/14/2001	PAD
EPA94	Calcium	5900	ug/L	1000.0	11/14/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	11/14/2001	PAD
EPA94	Iron	31	ug/L	20.0	11/14/2001	PAD
SM18	Potassium	430	ug/L	100.0	11/1/2001	PAD
EPA94	Magnesium	1300	ug/L	1000.0	11/14/2001	PAD
EPA94	Manganese	27	ug/L	20.0	11/14/2001	PAD
EPA94	Molybdenum	< MDL	ug/L	50.0	11/14/2001	PAD
EPA94	Sodium	4200	ug/L	1000.0	11/14/2001	PAD
EPA'79	Potable Metals Digestion	Completed			11/1/2001	PAD
SM18	Antimony	< MDL	ug/L	6	11/16/2001	PAD
SM18	Tin	< MDL	ug/L	100	11/8/2001	PAD
SM18	Titanium	< MDL	ug/L	100	11/9/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 1 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler
Received LK

Bottle C0447,P407,421,427,Q285,288,2

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample CATLEFF

ID of Source:

Collection 10/27/2001 AT 7:40:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26470

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Thallium	< MDL	ug/L	2	11/8/2001	PAD
EPA94	Vanadium	< MDL	ug/L	20.0	11/14/2001	PAD
Organics						
<u>Chlorine Pesticides - 508</u>						
	4,4-DDE	< MDL	ug/L	0.080	11/5/2001	DLV
	Aldrin	< MDL	ug/L	0.010	11/5/2001	DLV
	Chlordane	< MDL	ug/L	0.40	11/5/2001	DLV
	Dieldrin	< MDL	ug/L	0.016	11/5/2001	DLV
	Endrin	< MDL	ug/L	0.020	11/5/2001	DLV
	Heptachlor	< MDL	ug/L	0.020	11/5/2001	DLV
	Heptachlor Epoxide	< MDL	ug/L	0.030	11/5/2001	DLV
	Lindane	< MDL	ug/L	0.030	11/5/2001	DLV
	Methoxychlor	< MDL	ug/L	0.039	11/5/2001	DLV
	PCB's	< MDL	ug/L	0.20	11/5/2001	DLV
	Propachlor	< MDL	ug/L	0.040	11/5/2001	DLV
	Toxaphene	< MDL	ug/L	0.40	11/5/2001	DLV

The recovery for 2 of the 11 compounds in the LC S Standard were below their acceptance ranges.

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	11/1/2001	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 2 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0447,P407,421,427,Q285,288,2

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample CATLEFF

ID of Source:

Collection 10/27/2001 AT 7:40:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26470

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	11/1/2001	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	11/1/2001	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 3 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water

465 Columbus Ave.

Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0447,P407,421,427,Q285,288,2

Collected By: KRAUSE

Comment:

Sample NYC DEP

19 WESTLAKE DRIVE

VALHALLA, N.Y.

Sample CATLEFF

ID of Source:

Collection 10/27/2001 AT 7:40:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26470

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	4-chlorotoluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Benzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromomethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	11/1/2001	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	11/1/2001	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	11/1/2001	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Naphthalene	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 4 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received LK

Bottle C0447,P407,421,427,Q285,288,2

Collected By: KRAUSE

Comment:

Sample CATLEFF

ID of Source:

Collection 10/27/2001 AT 7:40:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26470

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	O-xylene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Styrene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Toluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	11/1/2001	SV

ONE OF THREE SURROGATES IS 5% ABOVE THE UPPER CONTROL LIMIT.

Organic Chemicals - 525.2

2,4-Dinitrotoluene	< MDL	ug/L	2.0	11/9/2001	DLV
2,6-Dinitrotoluene	< MDL	ug/L	2.0	11/9/2001	DLV
4,4-DDE	< MDL	ug/L	0.80	11/9/2001	DLV
Acetochlor	< MDL	ug/L	2.0	11/9/2001	DLV
Alachlor	< MDL	ug/L	0.20	11/9/2001	DLV
Atrazine	< MDL	ug/L	0.20	11/9/2001	DLV
Benzo(a)pyrene	< MDL	ug/L	0.20	11/9/2001	DLV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 5 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received LK

Bottle C0447,P407,421,427,Q285,288,2

Collected By: KRAUSE

Comment:

Sample CATLEFF

ID of Source:

Collection 10/27/2001 AT 7:40:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26470

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
	bis(2-Ethylhexyl)adipate	< MDL	ug/L	0.60	11/9/2001	DLV
	bis(2-Ethylhexyl)phthalate	0.61	ug/L	0.60	11/9/2001	DLV
	Butachlor	< MDL	ug/L	0.40	11/9/2001	DLV
	EPTC	< MDL	ug/L	1.0	11/9/2001	DLV
	Hexachlorobenzene	< MDL	ug/L	0.10	11/9/2001	DLV
	Hexachlorocyclopentadiene	< MDL	ug/L	0.10	11/9/2001	DLV
	Metolachlor	< MDL	ug/L	0.75	11/9/2001	DLV
	Metribuzin	< MDL	ug/L	0.15	11/9/2001	DLV
	Molinate	< MDL	ug/L	0.90	11/9/2001	DLV
	Simazine	< MDL	ug/L	0.40	11/9/2001	DLV
	Terbacil	< MDL	ug/L	2.0	11/9/2001	DLV

The breakdown for Endrin in the Breakdown Standard was 50%. Recoveries for 4 of the 18 compounds in the MDL Standard were outside of their acceptance ranges. Recoveries for 3 of the 18 compounds in the LCS Standard were below their acceptance ranges. Recoveries for 5 of the 18 compounds in the Spiked Sample were outside of their acceptance ranges. The level for bis(2-Ethylhexyl)phthalate in the Laboratory Blank was 0.64 ug/L.

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	12/4/2001	DLV
-------------------------	---	------	-----------	-----

A scan of the extract prepared for the 508 analysis, from 35-550 amu using a mass spectrometer, does not reveal the presence of non-target compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 6 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0440,P425,422,412,Q312,318,3

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample DEL18

ID of Source:

Collection 10/27/2001 AT 8:05:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26471

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Inorganics</u>						
EPA94	Beryllium	< MDL	ug/L	2	11/14/2001	PAD
EPA94	Calcium	5800	ug/L	1000.0	11/14/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	11/14/2001	PAD
EPA94	Iron	30	ug/L	20.0	11/14/2001	PAD
SM18	Potassium	420	ug/L	100.0	11/1/2001	PAD
EPA94	Magnesium	1300	ug/L	1000.0	11/14/2001	PAD
EPA94	Manganese	25	ug/L	20.0	11/14/2001	PAD
EPA94	Molybdenum	< MDL	ug/L	50.0	11/14/2001	PAD
EPA94	Sodium	4200	ug/L	1000.0	11/14/2001	PAD
EPA'79	Potable Metals Digestion	Completed			11/1/2001	PAD
SM18	Antimony	< MDL	ug/L	6	11/16/2001	PAD
SM18	Tin	< MDL	ug/L	100	11/8/2001	PAD
SM18	Titanium	< MDL	ug/L	100	11/9/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 1 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0440,P425,422,412,Q312,318,3

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample DEL18

ID of Source:

Collection 10/27/2001 AT 8:05:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26471

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Thallium	< MDL	ug/L	2	11/8/2001	PAD
EPA94	Vanadium	< MDL	ug/L	20.0	11/14/2001	PAD
Organics						
<u>Chlorine Pesticides - 508</u>						
	4,4-DDE	< MDL	ug/L	0.080	11/5/2001	DLV
	Aldrin	< MDL	ug/L	0.010	11/5/2001	DLV
	Chlordane	< MDL	ug/L	0.40	11/5/2001	DLV
	Dieldrin	< MDL	ug/L	0.016	11/5/2001	DLV
	Endrin	< MDL	ug/L	0.020	11/5/2001	DLV
	Heptachlor	< MDL	ug/L	0.020	11/5/2001	DLV
	Heptachlor Epoxide	< MDL	ug/L	0.030	11/5/2001	DLV
	Lindane	< MDL	ug/L	0.030	11/5/2001	DLV
	Methoxychlor	< MDL	ug/L	0.039	11/5/2001	DLV
	PCB's	< MDL	ug/L	0.20	11/5/2001	DLV
	Propachlor	< MDL	ug/L	0.040	11/5/2001	DLV
	Toxaphene	< MDL	ug/L	0.40	11/5/2001	DLV

The recovery for 2 of the 11 compounds in the LC S Standard were below their acceptance ranges.

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	11/1/2001	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 2 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water

465 Columbus Ave.

Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0440,P425,422,412,Q312,318,3

Collected By: KRAUSE

Comment:

Sample NYC DEP

19 WESTLAKE DRIVE

VALHALLA, N.Y.

Sample DEL18

ID of Source:

Collection 10/27/2001 AT 8:05:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26471

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	11/1/2001	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	11/1/2001	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 3 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received LK

Bottle C0440,P425,422,412,Q312,318,3

Collected By: KRAUSE

Comment:

Sample DEL18

ID of Source:

Collection 10/27/2001 AT 8:05:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26471

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	4-chlorotoluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Benzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromomethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	11/1/2001	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	11/1/2001	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	11/1/2001	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Naphthalene	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 4 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received LK

Bottle C0440,P425,422,412,Q312,318,3

Collected By: KRAUSE

Comment:

Sample DEL18

ID of Source:

Collection 10/27/2001 AT 8:05:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26471

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	O-xylene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Styrene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Toluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	11/1/2001	SV

ONE OF THREE SURROGATES IS 6% ABOVE THE UPPER CONTROL LIMIT.

Organic Chemicals - 525.2

2,4-Dinitrotoluene	< MDL	ug/L	2.0	11/7/2001	DLV
2,6-Dinitrotoluene	< MDL	ug/L	2.0	11/7/2001	DLV
4,4-DDE	< MDL	ug/L	0.80	11/7/2001	DLV
Acetochlor	< MDL	ug/L	2.0	11/7/2001	DLV
Alachlor	< MDL	ug/L	0.20	11/7/2001	DLV
Atrazine	< MDL	ug/L	0.20	11/7/2001	DLV
Benzo(a)pyrene	< MDL	ug/L	0.20	11/7/2001	DLV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 5 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0440,P425,422,412,Q312,318,3

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample DEL18

ID of Source:

Collection 10/27/2001 AT 8:05:00

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26471

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
	bis(2-Ethylhexyl)adipate	< MDL	ug/L	0.60	11/7/2001	DLV
	bis(2-Ethylhexyl)phthalate	1.9	ug/L	0.60	11/7/2001	DLV
	Butachlor	< MDL	ug/L	0.40	11/7/2001	DLV
	EPTC	< MDL	ug/L	1.0	11/7/2001	DLV
	Hexachlorobenzene	< MDL	ug/L	0.10	11/7/2001	DLV
	Hexachlorocyclopentadiene	< MDL	ug/L	0.10	11/7/2001	DLV
	Metolachlor	< MDL	ug/L	0.75	11/7/2001	DLV
	Metribuzin	< MDL	ug/L	0.15	11/7/2001	DLV
	Molinate	< MDL	ug/L	0.90	11/7/2001	DLV
	Simazine	< MDL	ug/L	0.40	11/7/2001	DLV
	Terbacil	< MDL	ug/L	2.0	11/7/2001	DLV

The breakdown for Endrin in the Breakdown Standard was 39%. Recoveries for 4 of the 18 compounds in the MDL Standard were outside of their acceptance ranges. Recoveries for 2 of the 18 compounds in the LCS Standard were outside of their acceptance ranges. Recoveries for 3 of the 18 compounds in the Spiked Sample were outside of their acceptance ranges.

GCMS Scan For Unknowns

Other unknown compounds	ug/L	12/4/2001	DLV
-------------------------	------	-----------	-----

A scan of the extract prepared for the 508 analysis, from 35-550 amu using a mass spectrometer, does not reveal the presence of non-target compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 6 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0417,Q1675,1676,1673,2067,1

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample CROGH

ID of Source:

Collection 10/27/2001 AT

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26472

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Inorganics</u>						
EPA94	Beryllium	< MDL	ug/L	2	11/14/2001	PAD
EPA94	Calcium	25000	ug/L	1000.0	11/14/2001	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	11/14/2001	PAD
EPA94	Iron	62	ug/L	20.0	11/14/2001	PAD
SM18	Potassium	2200	ug/L	100.0	11/1/2001	PAD
EPA94	Magnesium	8300	ug/L	1000.0	11/14/2001	PAD
EPA94	Manganese	68	ug/L	20.0	11/14/2001	PAD
EPA94	Molybdenum	< MDL	ug/L	50.0	11/14/2001	PAD
EPA94	Sodium	27000	ug/L	1000.0	11/14/2001	PAD
EPA'79	Potable Metals Digestion	Completed			11/1/2001	PAD
SM18	Antimony	< MDL	ug/L	6	11/16/2001	PAD
SM18	Tin	< MDL	ug/L	100	11/8/2001	PAD
SM18	Titanium	< MDL	ug/L	100	11/9/2001	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 1 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0417,Q1675,1676,1673,2067,1

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample CROGH

ID of Source:

Collection 10/27/2001 AT

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26472

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Thallium	< MDL	ug/L	2	11/8/2001	PAD
EPA94	Vanadium	< MDL	ug/L	20.0	11/14/2001	PAD
Organics						
<u>Chlorine Pesticides - 508</u>						
	4,4-DDE	< MDL	ug/L	0.080	11/5/2001	DLV
	Aldrin	< MDL	ug/L	0.010	11/5/2001	DLV
	Chlordane	< MDL	ug/L	0.40	11/5/2001	DLV
	Dieldrin	< MDL	ug/L	0.016	11/5/2001	DLV
	Endrin	< MDL	ug/L	0.020	11/5/2001	DLV
	Heptachlor	< MDL	ug/L	0.020	11/5/2001	DLV
	Heptachlor Epoxide	< MDL	ug/L	0.030	11/5/2001	DLV
	Lindane	< MDL	ug/L	0.030	11/5/2001	DLV
	Methoxychlor	< MDL	ug/L	0.039	11/5/2001	DLV
	PCB's	< MDL	ug/L	0.20	11/5/2001	DLV
	Propachlor	< MDL	ug/L	0.040	11/5/2001	DLV
	Toxaphene	< MDL	ug/L	0.40	11/5/2001	DLV

The recovery for 2 of the 11 compounds in the LC S Standard were below their acceptance ranges.

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	11/1/2001	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 2 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0417,Q1675,1676,1673,2067,1

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample CROGH

ID of Source:

Collection 10/27/2001 AT

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26472

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	11/1/2001	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	11/1/2001	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 3 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0417,Q1675,1676,1673,2067,1

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample CROGH

ID of Source:

Collection 10/27/2001 AT

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26472

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	4-chlorotoluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Benzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Bromomethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chloroethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Chloromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	11/1/2001	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	11/1/2001	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	11/1/2001	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Naphthalene	< MDL	ug/L	0.5	11/1/2001	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 4 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received LK

Bottle C0417,Q1675,1676,1673,2067,1

Collected By: KRAUSE

Comment:

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Sample CROGH

ID of Source:

Collection 10/27/2001 AT

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26472

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	O-xylene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Styrene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Toluene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	11/1/2001	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	11/1/2001	SV

ONE OF THREE SURROGATES IS 3% ABOVE THE UPPER CONTROL LIMIT.

Organic Chemicals - 525.2

2,4-Dinitrotoluene	< MDL	ug/L	2.0	11/7/2001	DLV
2,6-Dinitrotoluene	< MDL	ug/L	2.0	11/7/2001	DLV
4,4-DDE	< MDL	ug/L	0.80	11/7/2001	DLV
Acetochlor	< MDL	ug/L	2.0	11/7/2001	DLV
Alachlor	< MDL	ug/L	0.20	11/7/2001	DLV
Atrazine	< MDL	ug/L	0.20	11/7/2001	DLV
Benzo(a)pyrene	< MDL	ug/L	0.20	11/7/2001	DLV

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 5 of 6

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WESTLAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received LK

Bottle C0417,Q1675,1676,1673,2067,1

Collected By: KRAUSE

Comment:

Sample CROGH

ID of Source:

Collection 10/27/2001 AT

Submitted 10/29/2001 AT

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AD26472

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
	bis(2-Ethylhexyl)adipate	< MDL	ug/L	0.60	11/7/2001	DLV
	bis(2-Ethylhexyl)phthalate	0.80	ug/L	0.60	11/7/2001	DLV
	Butachlor	< MDL	ug/L	0.40	11/7/2001	DLV
	EPTC	< MDL	ug/L	1.0	11/7/2001	DLV
	Hexachlorobenzene	< MDL	ug/L	0.10	11/7/2001	DLV
	Hexachlorocyclopentadiene	< MDL	ug/L	0.10	11/7/2001	DLV
	Metolachlor	< MDL	ug/L	0.75	11/7/2001	DLV
	Metribuzin	< MDL	ug/L	0.15	11/7/2001	DLV
	Molinate	< MDL	ug/L	0.90	11/7/2001	DLV
	Simazine	< MDL	ug/L	0.40	11/7/2001	DLV
	Terbacil	< MDL	ug/L	2.0	11/7/2001	DLV

The breakdown for Endrin in the Breakdown Standard was 39%. Recoveries for 4 of the 18 compounds in the MDL Standard were outside of their acceptance ranges. Recoveries for 2 of the 18 compounds in the LCS Standard were outside of their acceptance ranges. Recoveries for 3 of the 18 compounds in the Spiked Sample were outside of their acceptance ranges.

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	12/4/2001	DLV
-------------------------	---	------	-----------	-----

A scan of the extract prepared for the 508 analysis, from 35-550 amu using a mass spectrometer, does not reveal the presence of non-target compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 12/24/2001

Environmental Laboratories

emailed

Original 12/24/2001

NYS ELAP # 10108

Page 6 of 6