

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1416,P323,2605,Q2418,2407

Collected By: KAGZI

Comment:

Sample 3

Sample 3

ID of Source:

Collection 1/24/2002 AT 9:46:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01796

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	1/30/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Barium	14.0	ug/L	0.1	1/30/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Manganese	26.9	ug/L	1.0	1/30/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	1/30/2002	PAD
ICP-MS. ALL ANALYTES RECOVERED FOR THE MSD AS WELL!						
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/5/2002	PAD
EPA94	Iron	32	ug/L	20.0	3/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	1/25/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1416,P323,2605,Q2418,2407

Collected By: KAGZI

Comment:

Sample 3

Sample 3

ID of Source:

Collection 1/24/2002 AT 9:46:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01796

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/20/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/6/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recovery for 1 of the 43 compounds in the LCS Standard was above its acceptance range.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1412,P2599,2604,Q2402,2401

Collected By: SPERANZA

Comment:

Sample 58

Sample 58

ID of Source:

Collection 1/24/2002 AT 9:29:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01797

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	1/30/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Barium	13.8	ug/L	0.1	1/30/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Manganese	26.9	ug/L	1.0	1/30/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/5/2002	PAD
EPA94	Iron	28	ug/L	20.0	3/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	1/25/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1412,P2599,2604,Q2402,2401

Collected By: SPERANZA

Comment:

Sample 58

Sample 58

ID of Source:

Collection 1/24/2002 AT 9:29:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01797

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/20/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/6/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recovery for 1 of the 43 compounds in the LCS Standard was above its acceptance range.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1268,P2539,2538,Q235,2290

Collected By: TSUI

Comment:

Sample 02526

Sample 16650

ID of Source:

Collection 1/23/2002 AT 9:05:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01798

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	1/30/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Barium	13.6	ug/L	0.1	1/30/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Copper	7.4	ug/L	1.0	1/30/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Manganese	25.2	ug/L	1.0	1/30/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Zinc	2.1	ug/L	2.0	1/30/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/5/2002	PAD
EPA94	Iron	28	ug/L	20.0	3/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	1/25/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1268,P2539,2538,Q235,2290

Collected By: TSUI

Comment:

Sample 02526

Sample 16650

ID of Source:

Collection 1/23/2002 AT 9:05:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01798

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/20/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/6/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds, except for an unidentified hydrocarbon at 33.4 minutes, and with an estimated level of 14 ug/L. The recovery for 1 of the 43 compounds in the LCS Standard was above its acceptance range.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Sample 02536

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Sample 28550

ID of Source:

Collection 1/23/2002 AT 11:37:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Received KM

Bottle C1277,P2540,2384,Q2239,2248

Collected By: DESSOURCES

Comment:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01799

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	1/30/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Barium	14.0	ug/L	0.1	1/30/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Copper	4.9	ug/L	1.0	1/30/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Manganese	32.3	ug/L	1.0	1/30/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/5/2002	PAD
EPA94	Iron	45	ug/L	20.0	3/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	1/25/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1277,P2540,2384,Q2239,2248

Collected By: DESSOURCES

Comment:

Sample 02536

Sample 28550

ID of Source:

Collection 1/23/2002 AT 11:37:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01799

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/20/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/6/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds, except for an unidentified hydrocarbon at 33.4 minutes, and with an estimated level of 1.4 ug/L. The recovery for 1 of the 43 compounds in the LCS Standard was above its acceptance range.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1285,P2490,2491,Q2249,201

Collected By: BOLTON

Comment:

Sample 02543

Sample 39550

ID of Source:

Collection 1/23/2002 AT 9:24:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01800

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	1/30/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Barium	13.3	ug/L	0.1	1/30/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Copper	5.7	ug/L	1.0	1/30/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Manganese	33.1	ug/L	1.0	1/30/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/5/2002	PAD
EPA94	Iron	37	ug/L	20.0	3/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	1/25/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1285,P2490,2491,Q2249,201

Collected By: BOLTON

Comment:

Sample 02543

Sample 39550

ID of Source:

Collection 1/23/2002 AT 9:24:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01800

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/20/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/6/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recovery for 1 of the 43 compounds in the LCS Standard was above its acceptance range.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1279,P2535,2536,Q2238,2244

Collected By: BROWN

Comment:

Sample 02552

Sample 46250

ID of Source:

Collection 1/23/2002 AT 10:17:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01801

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	1/30/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Barium	14.9	ug/L	0.1	1/30/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Copper	6.7	ug/L	1.0	1/30/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Manganese	27.3	ug/L	1.0	1/30/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Zinc	3.7	ug/L	2.0	1/30/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/5/2002	PAD
EPA94	Iron	38	ug/L	20.0	3/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	1/25/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1279,P2535,2536,Q2238,2244

Collected By: BROWN

Comment:

Sample 02552

Sample 46250

ID of Source:

Collection 1/23/2002 AT 10:17:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01801

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/20/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/6/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds, except for an unidentified hydrocarbon at 33.4 minutes, and with an estimated level of 5.8 ug/L. The recovery for 1 of the 43 compounds in the LCS Standard was above its acceptance range.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1264,P2533,2537,Q2250,2255

Collected By: GERTSIK

Comment:

Sample 02556

Sample 50550

ID of Source:

Collection 1/23/2002 AT 11:46:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01802

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	1/30/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Barium	13.0	ug/L	0.1	1/30/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Copper	4.9	ug/L	1.0	1/30/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Manganese	19.5	ug/L	1.0	1/30/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	1/30/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	1/30/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/5/2002	PAD
EPA94	Iron	25	ug/L	20.0	3/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	1/25/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1264,P2533,2537,Q2250,2255

Collected By: GERTSIK

Comment:

Sample 02556

Sample 50550

ID of Source:

Collection 1/23/2002 AT 11:46:00

Submitted 1/24/2002 AT 10:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE01802

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/20/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/6/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds, except for an unidentified hydrocarbon at 33.4 minutes, and with an estimated level of 0.60 ug/L. The recovery for 1 of the 43 compounds in the LCS Standard was above its acceptance range.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle P668,Q2396
Collected By: LAB
Comment:

Sample FBD

Sample FBD
ID of Source:
Collection 1/23/2002 AT 12:00:00
Submitted 1/24/2002 AT 10:41:00
Sample Type: POT_DW
PWS No.: **Source Code:**
Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE01803

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
GCMS Scan For Unknowns						
	Other unknown compounds	.	ug/L		3/6/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recovery for 1 of the 43 compounds in the LCS Standard was above its acceptance range.

Approved Pam Dilsizian QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed Original 3/7/2002

NYS ELAP # 10108

Page 1 of 1