

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle c1418,q2416,2513,2515,2517,24

Collected By: TSUI

Comment:

Sample 3

Sample 3

ID of Source:

Collection 1/30/2002 AT 10:40:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02334

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	2/4/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Barium	13.4	ug/L	0.1	2/4/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Manganese	21.4	ug/L	1.0	2/4/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/11/2002	PAD
EPA94	Iron	29	ug/L	20.0	3/11/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/5/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
 Received LK
 Bottle c1418,q2416,2513,2515,2517,24
 Collected By: TSUI
 Comment:

Sample 3

Sample 3
 ID of Source:
 Collection 1/30/2002 AT 10:40:00
 Submitted 1/30/2002 AT 11:36:00
 Sample Type: POT_DW
 PWS No.: Source Code:
 Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No.		AE02334					
Method	Test Description	Results	Units	MDL	Analyzed on	Validator	
EPA94	Molybdenum	< MDL	ug/L	50.0	3/11/2002	PAD	
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD	
SM18	Tin	< MDL	ug/L	100	2/21/2002	PAD	

Organics

GCMS Scan For Unknowns							
	Other unknown compounds		ug/L		3/22/2002	DLV	

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian		QA Officer	Date Approved: 3/25/2002	
Environmental Laboratories			emailed	Original 3/25/2002
NYS ELAP # 10108			Page 2 of 2	

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle c1142,q1963,1982,p2131,2136

Collected By: TSUI

Comment:

Sample 58

Sample 58

ID of Source:

Collection 1/30/2002 AT 10:08:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02335

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	2/4/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Barium	13.1	ug/L	0.1	2/4/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Manganese	18.4	ug/L	1.0	2/4/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/11/2002	PAD
EPA94	Iron	29	ug/L	20.0	3/11/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/5/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle c1142,q1963,1982,p2131,2136

Collected By: TSUI

Comment:

Sample 58

Sample 58

ID of Source:

Collection 1/30/2002 AT 10:08:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02335

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/21/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/22/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle c1517,q2472,2471,p1157,979

Collected By: GERTSIK

Comment:

Sample 03205

Sample 14950

ID of Source:

Collection 1/29/2002 AT 8:46:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02336

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Inorganics</u>						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	2/4/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Barium	17.2	ug/L	0.1	2/4/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Chromium	1.4	ug/L	1.0	2/4/2002	PAD
EPA94	Copper	6.9	ug/L	1.0	2/4/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Manganese	30.2	ug/L	1.0	2/4/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/11/2002	PAD
EPA94	Iron	40	ug/L	20.0	3/11/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/5/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle c1517,q2472,2471,p1157,979

Collected By: GERTSIK

Comment:

Sample 03205

Sample 14950

ID of Source:

Collection 1/29/2002 AT 8:46:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02336

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/21/2002	PAD
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		3/22/2002	DLV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle c1516,q2483,2485,p662,978

Collected By: KAGZI

Comment:

Sample 03217

Sample 24050

ID of Source:

Collection 1/29/2002 AT 10:08:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02337

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWQ						
EPA94	Antimony	< MDL	ug/L	0.1	2/4/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Barium	14.8	ug/L	0.1	2/4/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Copper	12.7	ug/L	1.0	2/4/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Manganese	21.9	ug/L	1.0	2/4/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/11/2002	PAD
EPA94	Iron	40	ug/L	20.0	3/11/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/5/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley

Received LK

Bottle c1516,q2483,2485,p662,978

Collected By: KAGZI

Comment:

Sample 03217

Sample 24050

ID of Source:

Collection 1/29/2002 AT 10:08:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02337

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/21/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/22/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle c1520,q2477,2475,p2647,2648,

Collected By: BOLTON

Comment:

Sample 03222

Sample 30450

ID of Source:

Collection 1/29/2002 AT 8:42:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02338

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	2/4/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Barium	16.0	ug/L	0.1	2/4/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Chromium	1.5	ug/L	1.0	2/4/2002	PAD
EPA94	Copper	6.6	ug/L	1.0	2/4/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Manganese	24.6	ug/L	1.0	2/4/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/11/2002	PAD
EPA94	Iron	30	ug/L	20.0	3/11/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/5/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle c1520,q2477,2475,p2647,2648,

Collected By: BOLTON

Comment:

Sample 03222

Sample 30450

ID of Source:

Collection 1/29/2002 AT 8:42:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02338

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/21/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/22/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Sample 03237

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle c1508,q839,826,p2646,2645

Collected By: SPERANZA

Comment:

Sample 45750

ID of Source:

Collection 1/29/2002 AT 11:12:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02339

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	2/4/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Barium	13.4	ug/L	0.1	2/4/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Copper	5.9	ug/L	1.0	2/4/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Manganese	16.1	ug/L	1.0	2/4/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	2/4/2002	PAD
Se and Ag did not recover. Results are suspect due to unsolved matrix effects						
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/11/2002	PAD
EPA94	Iron	26	ug/L	20.0	3/11/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/5/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle c1508,q839,826,p2646,2645

Collected By: SPERANZA

Comment:

Sample 03237

Sample 45750

ID of Source:

Collection 1/29/2002 AT 11:12:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02339

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/21/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/22/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle c1514,q819,817,p626,993

Collected By: HOYT

Comment:

Sample 02345

Sample 58350

ID of Source:

Collection 1/29/2002 AT 9:53:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02340

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWQ						
EPA94	Antimony	< MDL	ug/L	0.1	2/4/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Barium	13.6	ug/L	0.1	2/4/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Chromium	1.1	ug/L	1.0	2/4/2002	PAD
EPA94	Copper	6.8	ug/L	1.0	2/4/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Manganese	14.9	ug/L	1.0	2/4/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	2/4/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	2/4/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/11/2002	PAD
EPA94	Iron	24	ug/L	20.0	3/11/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/5/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle c1514,q819,817,p626,993

Collected By: HOYT

Comment:

Sample 02345

Sample 58350

ID of Source:

Collection 1/29/2002 AT 9:53:00

Submitted 1/30/2002 AT 11:36:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02340

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/11/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/4/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/21/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/22/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle q833, p1001

Collected By: LAB

Comment:

Sample FBD

Sample FBD

ID of Source:

Collection 1/30/2002 AT 12:00:00

Submitted 1/30/2002 AT 11:41:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE02341

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		3/22/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/25/2002

Environmental Laboratories

emailed

Original 3/25/2002

NYS ELAP # 10108

Page 1 of 1