

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1465,p2826,2825,q2627,764,k9

Collected By: SCOTT

Comment: possible contamination in q2627 - acid cap fell into sample bottle.

Sample DEL18

ID of Source:

Collection 2/6/2002 AT 8:19:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03014

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWEL New</u>						
EPA94	Antimony	0.14	ug/L	0.1	2/13/2002	AMB
EPA94	Arsenic	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Barium	13.4	ug/L	0.1	2/13/2002	AMB
EPA94	Beryllium	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Cadmium	< MDL	ug/L	0.2	2/13/2002	AMB
EPA94	Chromium	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Copper	1.7	ug/L	1.0	2/13/2002	AMB
EPA94	Lead	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Manganese	21.9	ug/L	1.0	2/13/2002	AMB
EPA94	Nickel	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Selenium	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Silver	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Thallium	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Zinc	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/15/2002	AMB
EPA94	Cobalt	< MDL	ug/L	20.0	3/15/2002	AMB
EPA94	Iron	27	ug/L	20.0	3/15/2002	AMB
EPA79	Mercury	< MDL	ug/L	0.40	2/8/2002	AMB

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1465,p2826,2825,q2627,764,k9

Collected By: SCOTT

Comment: possible contamination in q2627 - acid cap fell into sample bottle.

Sample DEL18

ID of Source:

Collection 2/6/2002 AT 8:19:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03014

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/15/2002	AMB
EPA'79	Potable Metals Digestion	Completed			2/7/2002	AMB
SM18	Tin	< MDL	ug/L	100	2/25/2002	AMB
Organics						
Volatile Organic Compounds						
524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/15/2002	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	2/15/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/15/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Sample DEL18

Received EP

ID of Source:

Bottle c1465,p2826,2825,q2627,764,k9

Collection 2/6/2002 AT 8:19:00

Collected By: SCOTT

Submitted 2/6/2002 AT 2:57:00

Comment: possible contamination in q2627 - acid cap fell into sample bottle.

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03014

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/15/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1465,p2826,2825,q2627,764,k9

Collected By: SCOTT

Comment: possible contamination in q2627 - acid cap fell into sample bottle.

Sample DEL18

ID of Source:

Collection 2/6/2002 AT 8:19:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03014

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/15/2002	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/15/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/15/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1465,p2826,2825,q2627,764,k9

Collected By: SCOTT

Comment: possible contamination in q2627 - acid cap fell into sample bottle.

Sample DEL18

ID of Source:

Collection 2/6/2002 AT 8:19:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03014

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/15/2002	SV
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		2/15/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

The recoveries for 7 of the 43 compounds in the LCS Standard were below their acceptance ranges.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 5 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1476,p2729,2580,q2524,2525,k

Collected By: SCOTT

Comment:

Sample CATLEFF

ID of Source:

Collection 2/6/2002 AT 8:00:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03015

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWE New</u>						
EPA94	Antimony	< MDL	ug/L	0.1	2/13/2002	AMB
EPA94	Arsenic	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Barium	12.8	ug/L	0.1	2/13/2002	AMB
EPA94	Beryllium	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Cadmium	< MDL	ug/L	0.2	2/13/2002	AMB
EPA94	Chromium	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Copper	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Lead	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Manganese	20.2	ug/L	1.0	2/13/2002	AMB
EPA94	Nickel	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Selenium	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Silver	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Thallium	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Zinc	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/15/2002	AMB
EPA94	Cobalt	< MDL	ug/L	20.0	3/15/2002	AMB
EPA94	Iron	33	ug/L	20.0	3/15/2002	AMB
EPA79	Mercury	< MDL	ug/L	0.40	2/8/2002	AMB

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1476,p2729,2580,q2524,2525,k

Collected By: SCOTT

Comment:

Sample CATLEFF

ID of Source:

Collection 2/6/2002 AT 8:00:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03015

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/15/2002	AMB
EPA'79	Potable Metals Digestion	Completed			2/7/2002	AMB
SM18	Tin	< MDL	ug/L	100	2/25/2002	AMB

Organics

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/15/2002	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	2/15/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/15/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Sample CATLEFF

Received EP

ID of Source:

Bottle c1476,p2729,2580,q2524,2525,k

Collection 2/6/2002 AT 8:00:00

Collected By: SCOTT

Submitted 2/6/2002 AT 2:57:00

Comment:

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03015

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/15/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Sample CATLEFF

Received EP

ID of Source:

Bottle c1476,p2729,2580,q2524,2525,k

Collection 2/6/2002 AT 8:00:00

Collected By: SCOTT

Submitted 2/6/2002 AT 2:57:00

Comment:

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03015

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/15/2002	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/15/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/15/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received EP

Sample CATLEFF
ID of Source:
Collection 2/6/2002 AT 8:00:00
Submitted 2/6/2002 AT 2:57:00

Bottle c1476,p2729,2580,q2524,2525,k
Collected By: SCOTT
Comment:

Sample Type: POT_DW
PWS No.: **Source Code:** 000

Type Descriptor:
Sample chilled on arrival? : yes

Report

Sample No. AE03015

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/15/2002	SV
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		2/15/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.
The recoveries for 7 of the 43 compounds in the LCS Standard were below their acceptance ranges.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 5 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Sample CROGH

Received EP

ID of Source:

Bottle c1440,p1181,1183,q2622,2629,k

Collection 2/6/2002 AT 11:50:00

Collected By: SCOTT

Submitted 2/6/2002 AT 2:57:00

Comment:

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03016

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWEL New</u>						
EPA94	Antimony	< MDL	ug/L	0.1	2/13/2002	AMB
EPA94	Arsenic	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Barium	28.3	ug/L	0.1	2/13/2002	AMB
EPA94	Beryllium	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Cadmium	< MDL	ug/L	0.2	2/13/2002	AMB
EPA94	Chromium	1.0	ug/L	1.0	2/13/2002	AMB
EPA94	Copper	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Lead	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Manganese	65.8	ug/L	1.0	2/13/2002	AMB
EPA94	Nickel	1.0	ug/L	1.0	2/13/2002	AMB
EPA94	Selenium	1.2	ug/L	1.0	2/13/2002	AMB
EPA94	Silver	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94	Thallium	< MDL	ug/L	1.0	2/13/2002	AMB
EPA94	Zinc	< MDL	ug/L	2.0	2/13/2002	AMB
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/15/2002	AMB
EPA94	Cobalt	< MDL	ug/L	20.0	3/15/2002	AMB
EPA94	Iron	57	ug/L	20.0	3/15/2002	AMB
EPA79	Mercury	< MDL	ug/L	0.40	2/8/2002	AMB

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1440,p1181,1183,q2622,2629,k

Collected By: SCOTT

Comment:

Sample CROGH

ID of Source:

Collection 2/6/2002 AT 11:50:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03016

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/15/2002	AMB
EPA'79	Potable Metals Digestion	Completed			2/7/2002	AMB
SM18	Tin	< MDL	ug/L	100	2/25/2002	AMB

Organics

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/15/2002	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	2/15/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/15/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1440,p1181,1183,q2622,2629,k

Collected By: SCOTT

Comment:

Sample CROGH

ID of Source:

Collection 2/6/2002 AT 11:50:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03016

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/15/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1440,p1181,1183,q2622,2629,k

Collected By: SCOTT

Comment:

Sample CROGH

ID of Source:

Collection 2/6/2002 AT 11:50:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03016

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/15/2002	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/15/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/15/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/15/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/15/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1440,p1181,1183,q2622,2629,k

Collected By: SCOTT

Comment:

Sample CROGH

ID of Source:

Collection 2/6/2002 AT 11:50:00

Submitted 2/6/2002 AT 2:57:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE03016

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/15/2002	SV
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		3/12/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. Because of the low Surrogate Standard recovery (69%) this sample will be reextracted and reanalyzed.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 5 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample FBW

Attention: Steve Schindler
Received EP
Bottle p1046,q861
Collected By: LAB
Comment:

Sample FBW
ID of Source:
Collection 2/6/2002 AT 12:00:00
Submitted 2/6/2002 AT 3:00:00
Sample Type: DI WATER
PWS No.: **Source Code:** 000

Type Descriptor:
Sample chilled on arrival? : yes

Report

Sample No. AE03017

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		3/12/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian **QA Officer**

Date Approved: 3/13/2002

Environmental Laboratories

emailed Original 3/13/2002

NYS ELAP # 10108

Page 1 of 1