

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle q2213,2227,p1358,1612

Collected By: PATEL/AP

Comment: c bottle opened and spilled per collector

Sample 3

Sample 3

ID of Source:

Collection 2/12/2002 AT 9:50:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03434

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		3/12/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries of 5 of the 43 compounds in the LCS Standard were outside of their acceptance ranges.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/13/2002

Environmental Laboratories

emailed

Original 3/13/2002

NYS ELAP # 10108

Page 1 of 1

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received JC

Bottle c1592,q64,107,p2949,2950

Collected By: PATEL/AP

Comment:

Sample 58

Sample 58

ID of Source:

Collection 2/12/2002 AT 9:15:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03435

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/7/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Barium	14.1	ug/L	0.1	3/7/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Manganese	21.0	ug/L	1.0	3/7/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/27/2002	PAD
EPA94	Iron	38	ug/L	20.0	3/27/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/20/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed

Original 3/27/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle c1592,q64,107,p2949,2950

Collected By: PATEL/AP

Comment:

Sample 58

Sample 58

ID of Source:

Collection 2/12/2002 AT 9:15:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03435

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/14/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/25/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/12/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries of 5 of the 43 compounds in the LCS Standard were outside of their acceptance ranges.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed

Original 3/27/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle c1603,q2721,2720,p2888,2881

Collected By: SPERANZA

Comment:

Sample 04685

Sample 11150

ID of Source:

Collection 2/11/2002 AT 10:33:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03436

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/7/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Barium	13.5	ug/L	0.1	3/7/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Copper	4.7	ug/L	1.0	3/7/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Manganese	19.8	ug/L	1.0	3/7/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/27/2002	PAD
EPA94	Iron	37	ug/L	20.0	3/27/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/20/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed

Original 3/27/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received JC
Bottle c1603,q2721,2720,p2888,2881
Collected By: SPERANZA
Comment:

Sample 04685

Sample 11150
ID of Source:
Collection 2/11/2002 AT 10:33:00
Submitted 2/12/2002 AT 11:05:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? :

Report

Sample No. AE03436

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/14/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/25/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	ug/L	3/12/2002	DLV
-------------------------	------	-----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries of 5 of the 43 compounds in the LCS Standard were outside of their acceptance ranges.

Approved Pam Dilsizian QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed Original 3/27/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle c1637,q2752,2740,p2916,2913

Collected By: BOLTON

Comment:

Sample 04696

Sample 23950

ID of Source:

Collection 2/11/2002 AT 8:20:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03437

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Inorganics</u>						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/7/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Barium	15.1	ug/L	0.1	3/7/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Copper	9.0	ug/L	1.0	3/7/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Manganese	27.7	ug/L	1.0	3/7/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Zinc	6.0	ug/L	2.0	3/7/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/27/2002	PAD
EPA94	Iron	45	ug/L	20.0	3/27/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/20/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle c1637,q2752,2740,p2916,2913

Collected By: BOLTON

Comment:

Sample 04696

Sample 23950

ID of Source:

Collection 2/11/2002 AT 8:20:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03437

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/14/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/25/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	ug/L	3/29/2002	DLV
-------------------------	------	-----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for the compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle c1623,q2679,2677,p2851,2862

Collected By: SPERANZA

Comment:

Sample 04708

Sample 35350

ID of Source:

Collection 2/11/2002 AT 11:07:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03438

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/7/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Barium	31.2	ug/L	0.1	3/7/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Chromium	1.1	ug/L	1.0	3/7/2002	PAD
EPA94	Copper	14.8	ug/L	1.0	3/7/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Manganese	57.2	ug/L	1.0	3/7/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Zinc	2.5	ug/L	2.0	3/7/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/27/2002	PAD
EPA94	Iron	61	ug/L	20.0	3/27/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/20/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed

Original 3/27/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received JC
Bottle c1623,q2679,2677,p2851,2862
Collected By: SPERANZA
Comment:

Sample 04708

Sample 35350
ID of Source:
Collection 2/11/2002 AT 11:07:00
Submitted 2/12/2002 AT 11:05:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? :

Report

Sample No. AE03438

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/14/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/25/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	ug/L	3/14/2002	DLV
-------------------------	------	-----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 2 of the 43 compounds in the LCS Standard were outside their acceptance ranges.

Approved Pam Dilsizian QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed Original 3/27/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle c1630,q2750,2746,p2896,2927

Collected By: TIGLAO

Comment:

Sample 04717

Sample 45250

ID of Source:

Collection 2/11/2002 AT 11:11:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03439

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/7/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Barium	14.6	ug/L	0.1	3/7/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Copper	5.2	ug/L	1.0	3/7/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Manganese	22.4	ug/L	1.0	3/7/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Zinc	4.4	ug/L	2.0	3/7/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/27/2002	PAD
EPA94	Iron	43	ug/L	20.0	3/27/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/20/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed

Original 3/27/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received JC

Bottle c1630,q2750,2746,p2896,2927

Collected By: TIGLAO

Comment:

Sample 04717

Sample 45250

ID of Source:

Collection 2/11/2002 AT 11:11:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03439

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/14/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/25/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/14/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 2 of the 43 compounds in the LCS Standard were outside their acceptance ranges.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed

Original 3/27/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received JC

Bottle c1602,q2742,2744,p2903,2909

Collected By: VASSILEV

Comment:

Sample 04722

Sample 51550

ID of Source:

Collection 2/11/2002 AT 9:58:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03440

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/7/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Barium	14.1	ug/L	0.1	3/7/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Copper	5.8	ug/L	1.0	3/7/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Manganese	20.6	ug/L	1.0	3/7/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/7/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/7/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/27/2002	PAD
EPA94	Iron	26	ug/L	20.0	3/27/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/20/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed

Original 3/27/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle c1602,q2742,2744,p2903,2909

Collected By: VASSILEV

Comment:

Sample 04722

Sample 51550

ID of Source:

Collection 2/11/2002 AT 9:58:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03440

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/27/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/14/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/25/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/14/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 2 of the 43 compounds in the LCS Standard were outside their acceptance ranges.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/27/2002

Environmental Laboratories

emailed

Original 3/27/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle q2768, p2843

Collected By: LAB

Comment:

Report

Sample FBD

Sample FBD

ID of Source:

Collection 2/12/2002 AT 12:00:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Sample No. AE03441

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		3/14/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 2 of the 43 compounds in the LCS Standard were outside their acceptance ranges.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/15/2002

Environmental Laboratories

emailed

Original 3/15/2002

NYS ELAP # 10108

Page 1 of 1

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received JC

Bottle Q2764, P1351

Collected By: LAB

Comment:

Sample FBD

Sample FBD

ID of Source:

Collection 2/12/2002 AT 12:00:00

Submitted 2/12/2002 AT 11:05:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? :

Report

Sample No. AE03454

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		3/14/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 2 of the 43 compounds in the LCS Standard were outside their acceptance ranges.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/15/2002

Environmental Laboratories

emailed

Original 3/15/2002

NYS ELAP # 10108

Page 1 of 1