

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1524,P991,1950,Q1092,536

Collected By: YACOB

Comment:

Sample 3

Sample 3

ID of Source:

Collection 2/16/2002 AT 9:06:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03822

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	13.9	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	20.1	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/29/2002	PAD
EPA94	Iron	34	ug/L	20.0	3/29/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/21/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1524,P991,1950,Q1092,536

Collected By: YACoub

Comment:

Sample 3

Sample 3

ID of Source:

Collection 2/16/2002 AT 9:06:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03822

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/20/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/26/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/22/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. Recoveries for the LCS Standard compounds were high. New acceptance ranges will be calculated.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1541,P0030,1627,Q1405,1399

Collected By: RIBANDO

Comment:

Sample 58

Sample 58

ID of Source:

Collection 2/16/2002 AT 8:33:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03823

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.5	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	19.5	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/29/2002	PAD
EPA94	Iron	40	ug/L	20.0	3/29/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/21/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1541,P0030,1627,Q1405,1399

Collected By: RIBANDO

Comment:

Sample 58

Sample 58

ID of Source:

Collection 2/16/2002 AT 8:33:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03823

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/20/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/26/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/29/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for the compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1584,P2941,2943,Q772,2775

Collected By: DESSOURCES

Comment:

Sample 05190

Sample 18650

ID of Source:

Collection 2/15/2002 AT 8:31:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03824

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	0.11	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	15.3	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	6.9	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	20.3	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/29/2002	PAD
EPA94	Iron	36	ug/L	20.0	3/29/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/21/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1584,P2941,2943,Q772,2775

Collected By: DESSOURCES

Comment:

Sample 05190

Sample 18650

ID of Source:

Collection 2/15/2002 AT 8:31:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03824

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/20/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/26/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/29/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for the compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1585,P2879,2938,Q2781,2782

Collected By: BOLTON

Comment:

Sample 05194

Sample 22650

ID of Source:

Collection 2/15/2002 AT 10:26:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03825

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWQ						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.9	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	8.8	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	25.7	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/29/2002	PAD
EPA94	Iron	42	ug/L	20.0	3/29/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/21/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle C1585,P2879,2938,Q2781,2782
Collected By: BOLTON
Comment:

Sample 05194

Sample 22650
ID of Source:
Collection 2/15/2002 AT 10:26:00
Submitted 2/16/2002 AT 10:00:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03825

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/20/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/26/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	ug/L	3/29/2002	DLV
-------------------------	------	-----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for the compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1589,P1303,2947,Q2774,2773

Collected By: SPERANZA

Comment:

Sample 05205

Sample 38250

ID of Source:

Collection 02/15/02 AT 11:36:00

Submitted 02/16/02 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Report

Sample No. AE03826

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	03/14/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	03/14/02	PAD
EPA94	Barium	13.7	ug/L	0.1	03/14/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	03/14/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	03/14/02	PAD
EPA94	Copper	4.4	ug/L	1.0	03/14/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	03/14/02	PAD
EPA94	Manganese	18.9	ug/L	1.0	03/14/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	03/14/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	03/14/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	03/14/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	03/14/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	03/14/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	03/29/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	03/29/02	PAD
EPA94	Iron	37	ug/L	20.0	03/29/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	02/21/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/17/02

Environmental Laboratories

emailed

Copy 04/18/02

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1589,P1303,2947,Q2774,2773

Collected By: SPERANZA

Comment:

Sample 05205

Sample 38250

ID of Source:

Collection 02/15/02 AT 11:36:00

Submitted 02/16/02 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Report

Sample No. AE03826

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	03/29/02	PAD
EPA'79	Potable Metals Digestion	Completed			02/20/02	PAD
SM18	Tin	< MDL	ug/L	100	02/26/02	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

04/16/02

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 2 of the 43 compounds in the LCS Standard were high. This sample was extracted twice with Surrogate Standard recoveries of 68% and 64%.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/17/02

Environmental Laboratories

emailed

Copy 04/18/02

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1590,P2935,2928,Q2759,2762

Collected By: BROWN

Comment:

Sample 05215

Sample 41950

ID of Source:

Collection 2/15/2002 AT 8:38:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03827

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.2	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	7.5	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	18.4	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	32	ug/L	50.0	3/29/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/29/2002	PAD
EPA94	Iron	41	ug/L	20.0	3/29/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/21/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle C1590,P2935,2928,Q2759,2762

Collected By: BROWN

Comment:

Sample 05215

Sample 41950

ID of Source:

Collection 2/15/2002 AT 8:38:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03827

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/20/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/26/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/29/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for the compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1597,P936,2937,Q2780,2777

Collected By: HOYT

Comment:

Sample 05219

Sample 50250

ID of Source:

Collection 2/15/2002 AT 12:06:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03828

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.7	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	1.0	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	5.6	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	20.4	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	5.4	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	3/29/2002	PAD
EPA94	Iron	32	ug/L	20.0	3/29/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/21/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle C1597,P936,2937,Q2780,2777

Collected By: HOYT

Comment:

Sample 05219

Sample 50250

ID of Source:

Collection 2/15/2002 AT 12:06:00

Submitted 2/16/2002 AT 10:00:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03828

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	3/29/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/20/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/26/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

3/29/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for the compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed

Original 3/29/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
 Received KM
 Bottle P1103,Q1412
 Collected By: LAB
 Comment:

Sample FBD

Sample FBD

ID of Source:
 Collection 2/16/2002 AT 12:00:00
 Submitted 2/16/2002 AT 10:00:00
 Sample Type: POT_DW
 PWS No.:

Source Code:

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AE03829

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds		ug/L		3/29/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for the compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian QA Officer

Date Approved: 3/29/2002

Environmental Laboratories

emailed Original 3/29/2002

NYS ELAP # 10108

Page 1 of 1