

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5118
Collected By: JB
Comment:

Sample 3

Sample 3

ID of Source:
Collection 2/14/2002 AT 10:00:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.:

Source Code:

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03917

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	4.0	ug/L	0.5	2/28/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/28/2002	SV
524.2	*THM-Chloroform	27	ug/L	0.5	2/28/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/28/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5118
Collected By: JB
Comment:

Sample 3

Sample 3

ID of Source:
Collection 2/14/2002 AT 10:00:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.:

Source Code:

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03917

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/28/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5118
Collected By: JB
Comment:

Sample 3

Sample 3
ID of Source:
Collection 2/14/2002 AT 10:00:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03917

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/28/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/28/2002	SV

The recovery of 2-butanone in the QC sample was 200%.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5048
Collected By: JB
Comment:

Sample 16250

Sample 16250
ID of Source:
Collection 2/14/2002 AT 11:44:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03918

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	3.0	ug/L	0.5	2/28/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/28/2002	SV
524.2	*THM-Chloroform	19	ug/L	0.5	2/28/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/28/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5048
Collected By: JB
Comment:

Sample 16250

Sample 16250
ID of Source:
Collection 2/14/2002 AT 11:44:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03918

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/28/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle 5048

Collected By: JB

Comment:

Sample 16250

Sample 16250

ID of Source:

Collection 2/14/2002 AT 11:44:00

Submitted 2/19/2002 AT 11:35:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03918

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/28/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/28/2002	SV

The recovery of 2-butanone in the QC sample was 200%.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5096
Collected By: JB
Comment:

Sample 32

Sample 32
ID of Source:
Collection 2/14/2002 AT 11:15:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03919

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	6.5	ug/L	0.5	2/28/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/28/2002	SV
524.2	*THM-Chloroform	25	ug/L	0.5	2/28/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/28/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5096
Collected By: JB
Comment:

Sample 32

Sample 32
ID of Source:
Collection 2/14/2002 AT 11:15:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03919

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/28/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5096
Collected By: JB
Comment:

Sample 32

Sample 32
ID of Source:
Collection 2/14/2002 AT 11:15:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03919

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/28/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/28/2002	SV

The recovery of 2-butanone in the QC sample was 200%.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley
Received KM
Bottle 5059
Collected By: JB
Comment:

Sample 29050

Sample 29050
ID of Source:
Collection 2/14/2002 AT 10:24:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03920

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	3.7	ug/L	0.5	2/28/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/28/2002	SV
524.2	*THM-Chloroform	23	ug/L	0.5	2/28/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/28/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5059
Collected By: JB
Comment:

Sample 29050

Sample 29050
ID of Source:
Collection 2/14/2002 AT 10:24:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03920

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/28/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5059
Collected By: JB
Comment:

Sample 29050

Sample 29050
ID of Source:
Collection 2/14/2002 AT 10:24:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03920

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/28/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/28/2002	SV

The recovery of 2-butanone in the QC sample was 200%.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle 5079

Collected By: JB

Comment:

Sample 50750

Sample 50750

ID of Source:

Collection 2/14/2002 AT 10:16:00

Submitted 2/19/2002 AT 11:35:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03921

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	3.8	ug/L	0.5	2/28/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/28/2002	SV
524.2	*THM-Chloroform	30	ug/L	0.5	2/28/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/28/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/13/2002

Environmental Laboratories

emailed

Original 3/13/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5079
Collected By: JB
Comment:

Sample 50750

Sample 50750
ID of Source:
Collection 2/14/2002 AT 10:16:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03921

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/28/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/13/2002

Environmental Laboratories

emailed

Original 3/13/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle 5079

Collected By: JB

Comment:

Sample 50750

Sample 50750

ID of Source:

Collection 2/14/2002 AT 10:16:00

Submitted 2/19/2002 AT 11:35:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03921

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/28/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/28/2002	SV

The recovery of 2-butanone in the QC sample was 200%.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/13/2002

Environmental Laboratories

emailed

Original 3/13/2002

NYS ELAP # 10108

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5119
Collected By: JB
Comment:

Sample 58

Sample 58
ID of Source:
Collection 2/14/2002 AT 9:25:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03922

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	2.5	ug/L	0.5	2/28/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/28/2002	SV
524.2	*THM-Chloroform	16	ug/L	0.5	2/28/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/28/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5119
Collected By: JB
Comment:

Sample 58

Sample 58
ID of Source:
Collection 2/14/2002 AT 9:25:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03922

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/28/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle 5119

Collected By: JB

Comment:

Sample 58

Sample 58

ID of Source:

Collection 2/14/2002 AT 9:25:00

Submitted 2/19/2002 AT 11:35:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03922

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/28/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/28/2002	SV

The recovery of 2-butanone in the QC sample was 200%.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5097
Collected By: JB
Comment:

Sample 33

Sample 33
ID of Source:
Collection 2/14/2002 AT 11:30:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03923

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	6.9	ug/L	0.5	2/28/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	2/28/2002	SV
524.2	*THM-Chloroform	26	ug/L	0.5	2/28/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	2/28/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5097
Collected By: JB
Comment:

Sample 33

Sample 33
ID of Source:
Collection 2/14/2002 AT 11:30:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03923

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	2/28/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	2/28/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received KM

Bottle 5097

Collected By: JB

Comment:

Sample 33

Sample 33

ID of Source:

Collection 2/14/2002 AT 11:30:00

Submitted 2/19/2002 AT 11:35:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03923

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	2/28/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	2/28/2002	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	2/28/2002	SV

The recovery of 2-butanone in the QC sample was 200%.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5072
Collected By: JB
Comment:

Sample 40650

Sample 40650
ID of Source:
Collection 2/14/2002 AT 8:47:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03924

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	2.1	ug/L	0.5	3/1/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	3/1/2002	SV
524.2	*THM-Chloroform	11	ug/L	0.5	3/1/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	3/1/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received KM

Bottle 5072

Collected By: JB

Comment:

Sample 40650

Sample 40650

ID of Source:

Collection 2/14/2002 AT 8:47:00

Submitted 2/19/2002 AT 11:35:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03924

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	3/1/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	3/1/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5072
Collected By: JB
Comment:

Sample 40650

Sample 40650
ID of Source:
Collection 2/14/2002 AT 8:47:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03924

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	3/1/2002	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	3/1/2002	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Naphthalene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	O-xylene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Styrene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Toluene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Vinyl chloride	< MDL	ug/L	0.5	3/1/2002	SV

The recovery of 2-butanone in the QC sample was 200%.

1,1-dichloro-2-propanone is present as a 524.2 TIC. The estimated concentration is 1.6 ug/L.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 3 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5065
Collected By: JB
Comment:

Sample 33950

Sample 33950
ID of Source:
Collection 2/14/2002 AT 11:53:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03925

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>Volatile Organic Compounds</u>						
524.2	*THM-Bromodichloromethane	7.4	ug/L	0.5	3/1/2002	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	3/1/2002	SV
524.2	*THM-Chloroform	31	ug/L	0.5	3/1/2002	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	3/1/2002	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 1 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received KM
Bottle 5065
Collected By: JB
Comment:

Sample 33950

Sample 33950

ID of Source:

Collection 2/14/2002 AT 11:53:00

Submitted 2/19/2002 AT 11:35:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE03925

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	3/1/2002	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Benzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Bromomethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Chloroethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Chloromethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	3/1/2002	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	3/1/2002	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 3/7/2002

Environmental Laboratories

emailed

Original 3/7/2002

NYS ELAP # 10108

Page 2 of 3

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley
Received KM
Bottle 5115
Collected By: JB
Comment:

Sample FB

Sample FB

ID of Source:
Collection 2/14/2002 AT 12:00:00
Submitted 2/19/2002 AT 11:35:00
Sample Type: POT_DW
PWS No.:

Source Code:

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE03926

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
<u>Organics</u>	VOC COMMENT	completed			2/27/2002 10:28 AM	SV

There are no extraneous peaks present in this sample. However, all of the QC did not pass at the time that this sample was run, therefore, quantitative results cannot be reported.

Approved Pam Dilsizian

QA Officer

Date Approved: 3/13/2002

Environmental Laboratories

emailed

Original 3/13/2002

NYS ELAP # 10108

Page 1 of 1