

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle C0848,Q2842,2847,P1760,1687

Collected By: BROWN

Comment:

Sample 3

Sample 3

ID of Source:

Collection 2/22/2002 AT 9:45:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04330

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	13.9	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	1.2	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	22.4	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/2/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/2/2002	PAD
EPA94	Iron	42	ug/L	20.0	4/2/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/26/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/2/2002

Environmental Laboratories

emailed

Original 4/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received LK
Bottle C0848,Q2842,2847,P1760,1687
Collected By: BROWN
Comment:

Sample 3

Sample 3
ID of Source:
Collection 2/22/2002 AT 9:45:00
Submitted 2/22/2002 AT 10:32:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE04330

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/2/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/27/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/27/2002	PAD

Organics

GCMS Scan For Unknowns						
	Other unknown compounds	.	ug/L		4/1/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.
 The recoveries for 10 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian QA Officer

Date Approved: 4/2/2002

Environmental Laboratories

emailed Original 4/2/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle C9959,Q2841,2838,P1533,1961

Collected By: BROWN/HOYT

Comment:

Sample 58

Sample 58

ID of Source:

Collection 2/22/2002 AT 9:15:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04331

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.1	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	1.1	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	21.0	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/2/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/2/2002	PAD
EPA94	Iron	40	ug/L	20.0	4/2/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/26/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/2/2002

Environmental Laboratories

emailed

Original 4/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle C9959,Q2841,2838,P1533,1961

Collected By: BROWN/HOYT

Comment:

Sample 58

Sample 58

ID of Source:

Collection 2/22/2002 AT 9:15:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04331

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/2/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/27/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/27/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/1/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.
The recoveries for 10 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/2/2002

Environmental Laboratories

emailed

Original 4/2/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received LK
Bottle C1535,Q2831,2859,P1302,1317
Collected By: SPERANZA
Comment:

Sample 05802

Sample 11550
ID of Source:
Collection 2/21/2002 AT 9:42:00
Submitted 2/22/2002 AT 10:32:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE04332

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	13.8	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	7.7	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	22.8	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/2/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/2/2002	PAD
EPA94	Iron	44	ug/L	20.0	4/2/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/26/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/2/2002

Environmental Laboratories

emailed

Original 4/2/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle C1535,Q2831,2859,P1302,1317

Collected By: SPERANZA

Comment:

Sample 05802

Sample 11550

ID of Source:

Collection 2/21/2002 AT 9:42:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04332

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/2/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/27/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/27/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/1/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

The recoveries for 10 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/2/2002

Environmental Laboratories

emailed

Original 4/2/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle C1526,Q2860,2862,P1664,1293

Collected By: GERTSIK

Comment:

Sample 05814

Sample 25050

ID of Source:

Collection 2/21/2002 AT 8:28:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04333

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.4	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	5.2	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	24.2	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	42	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/26/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle C1526,Q2860,2862,P1664,1293

Collected By: GERTSIK

Comment:

Sample 05814

Sample 25050

ID of Source:

Collection 2/21/2002 AT 8:28:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04333

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/27/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/27/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/1/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

The recoveries for 10 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle C1534,Q2845,2846,P1106,77

Collected By: BOLTON

Comment:

Sample 05824

Sample 35750

ID of Source:

Collection 2/21/2002 AT 10:23:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04334

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	0.12	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.0	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	4.0	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	23.1	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
ICP-MS, all analytes recovered!						
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	40	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/26/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received LK

Bottle C1534,Q2845,2846,P1106,77

Collected By: BOLTON

Comment:

Sample 05824

Sample 35750

ID of Source:

Collection 2/21/2002 AT 10:23:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04334

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/27/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/27/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/1/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

The recoveries for 10 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle C1549,Q2858,2865,P1551,1543

Collected By: AHMAD

Comment:

Sample 05834

Sample 46850

ID of Source:

Collection 2/21/2002 AT 9:23:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04335

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	0.10	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	13.7	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	5.6	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	21.1	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	46	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/26/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received LK
Bottle C1549,Q2858,2865,P1551,1543
Collected By: AHMAD
Comment:

Sample 05834

Sample 46850
ID of Source:
Collection 2/21/2002 AT 9:23:00
Submitted 2/22/2002 AT 10:32:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AE04335

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/27/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/27/2002	PAD

Organics

GCMS Scan For Unknowns						
	Other unknown compounds	.	ug/L		4/1/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.
 The recoveries for 10 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received LK

Bottle C1548,Q2835,2837,P1473,1322

Collected By: PATEL

Comment:

Sample 05838

Sample 58250

ID of Source:

Collection 2/21/2002 AT 11:23:00

Submitted 2/22/2002 AT 10:32:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : YES

Report

Sample No. AE04336

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	13.9	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	6.1	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	15.0	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	36	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	2/26/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received LK
Bottle C1548,Q2835,2837,P1473,1322
Collected By: PATEL
Comment:

Sample 05838

Sample 58250
ID of Source:
Collection 2/21/2002 AT 11:23:00
Submitted 2/22/2002 AT 10:32:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE04336

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			2/27/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/27/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	3/25/2002	DLV
-------------------------	---	------	-----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 8 of the compounds in the LCS Standard are high while 1 was low. New control limits will be calculated.

Approved Pam Dilsizian QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received LK
Bottle q1083, p1625
Collected By: LAB
Comment:

Sample FBD

Sample FBD
ID of Source:
Collection 2/22/2002 AT 12:00:00
Submitted 2/22/2002 AT 10:36:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
 Sample chilled on arrival? : YES

Report

Sample No. AE04337

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		4/2/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 12 of the 43 compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian QA Officer

Date Approved: 4/4/2002

Environmental Laboratories

emailed Original 4/4/2002

NYS ELAP # 10108

Page 1 of 1