

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received EP

Bottle c990,p1941,1853,q2936,2927

Collected By: BROWN

Comment:

Sample 3

Sample 3

ID of Source:

Collection 2/27/2002 AT 10:30:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04730

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	0.12	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	13.8	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	21.1	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	46	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	3/1/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received EP

Bottle c990,p1941,1853,q2936,2927

Collected By: BROWN

Comment:

Sample 3

Sample 3

ID of Source:

Collection 2/27/2002 AT 10:30:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04730

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			3/1/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/28/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/2/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 5 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received EP
Bottle c972,p1407,1563,q2924,2949,29
Collected By: BROWN
Comment:

Sample 58

Sample 58
ID of Source:
Collection 2/27/2002 AT 9:59:00
Submitted 2/27/2002 AT 11:21:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : yes

Report

Sample No. AE04731

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	13.7	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	20.8	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	41	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	3/1/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received EP

Bottle c972,p1407,1563,q2924,2949,29

Collected By: BROWN

Comment:

Sample 58

Sample 58

ID of Source:

Collection 2/27/2002 AT 9:59:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04731

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			3/1/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/28/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/2/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 5 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received EP
Bottle c1462,p2821,q2662,2661
Collected By: VASSILEV
Comment:

Sample 06336

Sample 10850
ID of Source:
Collection 2/26/2002 AT 11:58:00
Submitted 2/27/2002 AT 11:21:00
Sample Type: POT_DW
PWS No.: **Source Code:**

Type Descriptor:
Sample chilled on arrival? : yes

Report

Sample No. AE04732

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.1	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	4.6	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	24.3	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	46	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	3/1/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received EP

Bottle c1462,p2821,q2662,2661

Collected By: VASSILEV

Comment:

Sample 06336

Sample 10850

ID of Source:

Collection 2/26/2002 AT 11:58:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04732

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			3/1/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/28/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	4/2/2002	DLV
-------------------------	---	------	----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 5 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received EP

Bottle c394,p2047,1309,q2907,2906,c7

Collected By: SPERANZA

Comment: c394 received at lab with leak - sampled transferred to c790.

Sample 06348

Sample 23750

ID of Source:

Collection 2/26/2002 AT 10:56:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04733

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.6	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	20.9	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	25.8	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	3.4	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	5.0	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	48	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	3/1/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received EP

Bottle c394,p2047,1309,q2907,2906,c7

Collected By: SPERANZA

Comment: c394 received at lab with leak - sampled transferred to c790.

Sample 06348

Sample 23750

ID of Source:

Collection 2/26/2002 AT 10:56:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04733

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			3/1/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/28/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	4/4/2002	DLV
-------------------------	---	------	----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 12 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received EP

Bottle c314,p1279,q2919,2908

Collected By: GERTSIK

Comment: BOTTLE P 1170 BROKEN IN TRANSIT

Sample 06352

Sample 32050

ID of Source:

Collection 2/26/2002 AT 11:26:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04734

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.0	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	1.4	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	26.0	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	3.9	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	22.8	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/5/2002	PAD
EPA94	Iron	42	ug/L	20.0	4/5/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	3/1/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received EP

Bottle c314,p1279,q2919,2908

Collected By: GERTSIK

Comment: BOTTLE P 1170 BROKEN IN TRANSIT

Sample 06352

Sample 32050

ID of Source:

Collection 2/26/2002 AT 11:26:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04734

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/5/2002	PAD
EPA'79	Potable Metals Digestion	Completed			3/1/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/28/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/4/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 12 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/5/2002

Environmental Laboratories

emailed

Original 4/5/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received EP

Bottle c9726,p2733,2728,q2899,2911

Collected By: BOLTON

Comment:

Sample 06361

Sample 42850

ID of Source:

Collection 2/26/2002 AT 11:24:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04735

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	13.0	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	6.4	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	20.9	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/8/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/8/2002	PAD
EPA94	Iron	44	ug/L	20.0	4/8/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	3/1/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/8/2002

Environmental Laboratories

emailed

Original 4/8/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received EP

Bottle c9726,p2733,2728,q2899,2911

Collected By: BOLTON

Comment:

Sample 06361

Sample 42850

ID of Source:

Collection 2/26/2002 AT 11:24:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04735

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/8/2002	PAD
EPA'79	Potable Metals Digestion	Completed			3/1/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/28/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/4/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 12 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/8/2002

Environmental Laboratories

emailed

Original 4/8/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received EP

Bottle c1444,p2822,2827,q2660,2662

Collected By: SACKETT

Comment:

Sample 06370

Sample 58150

ID of Source:

Collection 2/26/2002 AT 11:15:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04736

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	3/14/2002	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Barium	14.0	ug/L	0.1	3/14/2002	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Chromium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Copper	6.8	ug/L	1.0	3/14/2002	PAD
EPA94	Lead	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Manganese	20.2	ug/L	1.0	3/14/2002	PAD
EPA94	Nickel	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Selenium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Silver	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94	Thallium	< MDL	ug/L	1.0	3/14/2002	PAD
EPA94	Zinc	< MDL	ug/L	2.0	3/14/2002	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	4/8/2002	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	4/8/2002	PAD
EPA94	Iron	38	ug/L	20.0	4/8/2002	PAD
EPA79	Mercury	< MDL	ug/L	0.40	3/1/2002	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 4/8/2002

Environmental Laboratories

emailed

Original 4/8/2002

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received EP

Bottle c1444,p2822,2827,q2660,2662

Collected By: SACKETT

Comment:

Sample 06370

Sample 58150

ID of Source:

Collection 2/26/2002 AT 11:15:00

Submitted 2/27/2002 AT 11:21:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample chilled on arrival? : yes

Report

Sample No. AE04736

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	4/8/2002	PAD
EPA'79	Potable Metals Digestion	Completed			3/1/2002	PAD
SM18	Tin	< MDL	ug/L	100	2/28/2002	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

4/4/2002

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 12 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/8/2002

Environmental Laboratories

emailed

Original 4/8/2002

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
 Received EP
 Bottle p1563,q2928
 Collected By: LAB
 Comment:

Sample FBD

Sample FBD

ID of Source:
 Collection 2/27/2002 AT 12:00:00
 Submitted 2/27/2002 AT 11:21:00
 Sample Type: DI WATER
 PWS No.:

Source Code:

Type Descriptor:
 Sample chilled on arrival? : yes

Report

Sample No. AE04737

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		4/4/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for 12 of the 43 compounds in the LCS Standard were high.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/4/2002

Environmental Laboratories

emailed

Original 4/4/2002

NYS ELAP # 10108

Page 1 of 1