

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received MC

Bottle C9322,Q3016,3015,P1454,1470

Collected By: RIBANDO

Comment:

Sample 3

Sample 3

ID of Source:

Collection 03/03/02 AT 9:31:00

Submitted 03/03/02 AT 10:12:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Report

Sample No. AE05062

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEWQ</u>						
EPA94	Antimony	< MDL	ug/L	0.1	04/04/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	04/04/02	PAD
EPA94	Barium	13.8	ug/L	0.1	04/04/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	04/04/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Copper	1.4	ug/L	1.0	04/04/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Manganese	19.9	ug/L	1.0	04/04/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	04/04/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	04/04/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/09/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/09/02	PAD
EPA94	Iron	37	ug/L	20.0	04/09/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/05/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/09/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received MC

Bottle C9322,Q3016,3015,P1454,1470

Collected By: RIBANDO

Comment:

Sample 3

Sample 3

ID of Source:

Collection 03/03/02 AT 9:31:00

Submitted 03/03/02 AT 10:12:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Report

Sample No. AE05062

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/09/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/13/02	PAD
SM18	Tin	< MDL	ug/L	100	03/07/02	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

04/09/02

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/09/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received MC

Bottle C0436,Q3004,3017,P1456,1455

Collected By: RIBANDO

Comment: ICP-MS, ALL ANALYTES
RECOVERED!

Sample 58

Sample 58

ID of Source:

Collection 03/03/02 AT 8:55:00

Submitted 03/03/02 AT 10:12:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Report

Sample No. AE05063

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWQC						
EPA94	Antimony	< MDL	ug/L	0.1	04/04/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	04/04/02	PAD
EPA94	Barium	13.6	ug/L	0.1	04/04/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	04/04/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Copper	1.0	ug/L	1.0	04/04/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Manganese	18.8	ug/L	1.0	04/04/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	04/04/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	04/04/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	04/04/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/09/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/09/02	PAD
EPA94	Iron	37	ug/L	20.0	04/09/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/05/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/09/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
Distribution Laboratory
96-05 Horace Harding Ex.
Corona N.Y. 11368
Dr. Ian Hurley

Received MC

Bottle C0436,Q3004,3017,P1456,1455

Collected By: RIBANDO

Comment: ICP-MS, ALL ANALYTES
RECOVERED!

Sample 58

Sample 58

ID of Source:

Collection 03/03/02 AT 8:55:00

Submitted 03/03/02 AT 10:12:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Report

Sample No. AE05063

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/09/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/13/02	PAD
SM18	Tin	< MDL	ug/L	100	03/07/02	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

04/09/02

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/09/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received MC
Bottle Q2931, P1564
Collected By: LAB
Comment:

Sample FBD

Sample FBD
ID of Source:
Collection 03/03/02 AT 12:00:00
Submitted 03/03/02 AT 10:12:00
Sample Type: POT_DW
PWS No.:
Source Code:
Type Descriptor:

Report

Sample No. AE05064

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		04/09/02	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/09/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 1