

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received EP

Bottle c390,p2301,2526,q2923,2926,k6

Collected By: WAGNER

Comment:

Report

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Sample CATLEFF

ID of Source:

Collection 03/02/02 AT 8:10:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample No. AE05231

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEW						
EPA94	Antimony	< MDL	ug/L	0.1	03/25/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Barium	14.1	ug/L	0.1	03/25/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Cadmium	< MDL	ug/L	0.2	03/25/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Copper	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Manganese	30.5	ug/L	1.0	03/25/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	03/25/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/09/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/09/02	PAD
EPA94	Iron	34	ug/L	20.0	04/09/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/08/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received EP

Bottle c390,p2301,2526,q2923,2926,k6

Collected By: WAGNER

Comment:

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Sample CATLEFF

ID of Source:

Collection 03/02/02 AT 8:10:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05231

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/09/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/13/02	PAD
SM18	Tin	< MDL	ug/L	100	03/07/02	PAD

Organics

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	03/10/02	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	03/10/02	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,1-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received EP

Bottle c390,p2301,2526,q2923,2926,k6

Collected By: WAGNER

Comment:

Sample CATLEFF

ID of Source:

Collection 03/02/02 AT 8:10:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05231

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	03/10/02	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Benzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromomethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c390,p2301,2526,q2923,2926,k6

Collected By: WAGNER

Comment:

Sample CATLEFF

ID of Source:

Collection 03/02/02 AT 8:10:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05231

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Naphthalene	< MDL	ug/L	0.5	03/10/02	SV
524.2	O-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Styrene	< MDL	ug/L	0.5	03/10/02	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Toluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received EP

Bottle c390,p2301,2526,q2923,2926,k6

Collected By: WAGNER

Comment:

Sample CATLEFF

ID of Source:

Collection 03/02/02 AT 8:10:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05231

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	03/10/02	SV
The recovery of chloroethane in the QC sample was 148%.						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		04/09/02	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 5 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received EP

Bottle c975,p2510,2505,q2939,2948,k6

Collected By: WAGNER

Comment:

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Sample DEL18

ID of Source:

Collection 03/02/02 AT 8:30:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05232

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWE New						
EPA94	Antimony	< MDL	ug/L	0.1	03/25/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Barium	14.6	ug/L	0.1	03/25/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Cadmium	< MDL	ug/L	0.2	03/25/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Copper	1.2	ug/L	1.0	03/25/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Manganese	19.1	ug/L	1.0	03/25/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	03/25/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/10/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/10/02	PAD
EPA94	Iron	30	ug/L	20.0	04/10/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/08/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received EP

Bottle c975,p2510,2505,q2939,2948,k6

Collected By: WAGNER

Comment:

Sample DEL18

ID of Source:

Collection 03/02/02 AT 8:30:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05232

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/10/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/13/02	PAD
SM18	Tin	< MDL	ug/L	100	03/07/02	PAD

Organics

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	03/10/02	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	03/10/02	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c975,p2510,2505,q2939,2948,k6

Collected By: WAGNER

Comment:

Sample DEL18

ID of Source:

Collection 03/02/02 AT 8:30:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05232

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	03/10/02	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Benzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromomethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c975,p2510,2505,q2939,2948,k6

Collected By: WAGNER

Comment:

Sample DEL18

ID of Source:

Collection 03/02/02 AT 8:30:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05232

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Naphthalene	< MDL	ug/L	0.5	03/10/02	SV
524.2	O-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Styrene	< MDL	ug/L	0.5	03/10/02	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Toluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received EP

Sample DEL18
ID of Source:
Collection 03/02/02 AT 8:30:00
Submitted 03/04/02 AT 2:13:00

Bottle c975,p2510,2505,q2939,2948,k6
Collected By: WAGNER
Comment:

Sample Type: POT_DW
PWS No.:

Source Code: 000
Type Descriptor:

Report

Sample No. AE05232

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	03/10/02	SV
The recovery of chloroethane in the QC sample was 148%.						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		04/09/02	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 5 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1539,p1168,p2053,q1387,1313,

Collected By: WAGNER

Comment:

Sample CROGH

ID of Source:

Collection 03/02/02 AT 1:30:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05233

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWE New						
EPA94	Antimony	< MDL	ug/L	0.1	03/25/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Barium	31.6	ug/L	0.1	03/25/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Cadmium	< MDL	ug/L	0.2	03/25/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Copper	1.3	ug/L	1.0	03/25/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Manganese	67.0	ug/L	1.0	03/25/02	PAD
EPA94	Nickel	1.4	ug/L	1.0	03/25/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	03/25/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	03/25/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	03/25/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/10/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/10/02	PAD
EPA94	Iron	58	ug/L	20.0	04/10/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/08/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1539,p1168,p2053,q1387,1313,

Collected By: WAGNER

Comment:

Sample CROGH

ID of Source:

Collection 03/02/02 AT 1:30:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05233

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/10/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/13/02	PAD
SM18	Tin	< MDL	ug/L	100	03/07/02	PAD

Organics

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	03/10/02	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	03/10/02	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,1-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1539,p1168,p2053,q1387,1313,

Collected By: WAGNER

Comment:

Sample CROGH

ID of Source:

Collection 03/02/02 AT 1:30:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05233

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	03/10/02	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Benzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromomethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c1539,p1168,p2053,q1387,1313,

Collected By: WAGNER

Comment:

Sample CROGH

ID of Source:

Collection 03/02/02 AT 1:30:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05233

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Naphthalene	< MDL	ug/L	0.5	03/10/02	SV
524.2	O-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Styrene	< MDL	ug/L	0.5	03/10/02	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Toluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received EP

Sample CROGH
ID of Source:
Collection 03/02/02 AT 1:30:00

Bottle c1539,p1168,p2053,q1387,1313,

Submitted 03/04/02 AT 2:13:00

Collected By: WAGNER

Sample Type: POT_DW

Comment:

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05233

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	03/10/02	SV

The recovery of chloroethane in the QC sample was 148%.

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	04/09/02	DLV
-------------------------	---	------	----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 5 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample FBW

Attention: Steve Schindler
Received EP
Bottle p654,q147
Collected By: LAB
Comment:

Sample FBW
ID of Source:
Collection 03/02/02 AT 12:00:00
Submitted 03/04/02 AT 2:13:00
Sample Type: DI WATER
PWS No.:
Source Code: 000
Type Descriptor:

Report

Sample No. AE05234

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
GCMS Scan For Unknowns						
	Other unknown compounds	.	ug/L		04/09/02	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.
This sample is the Field Blank which appears to contain a little more contamination than usually present in a Field

Approved Pam Dilsizian **QA Officer**

Date Approved: 04/09/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 1