

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c353,p1467,1465,q3003,3005,k7

Collected By: SCOTT

Comment:

Sample CATLEFF

ID of Source:

Collection 03/03/02 AT 7:57:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05235

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWEL New						
EPA94	Antimony	< MDL	ug/L	0.1	04/01/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Barium	13.2	ug/L	0.1	04/01/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Cadmium	< MDL	ug/L	0.2	04/01/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Copper	1.0	ug/L	1.0	04/01/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Manganese	22.4	ug/L	1.0	04/01/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	04/01/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/09/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/09/02	PAD
EPA94	Iron	70	ug/L	20.0	04/09/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/08/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c353,p1467,1465,q3003,3005,k7

Collected By: SCOTT

Comment:

Sample CATLEFF

ID of Source:

Collection 03/03/02 AT 7:57:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05235

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/09/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/13/02	PAD
SM18	Tin	< MDL	ug/L	100	03/07/02	PAD

Organics

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	03/10/02	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	03/10/02	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,1-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c353,p1467,1465,q3003,3005,k7

Collected By: SCOTT

Comment:

Sample CATLEFF

ID of Source:

Collection 03/03/02 AT 7:57:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05235

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	03/10/02	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Benzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromomethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c353,p1467,1465,q3003,3005,k7

Collected By: SCOTT

Comment:

Sample CATLEFF

ID of Source:

Collection 03/03/02 AT 7:57:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05235

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Naphthalene	< MDL	ug/L	0.5	03/10/02	SV
524.2	O-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Styrene	< MDL	ug/L	0.5	03/10/02	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Toluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c353,p1467,1465,q3003,3005,k7

Collected By: SCOTT

Comment:

Sample CATLEFF

ID of Source:

Collection 03/03/02 AT 7:57:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05235

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	03/10/02	SV
The recovery of chloroethane in the QC sample was 148%.						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		04/09/02	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 5 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received EP
Bottle c9709,p2516,1794,q2978,2977,k
Collected By: SCOTT
Comment:

Sample DEL18
ID of Source:
Collection 03/03/02 AT 8:18:00
Submitted 03/04/02 AT 2:13:00
Sample Type: POT_DW
PWS No.:
Source Code: 000
Type Descriptor:

Report

Sample No. AE05236

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
<u>ICPMS Metals for NEW</u>						
EPA94	Antimony	< MDL	ug/L	0.1	04/01/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Barium	13.3	ug/L	0.1	04/01/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Cadmium	< MDL	ug/L	0.2	04/01/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Copper	1.5	ug/L	1.0	04/01/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Manganese	17.1	ug/L	1.0	04/01/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	04/01/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/10/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/10/02	PAD
EPA94	Iron	34	ug/L	20.0	04/10/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/08/02	PAD

Approved Pam Disizian

QA Officer

Date Approved: 04/11/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received EP

Bottle c9709,p2516,1794,q2978,2977,k

Collected By: SCOTT

Comment:

Report

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Sample DEL18

ID of Source:

Collection 03/03/02 AT 8:18:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample No. AE05236

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/10/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/13/02	PAD
SM18	Tin	< MDL	ug/L	100	03/07/02	PAD

Organics

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	03/10/02	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	03/10/02	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,1-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/11/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received EP

Bottle c9709,p2516,1794,q2978,2977,k

Collected By: SCOTT

Comment:

Report

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Sample DEL18

ID of Source:

Collection 03/03/02 AT 8:18:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample No. AE05236

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	03/10/02	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Benzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromomethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/11/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler
Received EP
Bottle c9709,p2516,1794,q2978,2977,k
Collected By: SCOTT
Comment:

Sample DEL18
ID of Source:
Collection 03/03/02 AT 8:18:00
Submitted 03/04/02 AT 2:13:00
Sample Type: POT_DW
PWS No.:
Source Code: 000
Type Descriptor:

Report

Sample No. AE05236

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Naphthalene	< MDL	ug/L	0.5	03/10/02	SV
524.2	O-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Styrene	< MDL	ug/L	0.5	03/10/02	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Toluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/11/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Attention: Steve Schindler

Received EP

Bottle c9709,p2516,1794,q2978,2977,k

Collected By: SCOTT

Comment:

Report

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Sample DEL18

ID of Source:

Collection 03/03/02 AT 8:18:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Sample No. AE05236

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	03/10/02	SV

The recovery of chloroethane in the QC sample was 148%.

GCMS Scan For Unknowns

Other unknown compounds	.	ug/L	04/09/02	DLV
-------------------------	---	------	----------	-----

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/11/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 5 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c9276,p2349,2329,q3009,3012,k

Collected By: SCOTT

Comment:

Sample CROGH

ID of Source:

Collection 03/03/02 AT 12:20:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05237

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWE New						
EPA94	Antimony	< MDL	ug/L	0.1	04/01/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Barium	27.9	ug/L	0.1	04/01/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Cadmium	< MDL	ug/L	0.2	04/01/02	PAD
EPA94	Chromium	1.4	ug/L	1.0	04/01/02	PAD
EPA94	Copper	2.9	ug/L	1.0	04/01/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Manganese	58.3	ug/L	1.0	04/01/02	PAD
EPA94	Nickel	1.3	ug/L	1.0	04/01/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	04/01/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	04/01/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	04/01/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/10/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/10/02	PAD
EPA94	Iron	54	ug/L	20.0	04/10/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/08/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 1 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c9276,p2349,2329,q3009,3012,k

Collected By: SCOTT

Comment:

Sample CROGH

ID of Source:

Collection 03/03/02 AT 12:20:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05237

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/10/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/13/02	PAD
SM18	Tin	< MDL	ug/L	100	03/07/02	PAD

Organics

Volatile Organic Compounds

524.2	*THM-Bromodichloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Bromoform	< MDL	ug/L	2.0	03/10/02	SV
524.2	*THM-Chloroform	< MDL	ug/L	0.5	03/10/02	SV
524.2	*THM-Dibromochloromethane	< MDL	ug/L	2.0	03/10/02	SV
524.2	1,1,1,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,1- trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2,2-tetrachloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1,2-trichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-Dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,1-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,3-trichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2,4-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 2 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c9276,p2349,2329,q3009,3012,k

Collected By: SCOTT

Comment:

Sample CROGH

ID of Source:

Collection 03/03/02 AT 12:20:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05237

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	1,2-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3,5-trimethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,3-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	1,4-dichlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	2,2-dichloropropane	< MDL	ug/L	0.5	03/10/02	SV
524.2	2-butanone (MEK)	< MDL	ug/L	2.0	03/10/02	SV
524.2	2-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	4-chlorotoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Benzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromochloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Bromomethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Carbon tetrachloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chlorobenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloroethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Chloromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	cis-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Dibromomethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 3 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
465 Columbus Ave.
Valhalla, NY 10595

Sample NYC DEP
19 WEST LAKE DRIVE
VALHALLA, N.Y.

Attention: Steve Schindler

Received EP

Bottle c9276,p2349,2329,q3009,3012,k

Collected By: SCOTT

Comment:

Sample CROGH

ID of Source:

Collection 03/03/02 AT 12:20:00

Submitted 03/04/02 AT 2:13:00

Sample Type: POT_DW

PWS No.:

Source Code: 000

Type Descriptor:

Report

Sample No. AE05237

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Dichlorodifluoromethane	< MDL	ug/L	0.5	03/10/02	SV
524.2	Ethylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Hexachlorobutadiene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Isopropylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Methyl iso-butyl ketone (MIBK)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methyl tert-butyl ether (MTBE)	< MDL	ug/L	1.0	03/10/02	SV
524.2	Methylene Chloride	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	N-propylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Naphthalene	< MDL	ug/L	0.5	03/10/02	SV
524.2	O-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P & M-xylene	< MDL	ug/L	0.5	03/10/02	SV
524.2	P-isopropyltoluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	SEC-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Styrene	< MDL	ug/L	0.5	03/10/02	SV
524.2	TERT-butylbenzene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Tetrachloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Toluene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,2-dichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	trans-1,3-dichloropropene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichloroethene	< MDL	ug/L	0.5	03/10/02	SV
524.2	Trichlorofluoromethane	< MDL	ug/L	0.5	03/10/02	SV

Approved Pam Dilsizian

QA Officer

Date Approved: 04/10/02

Environmental Laboratories

emailed

Copy 04/10/02

NYS ELAP # 10108

Page 4 of 5

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water Supply
 465 Columbus Ave.
 Valhalla, NY 10595

 Attention: Steve Schindler
Received EP
Bottle c9276,p2349,2329,q3009,3012,k
Collected By: SCOTT
Comment:

Report

Sample NYC DEP
 19 WEST LAKE DRIVE
 VALHALLA, N.Y.

Sample CROGH
ID of Source:
Collection 03/03/02 AT 12:20:00
Submitted 03/04/02 AT 2:13:00
Sample Type: POT_DW
PWS No.:
Source Code: 000
Type Descriptor:

Sample No. AE05237

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
524.2	Vinyl chloride	< MDL	ug/L	0.5	03/10/02	SV
The recovery of chloroethane in the QC sample was 148%.						
<u>GCMS Scan For Unknowns</u>						
	Other unknown compounds	.	ug/L		04/09/02	DLV
The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.						

Approved Pam Dilsizian QA Officer

Date Approved: 04/10/02

Environmental Laboratories emailed Copy 04/10/02

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: NYCDEP Bureau Water
465 Columbus Ave.
Valhalla, NY 10595

Sample FBW

Attention: Steve Schindler
Received EP
Bottle p2379,q2251
Collected By: LAB
Comment:

Sample FBW
ID of Source:
Collection 3/3/2002 AT 12:00:00
Submitted 3/4/2002 AT 2:13:00
Sample Type: DI WATER
PWS No.: **Source Code:** 000

Type Descriptor:
Sample chilled on arrival? : yes

Report

Sample No. AE05238

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
GCMS Scan For Unknowns						
	Other unknown compounds	.	ug/L		3/29/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. The recoveries for the compounds in the LCS Standard were high. New limits will be calculated.

Approved Pam Dilsizian **QA Officer**

Environmental Laboratories

NYS ELAP # 10108

Date Approved: 4/1/2002

emailed Original 4/1/2002

Page 1 of 1