

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received MC

Bottle C9873,P419,2353,Q299,3116

Collected By: YACoub

Comment:

Sample 3

Sample 3

ID of Source:

Collection 03/10/02 AT 9:03:00

Submitted 03/10/02 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Report

Sample No. AE05917

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWQ						
EPA94	Antimony	< MDL	ug/L	0.1	04/05/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	04/05/02	PAD
EPA94	Barium	13.4	ug/L	0.1	04/05/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	04/05/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Copper	1.1	ug/L	1.0	04/05/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Manganese	18.9	ug/L	1.0	04/05/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	04/05/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	04/05/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/12/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/12/02	PAD
EPA94	Iron	36	ug/L	20.0	04/12/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/13/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/12/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received MC

Bottle C9873,P419,2353,Q299,3116

Collected By: YACoub

Comment:

Report

Sample 3

Sample 3

ID of Source:

Collection 03/10/02 AT 9:03:00

Submitted 03/10/02 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample No. AE05917

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/12/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/18/02	PAD
SM18	Tin	< MDL	ug/L	100	03/18/02	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

04/05/02

DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/12/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received MC
Bottle C7929,P3285,3276,Q3143,3113
Collected By: YACoub
Comment:

Sample 58

Sample 58
ID of Source:
Collection 03/10/02 AT 8:24:00
Submitted 03/10/02 AT 9:40:00
Sample Type: POT_DW
PWS No.:
Source Code:
Type Descriptor:

Report

Sample No. AE05918

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Inorganics						
ICPMS Metals for NEWQ						
EPA94	Antimony	< MDL	ug/L	0.1	04/05/02	PAD
EPA94	Arsenic	< MDL	ug/L	2.0	04/05/02	PAD
EPA94	Barium	13.4	ug/L	0.1	04/05/02	PAD
EPA94	Beryllium	< MDL	ug/L	2.0	04/05/02	PAD
EPA94	Chromium	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Copper	1.0	ug/L	1.0	04/05/02	PAD
EPA94	Lead	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Manganese	18.0	ug/L	1.0	04/05/02	PAD
EPA94	Nickel	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Selenium	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Silver	< MDL	ug/L	2.0	04/05/02	PAD
EPA94	Thallium	< MDL	ug/L	1.0	04/05/02	PAD
EPA94	Zinc	< MDL	ug/L	2.0	04/05/02	PAD
EPA94200.	Aluminum	< MDL	ug/L	50.0	04/12/02	PAD
EPA94	Cobalt	< MDL	ug/L	20.0	04/12/02	PAD
EPA94	Iron	35	ug/L	20.0	04/12/02	PAD
EPA79	Mercury	< MDL	ug/L	0.40	03/13/02	PAD

Approved Pam Dilsizian

QA Officer

Date Approved: 04/12/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 1 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC

Distribution Laboratory

96-05 Horace Harding Ex.

Corona N.Y. 11368

Dr. Ian Hurley

Received MC

Bottle C7929,P3285,3276,Q3143,3113

Collected By: YACoub

Comment:

Report

Sample 58

Sample 58

ID of Source:

Collection 03/10/02 AT 8:24:00

Submitted 03/10/02 AT 9:40:00

Sample Type: POT_DW

PWS No.:

Source Code:

Type Descriptor:

Sample No. AE05918

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
EPA94	Molybdenum	< MDL	ug/L	50.0	04/12/02	PAD
EPA'79	Potable Metals Digestion	Completed			03/18/02	PAD
SM18	Tin	< MDL	ug/L	100	03/18/02	PAD

Organics

GCMS Scan For Unknowns

Other unknown compounds

ug/L

04/05/02

DLV

The GCMS scan, from 35 to 550 amu, reveals the tentative presence of Piperidine.

Approved Pam Dilsizian

QA Officer

Date Approved: 04/12/02

Environmental Laboratories

emailed

Copy 04/16/02

NYS ELAP # 10108

Page 2 of 2

REPORT OF ANALYSIS

Westchester County Department of Labs and Research 2 Dana Road Valhalla, New York

Agency: New York City DEP DWQC
 Distribution Laboratory
 96-05 Horace Harding Ex.
 Corona N.Y. 11368
 Dr. Ian Hurley
Received MC
Bottle P3302,Q3143
Collected By: LAB
Comment:

Sample FBD

Sample FBD

ID of Source:
Collection 3/10/2002 AT 12:00:00
Submitted 3/10/2002 AT 9:40:00
Sample Type: POT_DW
PWS No.:

Source Code:

Type Descriptor:
Sample chilled on arrival? : YES

Report

Sample No. AE05919

Method	Test Description	Results	Units	MDL	Analyzed on	Validator
Organics						
GCMS Scan For Unknowns						
	Other unknown compounds	.	ug/L		4/5/2002	DLV

The GCMS scan, from 35 to 550 amu, does not reveal the presence of unusual compounds. Isophorone is present at an estimated level of 0.26 ug/L.

Approved Pam Dilsizian

QA Officer

Date Approved: 4/8/2002

Environmental Laboratories

emailed

Original 4/8/2002

NYS ELAP # 10108

Page 1 of 1