

Theodorellys, Penny

From: Lutchmedial, Carlstien
Sent: Monday, April 07, 2003 8:12 AM
To: Radhakrishnan, Krish
Cc: Theodorellys, Penny; Plumptre, Alphonso; Atteloney, Leonard
Subject: 66 John Street Sampling

On Saturday April 5, 2003 DEP conducted TEM air monitoring at 66 John St. Sampling was done on the 10th Floor first then we proceeded to the 9th floor. A total of 13 samples were collected throughout the 10th floor. Then a total of 9 samples were taken from the 9th floor. Please note that on the 9th floor only the northern half of the floor was sampled. The part utilized by the NYC Human Resources Department was excluded (this was not part of the scope of sampling). Later that day the samples were sent to the lab. Yesterday, I was informed by Leonard Atteloney that all samples were negative for asbestos.

During the course of sampling, Plumptre and myself conducted visual inspections of the floor again and did not observe any suspect WTC debris.

I have attached a PDF file of the 9th & 10th floors with the sampling locations for your records.



66 john St.pdf