

10/23/2002 15:21 FAX

018

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 764-7490

Fax. (718) 764-4085

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-10-148

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP, 55 John Street

DATE OF REPORT: 10/22/02

DATE OF ANALYSIS: 10/22/02

EFFECTIVE FILTER AREA (mm²): 385**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY****LABORATORY RESULTS**

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (struct./cm ³)	TOTAL ASBESTOS AIR CONC. (ttac./cu ³)	TOTAL ASBESTOS FILTER CONC. (air./mm ³)	AIR CONC. FOR STRICT. 0.5 <= 5um	AIR CONC. FOR STRICT. 8 >= 5.0um	ASBEST. TYPE CHRYS.	AMPLIM. ASBEST. TYPE SPECIFY
01	T02-10-148-3442	North area 2 nd floor	1300	5	0.0692	0.0043	<0.0043	<14.45	NA	NA	NA	NA
02	T02-10-148-3443	South area 2 nd floor	1300	5	0.0692	0.0043	<0.0043	<14.45	NA	NA	NA	NA
03	T02-10-148-3444	East area 2 nd floor	1300	5	0.0692	0.0043	<0.0043	<14.45	NA	NA	NA	NA
04	T02-10-148-3445	West area 2 nd floor	1300	5	0.0692	0.0043	0.0043	14.45	<0.0043	0.0043	Chrys.	NA
05	T02-10-148-3446	Middle area 2 nd floor	1300	5	0.0692	0.0043	<0.0043	<14.45	NA	NA	NA	NA

E. Sioukri

ANALYST
E. Sioukri

LABORATORY DIRECTOR
Spiru Dongaris**LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955**

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- This report relates only to items tested. This report must not be used to obtain product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

