



ASBESTOS ANALYTICAL REPORT

ASBESTOS CONTROL PROGRAM LABORATORY
96-05 HORACE HARDING EXPRESSWAY
CORONA, NEW YORK 11368
(718) 595-6309 FAX# (718) 595-6307

ELAP # 11045

TEST METHODS: 1) 40 CFR Part 763, Subpart F, App. A
2) Polarized Light Microscopy plus Stratified Point-Counting Method
3) EPA/600/R-93/116

Incident #: WTC071302
 Inspector : C. LUTCHMEDIAL
 Premise : 15 JOHN STREET
 Boro : Manhattan
 Analyst : A. SOLOKI

Date Collected: 07/13/02
 Received: 07/13/02
 Analyzed: 07/13/02

Client #:

DEP Sample #:	20713/A058021	20713/A058022	20713/A058023
Laboratory #:	20713/658	20713/659	20713/660
Location Sampled:	WEST FACADE LEDGE	WEST FACADE LEDGE	WEST FACADE LEDGE
Color:	GREY	GREY	GREY
Homogenous:	Yes	Yes	Yes
Asbestos Present:	Yes	Yes	Yes

Results (%)

Chrysotile	1	Chrysotile	<1	Chrysotile	TRACE
Cellulose	3	Cellulose	2	Cellulose	1
Fibrous glass	30	Fibrous glass	30	Fibrous glass	40
Matrix	66	Matrix	68	Matrix	59

Comments:

Reviewed by: *A. Delaney*
 Laboratory Director

This test report may not be reproduced except with the written approval of this laboratory. The test report relates only to the item(s) listed and does not represent a product endorsement by NVLAP or any other U.S. Government agency.