



ASBESTOS ANALYTICAL REPORT

ASBESTOS CONTROL PROGRAM LABORATORY
96-05 HORACE HARDING EXPRESSWAY
CORONA, NEW YORK 11368
(718) 595-6309 FAX# (718) 595-6307

ELAP # 11045

TEST METHODS: 1) 40 CFR Part 763, Subpart F, App. A
2) Polarized Light Microscopy plus Stratified Point-Counting Method
3) EPA/600/R-93/116

Incident #: WTC071302
 Inspector : C. LUTCHMEDIAL
 Premise : 15 JOHN STREET
 Boro : Manhattan
 Analyst : E. BRUTUS

Date Collected: 07/13/02
 Received: 07/13/02
 Analyzed: 07/13/02

Client #:

DEP Sample #: 20713/A058020

Laboratory #: 20713/657

Location Sampled: FACADE LEDGE

Color: GREY

Homogenous: Yes
 Asbestos Present: Yes

Results (%)

Chrysotile	1.0
Amosite	TRACE
Cellulose	10
Fibrous glass	25
Matrix	64

Comments:

Reviewed by: *A. Adelman*
 Laboratory Director

This test report may not be reproduced except with the written approval of this laboratory. The test report relates only to the item(s) listed and does not represent a product endorsement by NVLAP or any other U.S. Government agency.