

10/21/2002 08:45 FAX

005

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7490
Fax. (718) 784-4085**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**

CLIENT: Warren & Panzer Engineers, P.C.
 LABORATORY ID #: T02-10-107
 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.E.
 AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP, 20 John Street
 DATE OF REPORT: 10/18/02
 DATE OF ANALYSIS: 10/18/02
 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (L)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (micro/cm ²)	TOTAL ASBESTOS AIR CONC. (micro/cm ³)	TOTAL ASBESTOS FILTER CONC. (micro/cm ²)	AIR CONC. FOR STRUCT. 0.5-5-5µm	AIR CONC. FOR STRUCT. >5.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-10-107-3221	Exit to the roof	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
02	T02-10-107-3222	IWA 1 st left side of WA	1800	4	0.0554	0.0039	0.0039	18.07	0.0039	<0.0039	Chrys.	NA
03	T02-10-107-3223	IWA 2 nd left side of WA	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
04	T02-10-107-3224	IWA 3 rd left side of WA	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
05	T02-10-107-3225	IWA right side of WA	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA

ANALYST
E. Dmirakos

LABORATORY DIRECTOR
Spiro Dongaris

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED DATE 10/18/02 BY 1013 PCE

- Athenica Environmental Services Inc. (AES) is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.