



AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY


CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-10-039
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP, 24 John Street
DATE OF REPORT: 10/07/02
DATE OF ANALYSIS: 10/07/02
EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (struct./cm ²)	TOTAL ASBESTOS AIR CONC. (struct./cm ²)	TOTAL ASBESTOS FILTER CONC. (str./mm ²)	AIR CONC. FOR STRUCT. 0.558<5µm	AIR CONC. FOR STRUCT. 825.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-10-039-2875	Entrance to lower roof	1614	4	0.0554	0.0043	0.0129	54.20	<0.0043	0.0129	Chrys.	NA
02	T02-10-039-2876	Entrance to middle roof	1614	4	0.0554	0.0043	<0.0043	<18.07	NA	NA	NA	NA
03	T02-10-039-2877	Upper roof 1	1614	4	0.0554	0.0043	<0.0043	<18.07	NA	NA	NA	NA
04	T02-10-039-2878	Upper roof 2	1614	4	0.0554	0.0043	<0.0043	<18.07	NA	NA	NA	NA
05	T02-10-039-2879	Upper roof 3	1614	4	0.0554	0.0043	<0.0043	<18.07	NA	NA	NA	NA


ANALYST
E. Dimitrakas


LABORATORY DIRECTOR
Spiro Donaghy

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, KLAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its personnel.
- For sampling purposes only the system for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

10/08/2002 16:55 FAX

005