

10/10/2002 08:50 FAX

015/015

y&amp;10L

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7499

Fax. (718) 784-4085

CLIENT: Warren &amp; Paezzer Engineers, P.C.

LABORATORY ID #: T02-10-048

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm<sup>2</sup>): 0.013838

PROJECT: NYC DEP, 24 John Street

DATE OF REPORT: 10/08/02

DATE OF ANALYSIS: 10/08/02

EFFECTIVE FILTER AREA (mm<sup>2</sup>): 385**LABORATORY RESULTS**

| CLIENT # | LAB. ID #       | LOCATION                                                    | VOLUME (l) | G.O.'s ANALYZED | AREA ANALYZED (mm <sup>2</sup> ) | ANALYT. SENSITIVITY (dust/cm <sup>3</sup> ) | TOTAL ASBESTOS AIR CONC. (dust/cm <sup>3</sup> ) | TOTAL ASBESTOS FILTER CONC. (dust/cm <sup>3</sup> ) | AIR CONC. FOR STRUCT. 0.55<5µm | AIR CONC. FOR STRUCT. 825.0µm | ASBEST. TYPE CHRYS. | AMPHIB. ASBEST. TYPE SPECIFY |
|----------|-----------------|-------------------------------------------------------------|------------|-----------------|----------------------------------|---------------------------------------------|--------------------------------------------------|-----------------------------------------------------|--------------------------------|-------------------------------|---------------------|------------------------------|
| 011WA    | T02-10-048-2918 | On roof 4 <sup>th</sup> fl., center of work area            | 1350       | 5               | 0.0692                           | 0.0041                                      | <0.0041                                          | <14.45                                              | NA                             | NA                            | NA                  | NA                           |
| 021WA    | T02-10-048-2919 | On roof 4 <sup>th</sup> fl., west section of work area      | 1350       | 5               | 0.0692                           | 0.0041                                      | <0.0041                                          | <14.45                                              | NA                             | NA                            | NA                  | NA                           |
| 031WA    | T02-10-048-2920 | On roof 4 <sup>th</sup> fl., north section of work area     | 1350       | 5               | 0.0692                           | 0.0041                                      | <0.0041                                          | <14.45                                              | NA                             | NA                            | NA                  | NA                           |
| 041WA    | T02-10-048-2921 | On roof 4 <sup>th</sup> fl., east section of work area      | 1350       | 5               | 0.0692                           | 0.0041                                      | <0.0041                                          | <14.45                                              | NA                             | NA                            | NA                  | NA                           |
| 050WA    | T02-10-048-2922 | 4 <sup>th</sup> fl., on hall 6ft of doorway leading to roof | 1350       | 5               | 0.0692                           | 0.0041                                      | <0.0041                                          | <14.45                                              | NA                             | NA                            | NA                  | NA                           |

ANALYST  
P. Dimitrakas

LABORATORY DIRECTOR  
Quinn Treadwell**LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955**

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported asbestos concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.