

**ENVIROSCIENCE
CONSULTANTS, INC.**

2150 SMITHTOWN AVENUE
BRONX, NY 10460
PHONE: (631) 580-3191
FACSIMILE: (631) 580-3195
WWW.ENVIROHEALTH.ORG

ELAP # 11681
NVLAP # 200531-0

ITEM AIR SAMPLE RESULTS

CLIENT:	Tech Clean	SAMPLE DATE:	September 24, 2001
PROJECT NAME:	AMEX 22 Thaines	RECEIVED DATE:	September 25, 2001
AREA:	Third Floor	SAMPLER:	Ambient B. Gallagher
CLIENT #:	00-10233	CUSTODY #:	B-05-03

[illegible]

Analyzed by: Edward M. Schwab Date Analyzed: 9-25-07

Concentration on the filter is calculated by taking the number of asbestos structures and dividing by the area analyzed. Air concentration is calculated by multiplying the effective filter area (EFA) by the filter concentration and then dividing by the volume of air collected in cubic centimeters (cc).

the data pertaining to these calculations can be found on the Asbestos Court Sheet.

The air filler concentration relates only to air filler content. When samples are submitted by an outside agency for analysis, Enviroscience can only guarantee the accuracy of the filler concentration. This report may not be reproduced without the express permission of Enviroscience. This report can not be used to claim endorsement of products by NVLAP or any agency of the U.S. Government.

The samples collected in the response action area demonstrated a fiber concentration of asbestos less than seventy structures per square millimeter. This response action is considered complete according to EPA 40 CFR 763.

A result of zero structures per square millimeter is only applicable to the area analyzed. Test results only reflect conditions at the time samples were taken.