

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSL

Attn: Juan Salcedo
Emtequa Corporation
505 Eighth Avenue, Suite 900
New York, NY 10018
Fax: (212) 631-8086 Phone: 212-631-9000
Project: 01-0458 / 100 Wall St. NY, NY / Bsmr, Lobby 12th and
22nd

Customer ID: EMT51
Customer PO:
Received: 09/14/01 8:50 PM
EMSL Order: 030104247
EMSL Project ID:
Analysis Date: 9/14/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
01 030104247-0001	Inside Elev. Pit-Low Rise 1-2 Bsmr	9/14/2001	600.00	<5.5	100	0.004	<7.0	<0.004	
02 030104247-0002	South Part of Lobby Area	9/14/2001	600.00	<5.5	100	0.004	<7.0	<0.004	
03 030104247-0003	East side of 12th Fl by AC-1	9/14/2001	600.00	<5.5	100	0.004	<7.0	<0.004	
04 030104247-0004	North side of 12th Fl By AC-3	9/14/2001	600.00	<5.5	100	0.004	<7.0	<0.004	
05 030104247-0005	North side of 22nd Fl.	9/14/2001	600.00	<5.5	100	0.004	<7.0	<0.004	
06 030104247-0006	FIELD BLANK	9/14/2001	0.00	<5.5	100		<7.0		Field Blank
07 030104247-0007	FIELD BLANK	9/14/2001	0.00	<5.5	100		<7.0		Field Blank

Vicky Andrade

Analyst

 Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11608)

PC 1-1

1



EMTEQUE Corporation
505 Eighth Avenue, Suite 800
New York, New York 10018
Phone: (212) 631-9800
Fax: (212) 631-8066

ASBESTOS AIR SAMPLE LOG

SHIFT	
-------	--

Page (of)

Turn Around Time:
☒ - Immediate
☐ - 5 Hrs.
☐ - 24 Hrs
☐ - 3 Days

S	M	T	W	T	F	S
---	---	---	---	---	---	---

DATE: 9-14-01

WORK AREA: Basement Lobby: 12th and 22nd

PROJECT #: 01-0458 PROJECT SITE: 100 wall st. NY NY

TECHNICIAN: JUAN SALCEDO NYS CERT. #:

ROTOMETER #: _____ MANAGER: _____

MANAGER:

ANALYSIS: PCM **TEM-AHERA (NYC)**

☐ TEM-ABERA (NYC)

FOR LABORATORY USE ONLY

LABORATORY PROJECT #:

030104247

[illegible]

SAMPLE TYPE: ☐ BC-Backgroud ☐ P-Pretest ☐ D-During ☐ CLR-Clearance ☒ AS-Air Survey ☐ FB-Field Blank ☐ N/A-Not Analyzed ☐ OL-Overloaded

RELINQUISHED BY: _____ DATE: _____ TIME: _____ DISCHARGE NO. _____

RELINQUISHED BY: JUAN SALCEDO	DATE: 9-14-01	TIME:	RECEIVED BY: <i>[Signature]</i>	DATE: 9/14/01	TIME: 8:50 PM
RELINQUISHED BY:	DATE:	TIME:	RECEIVED BY:	DATE:	TIME: