
**SAFETY ENVIRONMENTAL
CO. OF N.Y. INC.**

(718) 390-0914
Fax (718) 390-0915

33 Clinton Avenue
Staten Island, NY 10301

CLIENT: NYC D.O.T.

SITE: BATTERY MARITIME BUILDING, NEW YORK, NY

RE: ASBESTOS AIR MONITORING AND TESTING 4TH FLOOR OFFICE SPACE

DATE SAMPLE COLLECTED: 10/15/01

DATE SAMPLE ANALYZED: 10/16/01

FILE NO.: 01-155

BATCH #: 10-022

SAMPLE TYPE: AIR QUALITY


CERTIFICATE OF ANALYSIS

Airborne asbestos analysis by NIOSH method no. 7400-phase contrast microscopy New York State ELAP # 11475, American Industrial Hygiene association # 17049. Microscope Type-PCM, Make-Olympus, Model CH-2


SAMPLE NUMBER	SAMPLE LOCATION	TOTAL TIME SAMPLED (MIN)	FLOW RATE (L/Min)	VOLUME (L)	RESULTS FIBERS/ CC
A1	BOGDAN OFFICE	80	10	800	0.006
A2	NANDI OFFICE	80	10	800	0.005
A3	IN FRONT OF COLLINS OFFIC	80	10	800	0.006
A4	RAMASH PATEL OFFICE	80	10	800	0.007
A5	BAIRD OFFICE	80	10	800	0.005
A6	VALLABH OFFICE	80	10	800	0.005
A7	GHESH OFFICE	80	10	800	0.006
A8	VERLEY OFFICE	80	10	800	0.005
A9	CAD ROOM	80	10	800	0.005
A10	BUTLER OFFICE	80	10	800	0.004
A11	RAJ PATEL OFFICE	80	10	800	0.005
A12	STILLMAN OFFICE	80	10	800	0.005

SAMPLE NUMBER	SAMPLE LOCATION	TOTAL TIME SAMPLED (MIN)	FLOW RATE (L/Min)	VOLUME (L)	RESULTS FIBERS/ CC
A13	LOUNGE	90	10	900	0.005
A14	ENGINEERING STORE ROOM	90	10	900	0.005
A15	MAN DIVISION LOUNGE RM	90	10	900	0.004
A16	BACK OF JOYCE'S OFFICE	90	10	900	0.007
A17	WILLIAMS OFFICE FRONT	90	10	900	0.005
A18	ROVETO OFFICE	90	10	900	0.004
A19	MAN DIVISION COPIER RM	90	10	900	0.007
A20	RUSSELL OFFICE	90	10	900	0.005
A21	S&A MAINTENANCE COPIER RM	90	10	900	0.005
A22	MS. BROWN'S OFFICE	90	10	900	0.004
A23	SIBENBA BROWN OFFICE	90	10	900	0.005
A24	SHAWN RAE	90	10	900	0.005
A25	BLANK				ND
A26	BLANK				ND

SAMPLE NUMBER	SAMPLE LOCATION	TOTAL TIME SAMPLED (MIN)	FLOW RATE (L/Min)	VOLUME (L)	RESULTS FIBERS/CC
A27	3 RD FL ELEVATOR BANK	90	10	900	0.004
A28	PRIV FERRY OPER OFFICE	90	10	900	0.007
A29	PRIV FERRY OPER CONF RM	90	10	900	0.005
A30	DEJESUS OFFICE	90	10	900	0.005
A31	GROTELL OFFICE	90	10	900	0.007
A32	CHUI FINANCE OFFICE	90	10	900	0.007
A33	TAYLOR OFFICE	90	10	900	0.005
A34	YUEZHUSON OFFICE	90	10	900	0.007
A35	MOTOLA OFFICE	90	10	900	0.005
A36	LOUIE OFFICE	90	10	900	0.007
A37	3 RD FL KITCHEN	90	10	900	0.005
A38	BUTLER OFFICE	90	10	900	0.005
A39	BLANK				ND
A40	BLANK				ND



Jane Kozlovskaya
Laboratory Analyst



Francis Owoh M.S., RPH
Laboratory Director