



New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

Attn: PSI - Professional Service Industries
9 East 37th Street 11th Floor
New York, NY 10016
Fax: (212) 889-0493 Phone: 212-889-0294
Project: 622 / 74 Trinity Place, NY,NY. / Various Floors / Trinity
Real State

Customer ID: PSII51
Customer PO:
Received: 12/07/01 9:59 PM
EMSL Order: 030109375
EMSL Project ID:

Analysis Date: 12/8/2001

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²) (S/cc)	Notes
A-12 030109375-0012	1260.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
A-13 030109375-0013	1260.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
A-14 030109375-0014	1260.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
A-15 030109375-0015	1260.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
A-16 030109375-0016	1260.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	

Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11508

TEMAHERA-1