

02/01/2002 15:28

212-290-2538

EMSL ANALYTICAL INC

PAGE 01

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSL

Attn: Jane Weber
 PSI - Professional Service Industries
 9 East 37th Street 11th Floor
 New York, NY 10016
 Fax: (212) 889-0493 Phone: 212-889-0294
 Project: 622-2E001 / TRINITY REAL ESTATE / 74 TRINITY PLACE
 / VARIOUS FLOORS / Revised report: 02/01/02

Customer ID: PSII51
 Customer PO:
 Received: 01/29/02 1 30 AM
 EMSL Order 030201221
 EMSL Project ID.
 Analysis Date: 1/31/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
TEM - 01 030201221-0001	1440.00	0.0625	0	None Detected		0.0043	<16.00 <0.0043	
TEM - 02 030201221-0002	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
TEM - 03 030201221-0003	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
TEM - 04 030201221-0004	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
TEM - 05 030201221-0005	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
TEM - 06 030201221-0006	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
TEM - 07 030201221-0007	1520.00	0.0625	0	None Detected		0.0041	<16.00 <0.0041	
TEM - 08 030201221-0008	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
TEM - 09 030201221-0009	1620.00	0.0500	0	None Detected		0.0048	<20.00 <0.0048	
TEM - 10 030201221-0010	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	

Louis Lombardi (10)

Eric B. B.
 Laboratory Manager
 or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-8, NY State ELAP #11508

TEMAHERA-1

1