NYC 9/11 Public Portal Document


# ENVIROSCIENCE CONSULTANTS, INC.

2150 SMITHTOWN AVENUE
RONKONKOMA, NY 11779
PHONE: (631) 580-3191 • FACSIMILE: (631) 580-3195
WWW.ENVIROHEALTH.ORG


## ASBESTOS BULK SAMPLE RESULTS

| | | | |
|---|---|---|---|
| CLIENT: | American Stock Exchange | CHAIN OF CUSTODY: | B-27-10 |
| PROJECT: | Pedestrian Protection Scaffold Debris Asbestos Testing | SAMPLER: | B. Gallagher |
| | | DATE: | February 19, 2002 |
| PAGE: | 1 of 1 | DATE ANALYZED: | February 21, 2002 |

| SAMPLE # | DESCRIPTION / LOCATION | RESULT |
|---|---|---|
| D1 | Debris, Gray Ash/Greenwich Street Scaffold - North | Trace Chrysotile |
| D2 | Debris, Gray Ash/Greenwich Street Scaffold | None Detected |
| D3 | Debris, Gray Ash/Greenwich Street Scaffold - Center | None Detected |
| D4 | Debris, Gray Ash/Greenwich Street Scaffold | Trace Chrysotile |
| D5 | Debris, Gray Ash/Greenwich Street Scaffold - South | None Detected |
| D6 | Debris, Gray Ash/Trinity Place Scaffold - North | None Detected |
| D7 | Debris, Gray Ash/Trinity Place Scaffold - Center | None Detected |
| D8 | Debris, Gray Ash/Trinity Place Scaffold - South | None Detected |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

Reviewed by: Edward A. Schwartz Analyzed by: [signature]

Asbestos Containing Materials contain more than 1% asbestos (shown in **bold** type).
Trace - Asbestos found is 1% or less; not considered ACM.
None Detected - No asbestos found in samples using polarized light microscopy (PLM).
None Detected by TEM - No asbestos found in samples using transmission electron microscopy (TEM).
Inconclusive - No asbestos found in non friable organically bound samples using polarized light microscopy (PLM).
ELAP # 11681