

Ambient Group, Inc.
10 Morris Avenue,
Glen Cove 11542
(516) 609-0009

ELAP 10865

**AIRBORNE ASBESTOS STRUCTURES RESULTS
(TRANSMISSION ELECTRON MICROSCOPY - TEM)**

**J. RESNICK & SONS
75 PARK PLACE
PROJECT ID: 211358
DATE COLLECTED: 9/19/01**

SAMPLE NUMBER	LAB SAMPLE ID	SAMPLE LOCATION	ASBESTOS STRUCTURES cm ³
211358-01 FIELD SHT 3151	AEM990 09424	LOBBY: SECURITY DESK LT ANYL SENS	<0.0049

LT ANAL SENS=LESS THAN ANALYTICAL SENSITIVITY
ANALYTICAL SENSITIVITY=0.0049