

TABLE I

**LIMITED CONDENSED DATA RANGES
AND ASSOCIATED INDUSTRY STANDARDS
(Airborne Dust Characterization)**

Parameter	Indoor Sample Ranges	Outdoor Sample Ranges	Standards/guidelines*
Fungal Spores (non-cultured)	301 to 489 spores/m ³	4,104 spores/m ³	Outdoor Not Applicable Indoor Suggested guideline 700 spores/m ³

220209 (zefons)

**AMBIENT GROUP, INC.**

10 Morris Avenue, Glen Cove, NY 11542
Phone: (516) 609-0009 - Fax: (516) 609-8271

Laboratory Report

AGL02151**Particulate Analysis On Air-O-Cell (Zefon) Cassette**

Client: Jack Resnick & Sons
Address: 75 Park Place
New York, NY
Collected By: Craig Kamback
Collected: 02/26/2002

Job Number: 220209
Date Received: 02/27/2002
Date Analyzed: 02/27/2002
Job Location: 75 Park Place, 10th Flr &
Facilities Office

Lab ID Field ID	Sample Location	Flow	Time	Volume	Constituents	Total Count	Concen. Ct/m3
0002151-001	Facilities Office/ Reception Area, Top of	15	10	0.02656	Total Fungal Spores	8	301
0002151-002	Facilities Office/Mike Martin's Office	15	10	0.02656	Total Fungal Spores	13	489
0002151-003	Lobby/Security Desk	15	10	0.02656	Total Fungal Spores	0	
0002151-004	Outside Air/Dark & Greenwich St.	15	10	0.02656	Total Fungal Spores	109	4,104

SIGNED FOR AMBIENT GROUP, INC. BY: