

Ambient Group, Inc.  
10 Morris Avenue,  
Glen Cove 11542  
(516) 609-0009

ELAP 10865

**AIRBORNE ASBESTOS STRUCTURES RESULTS  
(TRANSMISSION ELECTRON MICROSCOPY - TEM)**

**J. RESNICK & SONS  
75 PARK PLACE  
PROJECT ID: 211658  
DATE COLLECTED:**

| SAMPLE<br>NUMBER               | LAB<br>SAMPLE ID | SAMPLE LOCATION                                                                                         | ASBESTOS<br>STRUCTURES<br>cm <sup>3</sup> |
|--------------------------------|------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------|
| 211358-01<br>FIELD<br>SHT 6063 | AEM990<br>12397  | 12/27/01 – 11:03 AM<br>10 <sup>th</sup> Floor: IWA/Northside<br>Opposite Window<br>LT ANYL SENS         | <0.0045                                   |
| 211358-02<br>FIELD<br>SHT 6063 | AEM990<br>12398  | 12/27/01 – 11:04 AM<br>10 <sup>th</sup> Floor: IWA/Southside<br>Opposite Window<br>LT ANYL SENS         | <0.0045                                   |
| 211358-03<br>FIELD<br>SHT 6063 | AEM990<br>12399  | 12/27/01 – 11:06 AM<br>10 <sup>th</sup> Floor: IWA/Westside<br>Opposite Window<br>LT ANYL SENS          | <0.0045                                   |
| 211358-04<br>FIELD<br>SHT 6063 | AEM990<br>12400  | 12/27/01 – 11:08 AM<br>10 <sup>th</sup> Floor: IWA/Eastside<br>Opposite Window<br>LT ANYL SENS          | <0.0045                                   |
| 211358-05<br>FIELD<br>SHT 6063 | AEM990<br>12401  | 12/27/01 – 11:10 AM<br>10 <sup>th</sup> Floor: IWA/Middle Area<br>LT ANYL SENS                          | <0.0045                                   |
| 211358-06<br>FIELD<br>SHT 6058 | AEM990<br>12402  | 12/27/01 – 11:12 AM<br>10 <sup>th</sup> Floor: IWA/Southwest<br>Corner, Opposite Window<br>LT ANYL SENS | <0.0045                                   |
| 211358-07<br>FIELD<br>SHT 6058 | AEM990<br>12403  | 12/27/01 – 11:14 AM<br>10 <sup>th</sup> Floor: IWA/Northwest,<br>Opposite Window/Corner<br>LT ANYL SENS | <0.0045                                   |

LT ANAL SENS=LESS THAN ANALYTICAL SENSITIVITY  
ANALYTICAL SENSITIVITY=0.0049