

SciLab Job#: 202052099

Client Name: Applied Technology Services, Inc.

Table I
Summary of Bulk Asbestos Analysis Results
 E02411


SciLab Sample #	Client Sample# Location	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
01	26-051002-01 12th Floor / Dust + Debris N/W Corner / 24' E x 20' S Top Of Act.	001	0.83	9.52	20.00	70.48	NAD	NAD
02	26-051002-06 12th Floor / Dust / Top Of F/G Ins. CUNY R. Office At Closet Door (LOW WEIGHT)	004	0.028	42.86	53.57	3.57	NAD	NAD
03	26-051002-08 15th Floor / AHU #2 / Filter Element Door Inside Temp. Wall (LOW WEIGHT)	007	0.011	63.64	9.09	27.27	NAD	NAD
04	26-051002-09 16.5 Floor / Debris / N/W Corner 16.5 30' E Cooling Tower Area Along Wall	035	0.35	23.14	33.43	43.43	NAD	NAD
05	26-051002-10 16.5 Floor / Dust / Top Of Rectifier #1 Elevator Mech. Room	0119	0.119	24.37	51.26	24.37	NAD	NAD
06	26-051002-11 15th Floor / Hallway Outside Phone Room Above Insulation	0062	0.062	17.74	1.61	79.05	NAD	Chrysotile 1.6
07	26-051002-12 15th Floor / Hallway Outside Phone Room Above Steel Header	016	0.16	18.75	45.00	36.25	NAD	NAD
08	26-051002-14 15th Floor / Dust On Top Of Cooling Tower 8' East Of Door ENG. Office W/Door To Roof	0096	0.096	36.46	34.38	28.17	NAD	Chrysotile <1.0
09	26-051002-15 B Floor / Debris / Exhaust Duct On Fire Protection CZZ On Furn. West Wall	0507	0.507	14.40	28.99	56.61	NAD	NAD
10	26-051002-16 B Floor / Dust / East Side Of Unit AC-7 Air Intake	0335	0.335	21.19	43.88	34.83	NAD	Chrysotile Trace
11	26-051002-17 4th Floor / Dust + Debris / Mastic / 75' West Of F403 Hallway	0944	0.944	30.19	19.81	50.00	NAD	NAD
12	26-051002-18 4th Floor / 25' W. Along Wall Of F-408 Hallway A Top Water Fountains	0207	0.207	22.71	45.41	31.88	NAD	NAD
13	26-051002-19 4th Floor / * Dust / E. Wall 12' S Of Room F-405 Hall	0297	0.297	69.02	4.04	26.84	NAD	Chrysotile Trace

See Reporting notes on last page

SciLab Job#: 202052099
Client Name: Applied Technology Services, Inc.

Table I
Summary of Bulk Asbestos Analysis Results
E02411

SciLab Sample #	Client Sample# Location	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
14	26-051002-20 4th Floor / E. Wall In R. Room 400		0.29	51.72	22.76	24.52	NAD	Chrysotile <1.0

Analyzed by: Roman Peysakhov ; Date Analyzed 5/11/02
Quantitative Analysis (Semi/Full); Bulk Asbestos Analysis - PLM by EPA 600/M4-82-020 per 40 CFR (NVLAP Lab#200546-0); TEM (Semi/Full) by EPA 600/R-93/116 (not covered by NVLAP Bulk accreditation); or ELAP 198.1/198.4 for New York samples (NYSDOH ELAP#11480); NAD = no asbestos detected during a quantitative analysis; NA = not analyzed; Trace = <1%; Quantitation for beginning weights of <0.1 grams should be considered as qualitative only; Qualitative Analysis: Asbestos analysis results of "Present" or "NVA = No Visible Asbestos" represents results for Qualitative PLM or TEM Analysis only (no accreditation coverage available from any regulatory agency for qualitative analyses); AIHA Lab#102843.
Warning Note: PLM limitation, only TEM will resolve fibers <0.25 micrometers in diameter. TEM bulk analysis is representative of the fine grained matrix material and may not be representative of non-uniformly dispersed debris for which PLM evaluation is recommended (i.e. soils and other heterogeneous materials).

Reviewed By: 