

P.05/07

SciLab Job #: 20111640
Client Name: Applied Technology Services, Inc.

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
A01200-1: 84 West Broadway

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
01	29116/01- 07		600	.1	0.0064	0.0	0.0	0.0	<10	<10	<0.0064	<0.0064	NSD
	3rd Floor, Living Room Middle Of Floor												

PII

DEC-11-2001 10:56

Interpretation represented by the detection of 1 structure
not analyzed

0: No Asbestos Structures Detected

Reviewed By: _____

Analyzed By: _____

Alexander Baranovskii

Date: 11/7/01

/LAP#: 100346-0