

p.13

212 679 9392 P. 02/03

SciLab Job #: 201111640
Client Name: Applied Technology Services, Inc.

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
A01200-I; 84 West Broadway

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
01	29 11/601- 07		600	.1	0.0064	0.0	0.0	0.0	<10	<10	<0.0064	<0.0064	NSD
	3rd Floor, Living Room Middle CM Floor, PII												

JOSE JIMENEZ 201-943-9256
SCIENTIFIC LABS

Monday, December 10, 2001 5:42 PM
NOV-07-2001 09:26

concentration represented by the detection of 1 structure

* not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: _____

; Analyzed By: _____

Aleksandr Barenkovits

Date: 11/7/01

NVLAP#: 200546-0