

Scilab Job #: 20111639
Client Name: Applied Technology Services, Inc.

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
A01200-B; 84 West Broadway; Work Area Apartment 5M

Scilab Sample #	Client Sample #	Air Filtered Analyzed (liters)	Area Analyzed (sq. mm.)	Asbestos Structures Detected (fibers)	Structure Density (structures/mm.)		Structure Concentration (structures/air)		Type of Asbestos
					>5.0	Total	>5.0	Total	
01	29 11/5/01-02	600	1	0.0064	0.0	0.0	0.0	0.0	MSD
	5th Floor, Main Bed Room				<10	<10	<0.0064	<0.0064	

DEC-11-2001 11:01

asbestos represented by the detection of 1 structure
or analyzed
No Asbestos Structures Detected

Reviewed By:

Analyzed By:

Alexander Baranovskii

Date: 11/7/01

LAPR: 2003-06-04