

P.05/06

SciLab Job #: 201111616

Client Name: Applied Technology Services, Inc.

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
A01200-J

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
01	29-116/01-08 Living Room PII		600	.1	0.0064	0.0	0.0	0.0	<10	<10	<0.0064	<0.0064	NSD

*** TOTAL PAGE 02 ***


DEC-11-2001 11:02

* concentration represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: _____

Analyzed By: 

Date: 11/7/2001

Alexander Brimengola

NVLAP#: 200546-0

P.06/06

APPLIED TECHNOLOGY SERVICES, INC.

240 NORTH AVENUE
NEW ROCHELLE, NEW YORK 10801
(914) 654-9000
FAX (914) 654-1332

201111616

TOTAL P.06

JOB NO: 101200-J

SAMPLE BY: JOSE JIMENEZ

DAY/DATE: 11-6-01

EMPLOYEE NO: 20

SITE

84 u20.

EPA LEVEL II

SAMPLE ID	B K G	P R P	D U R	F I N	FLR	LOCATION	TIME		FLOW RATE		L/MIN AVG.	DURATION minutes	TTL LTRS AVG X OUR	RESULTS FCC
							START END		START END					
29-110601-02						200B - WALK - 2009	1220		10					
ROTOMETER#						P11	1320		10		10	60	600	
ROTOMETER#														
ROTOMETER#														
ROTOMETER#														
ROTOMETER#														
ROTOMETER#														
ROTOMETER#														
ROTOMETER#														

SENT BY: JOSE JIMENZ

RECEIVED BY: A. Ramos

DATE: 11-6-01

DATE: 11/6/01

TIME: 1640

BLANK
BLANK

TURN AROUND TIME	
	IMMEDIATE
	2 HRS
	12 HRS
☒	24 HRS
	48 HRS
	72 HRS

TYPE OF ANALYSIS: NIOSH 7400 TEM
RUSH: YES () NO (X)

RESULTS TO: JOSE JIMENEZ

FAX: 1-201-943-8288

TEL:

BEEPER:

level 2

DEC-11-2001 11:02