

p.08

212 679 9392 P.03/03

JOSE JIMENEZ 201-943-9256

SCIENTIFIC LABS

Monday, December 10, 2001 5:42 PM

NOV-07-2001 10:03

APPLIED TECHNOLOGY SERVICES, INC.

240 NORTH AVENUE
NEW ROCHELLE, NEW YORK 10801
(914) 854-0000
FAX (914) 854-1332

201111616

JOB NO: 701200-J

DAY / DATE: Tues-11-6-01

SAMPLE BY: JOSE JIMENEZ

EMPLOYEE NO: 29

SITE _____

EPA LEVEL II

SAMPLE ID	B K G	P R P	D U R	F I N	FLR	LOCATION	TIME		FLOW RATE		L/MIN		DURATION minutes	TTL LTRS AVG X OUR	RESULTS FCC
							START	END	START	END	AVG.				
29-110601-08						LAB - LIVING ROOM	1220	10							
ROTOMETER#					PII	PII	1320	10			10		60	600	
ROTOMETER#															
ROTOMETER#															
ROTOMETER#															
ROTOMETER#															
ROTOMETER#															
ROTOMETER#															
ROTOMETER#															

SENT BY: JOSE JIMENEZ

DATE: 11-6-01

RECEIVED BY: A. Ramos

DATE: 11/6/01

TIME: 1640

	BLANK
	BLANK

TURN AROUND TIME	
	IMMEDIATE
	6 HRS
	12 HRS
<u>XXX</u>	24 HRS
	48 HRS
	72 HRS

TYPE OF ANALYSIS: NIOSH 7400 TEM

RUSH: YES () NO (X)

RESULTS TO: JOSE JIMENEZ

FAX: 1-201-943-9256

TEL: _____

BEEPER: _____

TOTAL P.03

p.09

SciLab Job #: 201111616

Client Name: Applied Technology Services, Inc.

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
A01200-J

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
01	29-11/6/01-08 25th Floor, Living Room, PII		600	.1	0.0064	0.0	0.0	0.0	<10	<10	<0.0064	<0.0064	NSD

PII

* concentration represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: _____

Analyzed By: _____

Date: 11/7/01

Aleksandr Barenholtz

NVLAP#: 200546-0

NOV-07-2001 10:03

SCIENTIFIC LABS

212 679 9392 P.02/03

JOSE JIMENEZ 201-943-9256

Monday, December 10, 2001 5:42 PM