

SciLab Job #: 201111785
 Client Name: Applied Technology Services, Inc.

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

A01200-P

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (structure air)	Asbestos Structures Detected (Microns)	Structure Density (structure/mm.)	Structure Concentration (structure/air)	Type of Asbestos
01	29-110701-24		600	.1	0.0064	0.0	<10	<0.0064	NSD
	Amb - Entrance To Apart.					0.0	<10	<0.0064	
						Total	Total	Total	
						>5.0	>5.0	>5.0	

* concentration represented by the detection of 1 structure

** not analyzed

MSD: No Asbestos Structures Detected

NVLAP#: 200546-0

Reviewed By:

Analyzed By:

Date: 11/9/01

Paul Mucha

APPLIED TECHNOLOGY SERVICES, INC.

240 NORTH AVENUE

NEW ROCHELLE, NEW YORK 10801

7914) 054-0090

FAX (914) 854-1332

JOE BOE

19012009

DAY / DATE:

1060-4-300X

西遊記

site

PI

SAMPLE BY: JOSE JIMENEZ

EMPLOYEE NO: 20

EPA LEVEL II

張

[illegible]

SENT BY: JOSE JIMENEZ

RECEIVED BY:

DATE: 11-7-01

DATE:

BLANK

TIME:

TYPE OF ANALYSIS: NIOSH 7400 TEM
RUSH# YES () NO (X)

RESULTS TO: JOSE JIMENEZ

FAX: 1-201-843-9258

TEL

DEEPER: