

5 To
88 West
Brooklyn

SciLab Job#: 20111758

Client Name: Applied Technology Services, Inc.

Table I
Summary of Bulk Asbestos Analysis Results
A01200-Q: 88 WB

SciLab Sample #	Client Sample# Location	HQ Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	Asbestos by PLM/DS	Asbestos by TEM
01	29 110701 33 Window Still W.B. Side Middle Window		---	---	---	---	NA	Chrysotile PRI
02	29 110701 34 Gray Chairs By Window		---	---	---	---	NA	Chrysotile PRI

Analyzed by: Paul M. Motta



Date Analyzed: 11/8/01

HEADNOTE = an asbestos detected; NA = not analyzed; NA/PS = not analyzed / positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab #200545-0) and ELAP PL Protocol 198.1 for New York samples (NYSDOH ELAP Lab # 11489); ELAP TRM Analysis Protocol 198.4 for negative NY NOB samples. Note: PLM is not consistently reliable in detecting asbestos in floor and similar non-finish organically bound materials. TEM is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos-containing in New York State (EPA Advisory for floor tile, FR 59, 146, 38970, 8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the laboratory. This PLM report relates ONLY to the items tested.
AIHA# 102843; VT Cert# AL016055 (A) = No Visible Asbestos

Reviewed By:

