

**Applied Technology Services, Inc.****Bulk Sample Analysis Summary**

Location: 84 W. BROADWAY MANHATTAN NY  
 ATS Project # A01200

Client:  
 Client Reference #

| SAMPLE ID #  | FLR   | APART ADDRESS       | LOCATION                    | SAMPLE DESCRIPTION | TSM | ACM CODE | PLM TEM % TYPE | TEM AIRS                  | PCM AIRS |
|--------------|-------|---------------------|-----------------------------|--------------------|-----|----------|----------------|---------------------------|----------|
| 29-110701-20 | 1     | 72 WARREN ST M&R    | FRONT COUNTER TOP           | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-25 | 2 1/2 | 74 WARREN ST        | LIVING ROOM BY WINDOW       | AIR SAMPLES        |     |          |                | CHRYSTOLE 1 FIBER PRESENT |          |
| 29-110701-15 | 5 1/2 | 74 WARREN ST        | LIVING ROOM BY WINDOW       | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-21 | 1     | 74 WARREN ST SCHOOL | MIDDLE OF FLOOR IN CORRIDOR | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-27 | 5     | 74 WARREN ST SCHOOL | LIVING ROOM                 | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-17 | 2N    | 84 W. BROADWAY      | MAIN BEDROOM BY WINDOW      | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-23 | 4S    | 84 W. BROADWAY      | ENTRANCE TO APART           | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-24 | 5S    | 84 W. BROADWAY      | ENTRANCE TO APART           | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-26 | 1     | 86 W.B. JEANNE LTD  | ENTRANCE TO STORE           | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-22 | B     | 88 W.B. BASEMENT    | CORRIDOR BETWEEN BUILD      | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-14 | 5     | 88 W.B. BASEMENT    | LIVING ROOM                 | AIR SAMPLES        |     |          |                | NSD                       |          |
| 29-110701-45 | 1     | 72 WARREN ST M&R    | FRONT WINDOW SILL           | DUST WIPE          | M   | WIP-023  | NVA            |                           |          |
| 29-110701-46 | 1     | 72 WARREN ST M&R    | L/S CLOTHING RACK           | DUST VACUUM        | M   | DVC-023  | NVA            |                           |          |
| 29-110701-35 | 5 1/2 | 74 WARREN ST        | R/S WINDOW SILL             | DUST WIPE          | M   | WIP-018  | NVA            |                           |          |
| 29-110701-36 | 5 1/2 | 74 WARREN ST        | FRONT ENTRANCE SOFA         | DUST VACUUM        | M   | DVC-018  | NVA            |                           |          |

NAD = No Asbestos Detected  
 PLM = Polarized Light Microscopy  
 NVA = No Visible Asbestos  
 NSD = No Structures Detected  
 TEM = Transmission Electron Microscopy  
 NA = Not Analyzed

T = Thermal Systems Insulation  
 S = Surfacing Materials  
 M = Misc