



**AIRBORNE ASBESTOS MONITORING DURING
9/11 DUST DECONTAMINATION**

PCM RESULTS

AT

**110 CHURCH STREET
NEW YORK, NEW YORK**

PREPARED FOR

**MR. MICHAEL RIEGLER
LIONS HEAD 110 DEVELOPMENT LLC
150 EAST 58th STREET
NEW YORK, NEW YORK 10155**

PREPARED BY

**ENVIRONMENTAL MONITORING & CONSULTING ASSOCIATES
POST OFFICE BOX 872
SOMERVILLE, NEW JERSEY 08876**


ENTERED

732.249.3005

1-19/01 PCM
12 < 7 (+)
5 (-)

AIRTEK ENVIRONMENTAL CORP		Date: 11/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 1 Code: FV	
--Types of Project--		Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01			
Sample	FV -1119-01	FV -1119-02	FV -1119-03	FV -1119-04	FV -1119-05
Location	IWA,110 CHURCH ST. GRND. FL. WITHIN 15FT.	IWA,110 CHURCH ST. 10 FT. EAST 50 MURRAY ST.	IWA,110 CHURCH ST. GRND. FL. /SE SIDE OF FLOOR	IWA,110 CHURCH ST. GRND. FL. NE SIDE OF FLOOR	IWA,110 CHURCH ST. GRND. FL. WITHIN 15FT.
Activity	BACKGROUND	BACKGROUND	BACKGROUND	BACKGROUND	BACKGROUND
Personal					
Avg Flow	10.0	10.0	10.0	10.0	10.0
Cal Date	11/19/01	11/19/01	11/19/01	11/19/01	11/19/01
Time On	11:20A	11:23A	11:26A	11:29A	01:20P
Time Off	01:20P	01:23P	01:26P	01:29P	03:20P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1200 ltr	1200 ltr	1200 ltr	1200 ltr	1200 ltr
AV Cnt Fibr Per Fld	.18	.53	.215	.235	.525
Fibr Cnt Fibr Per CC	0.0074	0.0217	0.0088	0.0096	0.0215
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature 

AIRTEK ENVIRONMENTAL CORP		Date: 11/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 2 Code: FV	
--Types of Project--		Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01			
Sample	FV -1119-06	FV -1119-	FV -1119-	FV -1119-	FV -1119-
Location	IWA, 110 CHURCH ST. 10FT. EAST 50 MURRAY ST.				
Activity	BACKGROUND				
Personal					
Avg Flow	10.0	0.0	0.0	0.0	0.0
Cal Date	11/19/01	11/19/01	11/19/01	11/19/01	11/19/01
Time On	01:23P				
Time Off	03:23P				
Tot Time	120 min				
Tot Vol	1200 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.645				
Fibr Cnt Fibr Per CC	0.0264				
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 3 Code: FV	
--Types of Project--		Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01			
Sample	FV -1119-07	FV -1119-08	FV -1119-09	FV -1119-10	FV -1119-11
Location	IWA,110 CHURCH ST. GRND FL. SE SIDE OF FLOOR	IWA,110 CHURCH ST. GRND FL. NE SIDE OF FL.	IWA,110 CHURCH ST. GRND. FL. WITHIN 15FT.	IWA,110 CHURCH ST. WITHIN 10 FT. EAST FROM 50	IWA,110 CHURCH ST. GRND. FL. SE SIDE OF FLOOR
Activity	BACKGROUND	BACKGROUND	BACKGROUND	BACKGROUND	BACKGROUND
Personal					
Avg Flow	10.0	10.0	10.0	10.0	10.0
Cal Date	11/19/01	11/19/01	11/19/01	11/19/01	11/19/01
Time On	01:26P	01:29P	03:20P	03:23P	03:26P
Time Off	03:26P	03:29P	05:20P	05:23P	05:26P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1200 ltr	1200 ltr	1200 ltr	1200 ltr	1200 ltr
AV Cnt Fibr Per Fld	.415	.36	.64	.26	.235
Fibr Cnt Fibr Per CC	0.0170	0.0147	0.0262	0.0106	0.0096
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 4 Code: FV	
--Types of Project--		Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01			
Sample	FV -1119-12	FV -1119-	FV -1119-	FV -1119-	FV -1119-
Location	IWA, 110 CHURCH ST. GRND FL. NE SIDE OF FLOOR				
Activity	BACKGROUND				
Personal					
Avg Flow	10.0	0.0	0.0	0.0	0.0
Cal Date	11/19/01	11/19/01	11/19/01	11/19/01	11/19/01
Time On	03:29P				
Time Off	05:29P				
Tot Time	120 min				
Tot Vol	1200 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.16				
Fibr Cnt Fibr Per CC	0.0065				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 11/19/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 5 Code: FV
--Types of Project-- Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01		

Sample	FV -1119-13	FV -1119-14	FV -1119-	FV -1119-	FV -1119-
Location	FIELD BLANK	FIELD BLANK			
Activity	Other	Other			
Personal	- -	- -			
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/19/01	11/19/01	11/19/01	11/19/01	11/19/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0	0	0
AV Cnt					
Fibr					
Per Fld	BDL	BDL			
Fibr Cnt					
Fibr					
Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

11/20/01 PCM

~~18~~ < 7(+)
17 < 10(-)

AIRTEK ENVIRONMENTAL CORP	Date: 11/20/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 6 Code: FV
--Types of Project-- Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01		

Sample	FV -1120-01	FV -1120-02	FV -1120-03	FV -1120-04	FV -1120-05
Location	ADJ.CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA,WITHIN 10 FT. FROM MURRAY ST. ENTRANCE	IWA,110 CHURCH GRND. FL. NE SIDE OF FLOOR	IWA,110 CHURCH MAIN STAIRCASE 6TH FLOOR	IWA,110 CHURCH ST. MAIN STAIRS 9TH FLOOR
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal	- -	- -			
Avg Flow	6.0	6.0	10.0	10.0	9.0
Cal Date	11/20/01	11/20/01	11/20/01	11/20/01	11/20/01
Time On	07:06A	07:08A	07:10A	07:15A	08:20A
Time Off	11:36A	11:38A	08:10A	08:15A	11:20A
Tot Time	270 min	270 min	60 min	60 min	180 min
Tot Vol	1620 ltr	1620 ltr	600 ltr	600 ltr	1620 ltr
AV Cnt Fibr Per Fld	.32	.785	.105	.005	.005
Fibr Cnt Fibr Per CC	0.0097	0.0238	0.0086	< 0.0045	< 0.0017
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/20/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 7 Code: FV	
--Types of Project--		Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01			
Sample	FV -1120-06	FV -1120-	FV -1120-	FV -1120-	FV -1120-
Location	IWA, 110 CHURCH ST. 8TH FL. CENTER WESTSIDE FL.				
Activity	PRE ABATEMENT				
Personal	- -				
Avg Flow	9.0	0.0	0.0	0.0	0.0
Cal Date	11/20/01	11/20/01	11/20/01	11/20/01	11/20/01
Time On	08:25A				
Time Off	11:25A				
Tot Time	180 min				
Tot Vol	1620 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.14				
Fibr Cnt Fibr Per CC	0.0042				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 11/20/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 10 Code: FV
--Types of Project-- Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01		

Sample	FV -1120-12	FV -1120-	FV -1120-	FV -1120-	FV -1120-
Location	ADJ.CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE				
Activity	PRE ABATEMENT				
Personal	- -				
Avg Flow	10.0	0.0	0.0	0.0	0.0
Cal Date	11/20/01	11/20/01	11/20/01	11/20/01	11/20/01
Time On	02:36P				
Time Off	05:26P				
Tot Time	170 min				
Tot Vol	1700 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.225				
Fibr Cnt Fibr Per CC	0.0065				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/20/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 11 Code: FV	
--Types of Project--		Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/21/01			
Sample	FV -1120-13	FV -1120-14	FV -1120-15	FV -1120-16	FV -1120-17
Location	OWA, WITHIN 10FT. FROM ENTRANCE AT 50 MURRAY ST	IWA, 110 CHURCH ST. 10FT. FROM MAIN STAIRS	IWA, 110 CHURCH ST. WEST ELEVATOR BANK GRND FL.	IWA, 110 CHURCH ST. GRND. FL. NORTH CENTER	FIELD BLANK
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	Other
Personal	- -				- -
Avg Flow	10.0	10.0	10.0	10.0	0.0
Cal Date	11/20/01	11/20/01	11/20/01	11/20/01	11/20/01
Time On	02:38P	02:45P	02:48P	02:51P	
Time Off	05:28P	05:15P	05:18P	05:21P	
Tot Time	170 min	150 min	150 min	150 min	
Tot Vol	1700 ltr	1500 ltr	1500 ltr	1500 ltr	0000000000
AV Cnt Fibr Per Fld	.01	.595	.705	.41	BDL
Fibr Cnt Fibr Per CC	< 0.0016	0.0195	0.0230	0.0134	
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK
ENVIRONMENTAL
CORP

Date: 11/20/01
AIR SAMPLING RESULTS

Proj Num: 01-1212

Page: 12

Code: FV

--Types of Project--

Address: LIONS HEAD 53
DEVELOPEMENT LLC
110 CHURCH STREET

State:

Zip:

Date Analyzed: 11/21/01

Sample	FV -1120-18	FV -1120-	FV -1120-	FV -1120-	FV -1120-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/20/01	11/20/01	11/20/01	11/20/01	11/20/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

11/21/01

PCM

15 < $\frac{8\oplus}{7\ominus}$

AIRTEK ENVIRONMENTAL CORP	Date: 11/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 14 Code: FV
--Types of Project-- Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/01/01		

Sample	FV -1121-06	FV -1121-	FV -1121-	FV -1121-	FV -1121-
Location	ADJ.CLEAN RM PERSON. DECON GRND. FL. 50 MURRAY ST.				
Activity	PRE ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/21/01	11/21/01	11/21/01	11/21/01	11/21/01
Time On	10:30A				
Time Off	01:30P				
Tot Time	180 min				
Tot Vol	1260 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.125				
Fibr Cnt Fibr Per CC	0.0049				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 11/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 15 Code: FV
--Types of Project-- Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/01/01		

Sample	FV -1121-07	FV -1121-08	FV -1121-09	FV -1121-10	FV -1121-11
Location	OWA, WITHIN 10FT. FROM ENTRANCE 50 MURRAY ST.	IWA, STAIRCASE TO BASEMENT	IWA, 2ND FLOOR WITHIN 10FT. FROM STAIRCASE	IWA, 2ND FLOOR NEXT TO ELEVATOR BANK	IWA, WITHIN 10FT. STAIR CASE GROUND FLOOR
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	6.0
Cal Date	11/21/01	11/21/01	11/21/01	11/21/01	11/21/01
Time On	10:32A	10:35A	10:38A	10:41A	12:50P
Time Off	12:32P	01:35P	01:38P	01:41P	04:50P
Tot Time	120 min	180 min	180 min	180 min	240 min
Tot Vol	840 ltr	1260 ltr	1260 ltr	1260 ltr	1440 ltr
AV Cnt Fibr Per Fld	.65	.395	1.66	.005	.395
Fibr Cnt Fibr Per CC	0.0379	0.0154	0.0646	< 0.0021	0.0135
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 11/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 16 Code: FV
--Types of Project-- Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/01/01		

Sample	FV -1121-12	FV -1121-	FV -1121-	FV -1121-	FV -1121-
Location	ADJ.CLEAN RM PERSON. DECON 50 MURRAY ST. ENT. GRND FL.				
Activity	PRE ABATEMENT				
Personal	- -				
Avg Flow	6.0	0.0	0.0	0.0	0.0
Cal Date	11/21/01	11/21/01	11/21/01	11/21/01	11/21/01
Time On	01:30P				
Time Off	05:30P				
Tot Time	240 min				
Tot Vol	1440 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.09				
Fibr Cnt Fibr Per CC	0.0031				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/21/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 17 Code: FV	
--Types of Project--		Address: LIONS HEAD 53 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/01/01			
Sample	FV -1121-13	FV -1121-14	FV -1121-15	FV -1121-16	FV -1121-17
Location	IWA, STAIRCASE TO BASEMENT	IWA, 2ND FL. WITHIN 10FT. FROM STAIRCASE	IWA, 2ND FLOOR NEXT TO EAST ELEVATOR BANK	FIELD BLANK	FIELD BLANK
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	Other	Other
Personal	- -			- -	- -
Avg Flow	7.0	7.0	7.0	0.0	0.0
Cal Date	11/21/01	11/21/01	11/21/01	11/21/01	11/21/01
Time On	01:35P	01:38P	01:14P		
Time Off	05:15P	05:18P	05:21P		
Tot Time	220 min	220 min	247 min		
Tot Vol	1540 ltr	1540 ltr	1729 ltr	0000000000	0000000000
AV Cnt Fibr Per Fld	.91	1.39	.005	BDL	BDL
Fibr Cnt Fibr Per CC	0.0290	0.0443	< 0.0016		
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK
ENVIRONMENTAL
CORP

Date: 11/21/01
AIR SAMPLING RESULTS

Proj Num: 01-1212

Page: 18

Code: FV

--Types of Project--

Address: LIONS HEAD
DEVELOPEMENT LLC
110 CHURCH STREET
State: Zip:

Date Analyzed: 12/01/01

Sample	FV -1121-18	FV -1121-	FV -1121-	FV -1121-	FV -1121-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/21/01	11/21/01	11/21/01	11/21/01	11/21/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

11/26/01 PCM
23a
23 < 12(+)
11(-)

AIRTEK ENVIRONMENTAL CORP		Date: 11/26/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 20 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/01/01			
Sample	FV -1126-06	FV -1126-	FV -1126-	FV -1126-	FV -1126-
Location	IWA, BSMT. ADJ. TO ELEVATOR SHAFT				
Activity	PRE ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/26/01	11/26/01	11/26/01	11/26/01	11/26/01
Time On	07:26A				
Time Off	10:26A				
Tot Time	180 min				
Tot Vol	1260 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.005				
Fibr Cnt Fibr Per CC	< 0.0021				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 11/26/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 21 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/01/01		

Sample	FV -1126-07	FV -1126-08	FV -1126-09	FV -1126-10	FV -1126-11
Location	IWA,BASEMENT NORTH CENTER SIDE OF ROOM	IWA,SUB BSMT RAMP AREA	ADJ,CLEAN RM PERSON. DECON ENT. AT 50 MURRAY ST.	IWA,1ST FL. WITHIN 15FT. OF MAIN STAIRCASE	IWA,1ST FL. ADJ. TO STAIRS TO BASEMENT
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/26/01	11/26/01	11/26/01	11/26/01	11/26/01
Time On	07:29A	07:32A	10:15A	10:17A	10:19A
Time Off	10:29A	10:32A	01:35P	01:37P	01:39P
Tot Time	180 min	180 min	200 min	200 min	200 min
Tot Vol	1260 ltr	1260 ltr	1400 ltr	1400 ltr	1400 ltr
AV Cnt Fibr Per Fld	.015	.80	.13	.52	VOID
Fibr Cnt Fibr Per CC	< 0.0021	0.0311	0.0046	0.0182	VOID
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 11/26/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 22 Code: FV
--Types of Project--		Address: LIONS HEAD DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/01/01

Sample	FV -1126-12	FV -1126-	FV -1126-	FV -1126-	FV -1126-
Location	IWA, 2ND FL. EAST ELEVATOR RANK				
Activity	PRE ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/26/01	11/26/01	11/26/01	11/26/01	11/26/01
Time On	10:21A				
Time Off	01:41P				
Tot Time	200 min				
Tot Vol	1400 ltr	0	0	0	0
AV Cnt Fibr Per Fld	VOID				
Fibr Cnt Fibr Per CC	VOID				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature 

AIRTEK ENVIRONMENTAL CORP	Date: 11/26/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 23 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/01/01		

Sample	FV -1126-13	FV -1126-14	FV -1126-15	FV -1126-16	FV -1126-17
Location	IWA, 2ND FL. STAIRCASE	IWA, BSMT. ADJ TO ELEVATOR SHAFT	IWA, BSMT. NORTH CENTER SIDE OF RM.	IWA, SUB BSMT RAMP AREA	ADJ, CLEAN RM PERSON. DECON ENT. AT 50 MURRAY ST.
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/26/01	11/26/01	11/26/01	11/26/01	11/26/01
Time On	10:23A	10:26A	10:29A	10:32A	01:35P
Time Off	01:43P	01:46P	01:49P	01:52P	05:25P
Tot Time	200 min	200 min	200 min	200 min	230 min
Tot Vol	1400 ltr	1400 ltr	1400 ltr	1400 ltr	1610 ltr
AV Cnt Fibr Per Fld	1.81	.01	.005	.955	.07
Fibr Cnt Fibr Per CC	0.0634	< 0.0019	< 0.0019	0.0335	0.0021
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/26/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 24 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/01/01			
Sample	FV -1126-18	FV -1126-	FV -1126-	FV -1126-	FV -1126-
Location	IWA, 1ST FL. WITHIN 15FT. OF MAIN STAIRCASE				
Activity	PRE ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/26/01	11/26/01	11/26/01	11/26/01	11/26/01
Time On	01:37P				
Time Off	05:27P				
Tot Time	230 min				
Tot Vol	1610 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.44				
Fibr Cnt Fibr Per CC	0.0134				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/26/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 25 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/01/01			
Sample	FV -1126-19	FV -1126-20	FV -1126-21	FV -1126-22	FV -1126-23
Location	IWA, 1ST FL. ADJ. TO STAIR CASE TO BSMT	IWA, 2ND FL. ELEVATOR BANK 4	IWA, BSMT. ADJ. TO ELEVATOR SHAFT 4	IWA, BSMT NORTH CENTER SIDE OF RM	IWA, SUB BSMT RAMP AREA
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/26/01	11/26/01	11/26/01	11/26/01	11/26/01
Time On	01:39P	01:41P	01:46P	01:49P	01:52P
Time Off	05:19P	05:21P	05:06P	05:09P	05:12P
Tot Time	220 min	220 min	200 min	200 min	200 min
Tot Vol	1540 ltr	1540 ltr	1400 ltr	1400 ltr	1400 ltr
AV Cnt Fibr Per Fld	.335	.005	1.18	.04	.01
Fibr Cnt Fibr Per CC	0.0107	< 0.0018	0.0413	< 0.0019	< 0.0019
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/26/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 26 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/01/01			
Sample	FV -1126-24	FV -1126-	FV -1126-	FV -1126-	FV -1126-
Location	SUB BSMT WITHIN 15FT. FROM STAIRCASE				
Activity	PRE ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/26/01	11/26/01	11/26/01	11/26/01	11/26/01
Time On	01:55P				
Time Off	05:15P				
Tot Time	200 min				
Tot Vol	1400 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.635				
Fibr Cnt Fibr Per CC	0.0222				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 11/26/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 27 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/01/01		

Sample	FV -1126-25	FV -1126-26	FV -1126-27	FV -1126-28	FV -1126-29
Location	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	Other	Other	Other	Other	Other
Personal	- -	- -	- -	- -	- -
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/26/01	11/26/01	11/26/01	11/26/01	11/26/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	BDL	BDL	BDL	BDL	BDL
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




11/27/01
22 < 8+ PCM
14(-)

AIRTEK ENVIRONMENTAL CORP		Date: 11/27/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 29 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/28/01			
Sample	FV -1127-01	FV -1127-02	FV -1127-03	FV -1127-04	FV -1127-05
Location	ADJ, CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. WITHIN 15FT. EAST FROM ENT.	OWA, 1ST FL. WITHIN 25' WEST FROM ENTRANCE	IWA, 1ST FL. STAIRCASE 20FT. FROM CLEANING ZONE	IWA, 2ND FL. SE SIDE OF FL. ACTIVE CLEANING AREA
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On	07:30A	07:33A	07:35A	08:40A	08:43A
Time Off	11:00A	11:03A	11:05A	12:00P	12:03P
Tot Time	210 min	210 min	210 min	200 min	200 min
Tot Vol	1470 ltr	1470 ltr	1470 ltr	1400 ltr	1400 ltr
AV Cnt Fibr Per Fld	.31	.01	.01	.22	1.46
Fibr Cnt Fibr Per CC	0.0103	< 0.0018	< 0.0018	0.0077	0.0511
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/27/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 30 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/28/01			
Sample	FV -1127-06	FV -1127-	FV -1127-	FV -1127-	FV -1127-
Location	IWA, 3RD FL. ADJ. TO ENT. STAIRCASE 25FT. CLEANING				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On	08:46A				
Time Off	12:06P				
Tot Time	200 min				
Tot Vol	1400 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.67				
Fibr Cnt Fibr Per CC	0.0235				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/27/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 31 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/28/01			
Sample	FV -1127-07	FV -1127-08	FV -1127-09	FV -1127-10	FV -1127-11
Location	IWA, 22ND FL. STAIRWELL TO ELEVATOR MOTOR RM.	IWA, ELEVATOR MOTOR RM. PENTHOUSE 23RD FLOOR	ADJ, CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 15FT. FROM 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. WITHIN 25FL. 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	7.0	7.0	7.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On	08:58A	08:59A	11:00A	11:03A	11:05A
Time Off	03:18P	03:19P	02:00P	02:03P	02:05P
Tot Time	380 min	380 min	180 min	180 min	180 min
Tot Vol	1900 ltr	1900 ltr	1260 ltr	1260 ltr	1260 ltr
AV Cnt Fibr Per Fld	.02	.34	.05	.01	.01
Fibr Cnt Fibr Per CC	< 0.0014	0.0088	< 0.0021	< 0.0021	< 0.0021
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/27/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 32 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/28/01			
Sample	FV -1127-12	FV -1127-	FV -1127-	FV -1127-	FV -1127-
Location	IWA, 1ST FL. STAIRCASE WITHIN 20FT. CLEANING ZONE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On	12:00P				
Time Off	03:00P				
Tot Time	180 min				
Tot Vol	1260 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.12				
Fibr Cnt Fibr Per CC	0.0047				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/27/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 33 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/28/01			
Sample	FV -1127-13	FV -1127-14	FV -1127-15	FV -1127-16	FV -1127-17
Location	IWA, 2ND FL. SE SIDE OF FLOOR ACTIVE CLEANING AREA	IWA, 3RD FL. ADJ. TO ENT. STAIRCASE 25 FT. CLEANING	ADJ, CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. WITHIN 15FT. 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. STAIRCASE WITHIN 20FT. CLEANING ZONE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On	12:03P	12:06P	02:00P	02:03P	02:05P
Time Off	03:03P	03:06P	05:30P	05:13P	05:15P
Tot Time	180 min	180 min	210 min	190 min	190 min
Tot Vol	1260 ltr	1260 ltr	1470 ltr	1330 ltr	1330 ltr
AV Cnt Fibr Per Fld	.30	1.08	.03	.01	.01
Fibr Cnt Fibr Per CC	0.0117	0.0420	< 0.0018	< 0.0020	< 0.0020
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 11/27/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 34 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 11/28/01		

Sample	FV -1127-18	FV -1127-	FV -1127-	FV -1127-	FV -1127-
Location	IWA, 1ST FL. STAIRCASE WIHTIN 20FT. CLEANING ZONE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On	03:00P				
Time Off	05:00P				
Tot Time	120 min				
Tot Vol	840 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.27				
Fibr Cnt Fibr Per CC	0.0158				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/27/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 35 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/28/01			
Sample	FV -1127-19	FV -1127-20	FV -1127-21	FV -1127-22	FV -1127-23
Location	IWA, 2ND FL. NE SIDE OF FL ACTIVE CLEANING AREA	IWA, 3RD FL. ADJ. TO ENT. STAIRCASE 25 FT. CLEANING	IWA, 23RD FL. PENTHOUSE ELEV. MOTOR RM.	IWA, 23RD FL. PENTHOUSE ELEV. MOTOR RM.	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	Other
Personal					- -
Avg Flow	7.0	7.0	10.0	10.0	0.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On	03:03P	03:06P	03:28P	03:29P	
Time Off	05:18P	05:19P	05:28P	05:29P	
Tot Time	135 min	133 min	120 min	120 min	
Tot Vol	945 ltr	931 ltr	1200 ltr	1200 ltr	0000000000
AV Cnt Fibr Per Fld	.40	.43	.195	.15	BDL
Fibr Cnt Fibr Per CC	0.0208	0.0227	0.0080	0.0061	
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/27/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 36 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET' State: Zip: Date Analyzed: 11/28/01			
Sample	FV -1127-24	FV -1127-	FV -1127-	FV -1127-	FV -1127-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/27/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 37 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/28/01			
Sample	FV -1127-25	FV -1127-26	FV -1127-	FV -1127-	FV -1127-
Location	FIELD BLANK	FIELD BLANK			
Activity	Other	Other			
Personal	- -	- -			
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/27/01	11/27/01	11/27/01	11/27/01	11/27/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0	0	0
AV Cnt Fibr Per Fld	BDL	BDL			
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

11-28-01

20K ~~10~~ (+) PCM
10 (-)

AIRTEK ENVIRONMENTAL CORP		Date: 11/28/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 38 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/29/01			
Sample	FV -1128-01	FV -1128-02	FV -1128-03	FV -1128-04	FV -1128-05
Location	ADJ, CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. WITHIN 15FT. FL. FROM ENT. 50 MURRAY ST.	OWA, 1ST FL. N. SIDE 25FT. 50 MURRAY ST. ENTRANCE	IWA, 1ST FL. WITHIN 10FT. FROM MAIN STAIRCASE	IWA, 1ST FL. WEST ELEVATOR BANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -	- -			
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/28/01	11/28/01	11/28/01	11/28/01	11/28/01
Time On	07:10A	07:13A	07:16A	07:19A	07:22A
Time Off	10:30A	10:33A	10:36A	10:39A	10:42A
Tot Time	200 min	200 min	200 min	200 min	200 min
Tot Vol	1400 ltr	1400 ltr	1400 ltr	1400 ltr	1400 ltr
AV Cnt Fibr Per Fld	.05	.015	.02	.725	.53
Fibr Cnt Fibr Per CC	< 0.0019	< 0.0019	< 0.0019	0.0254	0.0186
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/28/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 39 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/29/01			
Sample	FV -1128-06	FV -1128-	FV -1128-	FV -1128-	FV -1128-
Location	IWA, 2ND FL. NORTH CENTER SIDE OF FL.				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/28/01	11/28/01	11/28/01	11/28/01	11/28/01
Time On	07:25A				
Time Off	10:45A				
Tot Time	200 min				
Tot Vol	1400 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.57				
Fibr Cnt Fibr Per CC	0.0200				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/28/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 40 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/29/01			
Sample	FV -1128-07	FV -1128-08	FV -1128-09	FV -1128-10	FV -1128-11
Location	IWA, 2ND FL. E. SIDE OF FL.	IWA, 17TH FL. STAIRCASE ADJ TO DOOR ENTRANCE	ADJ, CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. WITHIN 15FT. ENT. 50 MURRAY ST.	OWA, 1ST FL. N. SIDE OF WITHIN 25FT. 50 MURRAY ST.
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/28/01	11/28/01	11/28/01	11/28/01	11/28/01
Time On	07:27A	07:35A	10:30A	10:33A	10:36A
Time Off	10:47A	10:55A	02:00P	02:03P	02:06P
Tot Time	200 min	200 min	210 min	210 min	210 min
Tot Vol	1400 ltr	1400 ltr	1470 ltr	1470 ltr	1470 ltr
AV Cnt Fibr Per Fld	.47	VOID	.115	.03	.02
Fibr Cnt Fibr Per CC	0.0165	VOID	0.0038	< 0.0018	< 0.0018
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/28/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 41 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/29/01			
Sample	FV -1128-12	FV -1128-	FV -1128-	FV -1128-	FV -1128-
Location	IWA, 1ST FL. WITHIN 10FT. FROM MAIN STAIRCASE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/28/01	11/28/01	11/28/01	11/28/01	11/28/01
Time On	10:39A				
Time Off	02:09P				
Tot Time	210 min				
Tot Vol	1470 ltr	0	0	0	0
AV Cnt Fibr Per Fld	VOID				
Fibr Cnt Fibr Per CC	VOID				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/28/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 43 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/29/01			
Sample	FV -1128-18	FV -1128-	FV -1128-	FV -1128-	FV -1128-
Location	OWA, 1ST FL. 15FT. FROM ENT. AT 50 MURRAY ST.				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/28/01	11/28/01	11/28/01	11/28/01	11/28/01
Time On	02:03P				
Time Off	05:03P				
Tot Time	180 min				
Tot Vol	1260 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.015				
Fibr Cnt Fibr Per CC	< 0.0021				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/28/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 45 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/29/01			
Sample	FV -1128-24	FV -1128-	FV -1128-	FV -1128-	FV -1128-
Location	IWA, 3RD FL. STAIRCASE ADJ TO DOOR ENT.				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/28/01	11/28/01	11/28/01	11/28/01	11/28/01
Time On	02:20P				
Time Off	05:20P				
Tot Time	180 min				
Tot Vol	1260 ltr	0	0	0	0
AV Cnt Fibr Per Fld	VOID				
Fibr Cnt Fibr Per CC	VOID				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 11/28/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 46 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 11/29/01		

Sample	FV -1128-25	FV -1128-26	FV -1128-27	FV -1128-28	FV -1128-29
Location	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	Other	Other	Other	Other	Other
Personal	- -	- -	- -	- -	- -
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/28/01	11/28/01	11/28/01	11/28/01	11/28/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	BDL	BDL	BDL	BDL	BDL
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



11-29-01 PCM

22 ALL
(-)

AIRTEK
ENVIRONMENTAL
CORP

Date: 11/29/01
AIR SAMPLING RESULTS

Proj Num: 01-1212
Page: 48
Code: FV

--Types of Project--


Address: LIONS HEAD 110
DEVELOPEMENT LLC
110 CHURCH STREET
State: Zip:

Date Analyzed: 11/30/01

Sample	FV -1129-06	FV -1129-	FV -1129-	FV -1129-	FV -1129-
Location	IWA, 2ND FL. NORTH CENTER SIDE OF FLOOR				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On	07:30A				
Time Off	10:10A				
Tot Time	160 min				
Tot Vol	1120 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.04				
Fibr Cnt Fibr Per CC	< 0.0024				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 11/29/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 49 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 11/30/01		

Sample	FV -1129-07	FV -1129-08	FV -1129-09	FV -1129-10	FV -1129-11
Location	IWA,BSMT. RAMP AREA NW SIDE OF FL.	IWA,BSMT. NORTH CENTER SIDE OF AREA	CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 15FT. FROM 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 20FT. WEST 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On	07:40A	07:42A	10:00A	10:02A	10:03A
Time Off	10:20A	10:22A	01:20P	01:22P	01:23P
Tot Time	160 min	160 min	200 min	200 min	200 min
Tot Vol	1120 ltr	1120 ltr	1400 ltr	1400 ltr	1400 ltr
AV Cnt Fibr Per Fld	.08	.20	.05	.025	.02
Fibr Cnt Fibr Per CC	0.0035	0.0088	< 0.0019	< 0.0019	< 0.0019
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 11/29/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 50 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 11/30/01		

Sample	FV -1129-12	FV -1129-	FV -1129-	FV -1129-	FV -1129-
Location	IWA, 1ST FL. 10FT. SOUTH OF EAST ELEV. BANK				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On	10:08A				
Time Off	01:28P				
Tot Time	200 min				
Tot Vol	1400 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.02				
Fibr Cnt Fibr Per CC	< 0.0019				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/29/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 51 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/30/01			
Sample	FV -1129-13	FV -1129-14	FV -1129-15	FV -1129-16	FV -1129-17
Location	IWA, 2ND FLOOR NORTH CENTER SIDE OF FLOOR	IWA, SUB BSMT. RAMP AREA NW. SIDE OF FLOOR	IWA, BASEMENT NORTH CENTER SIDE OF FL.	ADJ, CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 15FT. EAST FROM MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On	10:10A	10:20A	10:22A	01:20P	01:22P
Time Off	01:30P	01:40P	01:42P	05:30P	05:22P
Tot Time	200 min	200 min	200 min	250 min	240 min
Tot Vol	1400 ltr	1400 ltr	1400 ltr	1750 ltr	1680 ltr
AV Cnt Fibr Per Fld	.07	.115	.17	.02	.01
Fibr Cnt Fibr Per CC	0.0025	0.0040	0.0060	< 0.0015	< 0.0016
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/29/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 52 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/30/01			
Sample	FV -1129-18	FV -1129-	FV -1129-	FV -1129-	FV -1129-
Location	OWA, 1ST FL. 20FT. WEST FROM MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On	01:23P				
Time Off	05:23P				
Tot Time	240 min				
Tot Vol	1680 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.01				
Fibr Cnt Fibr Per CC	< 0.0016				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/29/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 53 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/30/01			
Sample	FV -1129-19	FV -1129-20	FV -1129-21	FV -1129-22	FV -1129-23
Location	IWA, 1ST FL. 10FT. SOUTH OF EAST ELEV. BANK	IWA, SUB BSMT. RAMP AREA NW SIDE OF FL.	IWA, BSMT. NORTH CENTER SIDE OF FLOOR	IWA, BSMT NE SIDE OF FLOOR	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	Other
Personal	- -				- -
Avg Flow	7.0	7.0	7.0	7.0	0.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On	01:28P	01:40P	01:42P	01:45P	
Time Off	05:28P	05:20P	05:32P	05:35P	
Tot Time	240 min	220 min	230 min	230 min	
Tot Vol	1680 ltr	1540 ltr	1610 ltr	1610 ltr	0000000000
AV Cnt Fibr Per Fld	.15	.11	.06	.10	BDL
Fibr Cnt Fibr Per CC	0.0044	0.0035	0.0018	0.0030	
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/29/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 54 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/30/01			
Sample	FV -1129-24	FV -1129-	FV -1129-	FV -1129-	FV -1129-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/29/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 55 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 11/30/01			
Sample	FV -1129-25	FV -1129-26	FV -1129-	FV -1129-	FV -1129-
Location	FIELD BLANK	FIELD BLANK			
Activity	Other	Other			
Personal	- -	- -			
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/29/01	11/29/01	11/29/01	11/29/01	11/29/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0	0	0
AV Cnt Fibr Per Fld	BDL	BDL			
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



11-30-01

PCM

12 AUE

AIRTEK ENVIRONMENTAL CORP	Date: 11/30/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 56 Code: FV
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:
Date Analyzed: 12/02/01		

Sample	FV -1130-01	FV -1130-02	FV -1130-03	FV -1130-04	FV -1130-05
Location	ADJ,CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA,1ST FL. WITHIN 15FT. 50 MURRAY ST ENTRANCE	OWA,1ST FLOOR 20FT. WEST 50 MURRAY ST. ENTRANCE	ADJ,CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA,1ST FLOOR 15FT. EAST 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -	- -			
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/30/01	11/30/01	11/30/01	11/30/01	11/30/01
Time On	07:13A	07:14A	07:15A	10:13A	10:14A
Time Off	10:13A	10:14A	10:15A	01:13P	01:14P
Tot Time	180 min	180 min	180 min	180 min	180 min
Tot Vol	1260 ltr	1260 ltr	1260 ltr	1260 ltr	1260 ltr
AV Cnt Fibr Per Fld	.04	.005	.005	.005	.01
Fibr Cnt Fibr Per CC	< 0.0021	< 0.0021	< 0.0021	< 0.0021	< 0.0021
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 11/30/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 57 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/02/01			
Sample	FV -1130-06	FV -1130-	FV -1130-	FV -1130-	FV -1130-
Location	OWA, 1ST FL. 20FT. WEST 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/30/01	11/30/01	11/30/01	11/30/01	11/30/01
Time On	10:15A				
Time Off	01:15P				
Tot Time	180 min				
Tot Vol	1260 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.005				
Fibr Cnt Fibr Per CC	< 0.0021				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 11/30/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 58 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/02/01		

Sample	FV -1130-07	FV -1130-08	FV -1130-09	FV -1130-10	FV -1130-11
Location	ADJ,CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 15FT. EAST 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 20FT. WEST 50 MURRAY ST ENTRANCE	OWA,BSMT. 5FT. FROM STAIRCASE	IWA,SUB BSMT RAMP AREA
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	11/30/01	11/30/01	11/30/01	11/30/01	11/30/01
Time On	01:13P	01:14P	01:15P	01:20P	01:23P
Time Off	05:13P	05:14P	05:15P	05:20P	05:23P
Tot Time	240 min	240 min	240 min	240 min	240 min
Tot Vol	1680 ltr	1680 ltr	1680 ltr	1680 ltr	1680 ltr
AV Cnt Fibr Per Fld	.065	.005	.01	.125	.035
Fibr Cnt Fibr Per CC	0.0019	< 0.0016	< 0.0016	0.0036	< 0.0016
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/30/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 59 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/02/01			
Sample	FV -1130-12	FV -1130-	FV -1130-	FV -1130-	FV -1130-
Location	IWA, SUB BSMT. NORTH CENTER SIDE OF ROOM				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	11/30/01	11/30/01	11/30/01	11/30/01	11/30/01
Time On	01:24P				
Time Off	05:24P				
Tot Time	240 min				
Tot Vol	1680 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.03				
Fibr Cnt Fibr Per CC	< 0.0016				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 11/30/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 60 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/02/01			
Sample	FV -1130-13	FV -1130-14	FV -1130-	FV -1130-	FV -1130-
Location	FIELD BLANK	FIELD BLANK			
Activity	Other	Other			
Personal	- -	- -			
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	11/30/01	11/30/01	11/30/01	11/30/01	11/30/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0	0	0
AV Cnt Fibr Per Fld	BDL	BDL			
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




12/4/01 PCM
17 < 3(+)
14(-)

AIRTEK ENVIRONMENTAL CORP	Date: 12/04/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 61 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/06/01		

Sample	FV -1204-01	FV -1204-02	FV -1204-03	FV -1204-04	FV -1204-05
Location	OWA, CLEAN ROOM PERSON. DECON 50 MURRAY ST. ENT	OWA, 1ST FLOOR WITHIN 15FT. EAST FROM 50 MURRAY STREET	OWA, 1ST FLOOR WITHIN 25FT. WEST FROM 50 MURRAY STREET	IWA, 21ST FL. SE SIDE OF THE FLOOR	IWA, 20TH FL. SW SIDE OF THE FLOOR
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	12/04/01	12/04/01	12/04/01	12/04/01	12/04/01
Time On	07:20A	07:21A	07:22A	07:40A	07:44A
Time Off	11:20A	11:21A	11:22A	11:40A	11:44A
Tot Time	240 min	240 min	240 min	240 min	240 min
Tot Vol	1680 ltr	1680 ltr	1680 ltr	1680 ltr	1680 ltr
AV Cnt Fibr Per Fld	.195	.005	.005	.34	.235
Fibr Cnt Fibr Per CC	0.0057	< 0.0016	< 0.0016	0.0099	0.0069
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/04/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 63 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/06/01		

Sample	FV -1204-07	FV -1204-08	FV -1204-09	FV -1204-10	FV -1204-11
Location	IWA, 22ND FL. NW SIDE OF THE FLOOR	IWA, 1ST FL. ADJ. TO ELEV. ENT. BANK (EAST)	OWA, CLEAN ROOM PERSON. DECON 50 MURRAY ST. ENT	OWA, 1ST FL. 15FT. EAST FROM 50 MURRAY ST.	OWA, 1ST FL. 25FT. WEST FROM 50 MURRAY ST.
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	7.0	7.0	5.0	5.0	5.0
Cal Date	12/04/01	12/04/01	12/04/01	12/04/01	12/04/01
Time On	07:51A	07:55A	11:20A	11:21A	11:22A
Time Off	11:51A	11:55A	05:20P	05:21P	05:02P
Tot Time	240 min	240 min	360 min	360 min	340 min
Tot Vol	1680 ltr	1680 ltr	1800 ltr	1800 ltr	1700 ltr
AV Cnt Fibr Per Fld	.02	.165	.205	.005	.005
Fibr Cnt Fibr Per CC	< 0.0016	0.0048	0.0056	< 0.0015	< 0.0016
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/04/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 64 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/06/01			
Sample	FV -1204-12	FV -1204-	FV -1204-	FV -1204-	FV -1204-
Location	IWA, 21ST FL. SE SIDE OF FLOOR				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/04/01	12/04/01	12/04/01	12/04/01	12/04/01
Time On	11:40A				
Time Off	05:10P				
Tot Time	330 min				
Tot Vol	1650 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.14				
Fibr Cnt Fibr Per CC	0.0042				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/04/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 65 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/06/01			
Sample	FV -1204-13	FV -1204-14	FV -1204-15	FV -1204-16	FV -1204-17
Location	IWA, 20TH FL. SW SIDE OF FLOOR	IWA, 19TH FL. SOUTH CENTER SIDE OF FLOOR	IWA, 22ND FL. NW SIDE OF THE FLOOR	IWA, 1ST FL. ADJ. TO ELEV. ENT. EAST ELEV. BANK	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	Other
Personal					- -
Avg Flow	5.0	5.0	5.0	5.0	0.0
Cal Date	12/04/01	12/04/01	12/04/01	12/04/01	12/04/01
Time On	11:44A	11:47A	11:51A	11:55A	
Time Off	05:14P	05:17P	05:11P	04:55P	
Tot Time	330 min	330 min	320 min	300 min	
Tot Vol	1650 ltr	1650 ltr	1600 ltr	1500 ltr	0000000000
AV Cnt Fibr Per Fld	.73	.58	.315	.255	BDL
Fibr Cnt Fibr Per CC	0.0217	0.0172	0.0097	0.0083	
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/04/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 66 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/06/01		

Sample	FV -1204-18	FV -1204-	FV -1204-	FV -1204-	FV -1204-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/04/01	12/04/01	12/04/01	12/04/01	12/04/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt					
Fibr					
Per Fld	BDL				
Fibr Cnt					
Fibr					
Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



12/3/01

11 < ALL (→) PCM

AIRTEK ENVIRONMENTAL CORP	Date: 12/03/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 68 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/06/01		

Sample	FV -1203-01	FV -1203-02	FV -1203-03	FV -1203-04	FV -1203-05
Location	OWA,CLEAN RM PERSON. DECON 50 MURRAY ST ENTRANCE	OWA,1ST FL. 15FT. EAST FROM 50 MURRAY STREET	OWA,1ST FL. 25FT. WEST FROM 50 MURRAY STREET	OWA,WASTE RM DECON. UNIT 50 MURRAY STREET ENT.	OWA,CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	12/03/01	12/03/01	12/03/01	12/03/01	12/03/01
Time On	07:05A	07:06A	07:07A	09:40A	10:25A
Time Off	10:25A	10:26A	10:27A	12:00P	01:55P
Tot Time	200 min	200 min	200 min	140 min	210 min
Tot Vol	1400 ltr	1400 ltr	1400 ltr	980 ltr	1470 ltr
AV Cnt Fibr Per Fld	.08	.005	.01	.14	.065
Fibr Cnt Fibr Per CC	0.0028	< 0.0019	< 0.0019	0.0070	0.0022
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/03/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 69 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/06/01			
Sample	FV -1203-06	FV -1203-	FV -1203-	FV -1203-	FV -1203-
Location	OWA, 1ST FLOOR 15FT. EAST FROM 50 MURRAY STREET				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	12/03/01	12/03/01	12/03/01	12/03/01	12/03/01
Time On	10:26A				
Time Off	01:56P				
Tot Time	210 min				
Tot Vol	1470 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.005				
Fibr Cnt Fibr Per CC	< 0.0018				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/03/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 70 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/06/01			
Sample	FV -1203-07	FV -1203-08	FV -1203-09	FV -1203-10	FV -1203-11
Location	OWA, 1ST FL. WITHIN 25FT. WEST FROM 50 MURRAY STREET	OWA, CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 15FT. EAST FROM 50 MURRAY ST	OWA, 1ST FL. 25FT. WEST FROM 50 MURRAY ST.	IWA, 2ND FL. WITHIN 10FT. FROM STAIRCASE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	12/03/01	12/03/01	12/03/01	12/03/01	12/03/01
Time On	10:27A	01:55P	01:56P	01:57P	02:00P
Time Off	01:57P	05:25P	05:16P	05:17P	05:00P
Tot Time	210 min	210 min	200 min	200 min	180 min
Tot Vol	1470 ltr	1470 ltr	1400 ltr	1400 ltr	1260 ltr
AV Cnt Fibr Per Fld	.005	.085	.005	.01	.07
Fibr Cnt Fibr Per CC	< 0.0018	0.0028	< 0.0019	< 0.0019	0.0027
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/03/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 71 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/06/01		

Sample	FV -1203-12	FV -1203-	FV -1203-	FV -1203-	FV -1203-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/03/01	12/03/01	12/03/01	12/03/01	12/03/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/03/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 72 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/06/01			
Sample	FV -1203-13	FV -1203-	FV -1203-	FV -1203-	FV -1203-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/03/01	12/03/01	12/03/01	12/03/01	12/03/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



12/5/01

20 < 3+ PCM
17Θ


NYC-WTC 000098213

AIRTEK ENVIRONMENTAL CORP	Date: 12/05/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 74 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT 110 CHURCH STREET State: Zip: Date Analyzed: 12/08/01		

Sample	FV -1205-06	FV -1205-	FV -1205-	FV -1205-	FV -1205-
Location	IWA, 17TH FL. SOUTH CENTER SIDE OF FLOOR				
Activity	PRE ABATEMENT				
Personal					
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	12/05/01	12/05/01	12/05/01	12/05/01	12/05/01
Time On	07:43A				
Time Off	11:43A				
Tot Time	240 min				
Tot Vol	1680 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.385				
Fibr Cnt Fibr Per CC	0.0112				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/05/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 75 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/08/01			
Sample	FV -1205-07	FV -1205-08	FV -1205-09	FV -1205-10	FV -1205-11
Location	IWA, 16TH FL. CENTER SIDE OF THE FLOOR	IWA, 15TH FL. CENTER SIDE OF THE FLOOR	ADJ. CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE	OWA, 15FT. EAST FROM 50 MURRAY ST. ENT. 11TH FL.	OWA, 25FT. WEST FROM 50 MURRAY ST. ENT. 1ST FL.
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal					
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	12/05/01	12/05/01	12/05/01	12/05/01	12/05/01
Time On	07:46A	07:49A	11:20A	11:21A	11:22A
Time Off	11:46A	11:49A	03:00P	03:01P	03:02P
Tot Time	240 min	240 min	220 min	220 min	220 min
Tot Vol	1680 ltr	1680 ltr	1540 ltr	1540 ltr	1540 ltr
AV Cnt Fibr Per Fld	.165	.375	.20	.005	.01
Fibr Cnt Fibr Per CC	0.0048	0.0109	0.0064	< 0.0018	< 0.0018
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/05/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 76 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/08/01			
Sample	FV -1205-12	FV -1205-	FV -1205-	FV -1205-	FV -1205-
Location	IWA, 1ST FL. ELEVATOR BANK ELEV. ENT. 1ST FLOOR				
Activity	PRE ABATEMENT				
Personal					
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	12/05/01	12/05/01	12/05/01	12/05/01	12/05/01
Time On	11:24A				
Time Off	03:24P				
Tot Time	240 min				
Tot Vol	1680 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.23				
Fibr Cnt Fibr Per CC	0.0067				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/05/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 77 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/08/01		

Sample	FV -1205-13	FV -1205-14	FV -1205-15	FV -1205-16	FV -1205-17
Location	IWA, 12TH FL. NORTH OF EAST ELEV. BANK	IWA, 13TH FL. SOUTH CENTER SIDE OF FLOOR	IWA, 14TH FL. ADJ. TO MAIN STAIRCASE ENTRANCE	IWA, 15TH FL. CENTER SIDE OF THE FLOOR	ADJ. CLEAN RM PERSON. DECON 50 MURRAY ST. ENTRANCE
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal					
Avg Flow	7.0	7.0	7.0	7.0	7.0
Cal Date	12/05/01	12/05/01	12/05/01	12/05/01	12/05/01
Time On	12:00P	12:04P	12:07P	12:10P	03:00P
Time Off	04:00P	04:04P	04:07P	04:10P	05:20P
Tot Time	240 min	240 min	240 min	240 min	140 min
Tot Vol	1680 ltr	1680 ltr	1680 ltr	1680 ltr	980 ltr
AV Cnt Fibr Per Fld	.165	.375	.17	.075	.03
Fibr Cnt Fibr Per CC	0.0048	0.0109	0.0050	0.0022	< 0.0028
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/05/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 78 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/08/01		

Sample	FV -1205-18	FV -1205-	FV -1205-	FV -1205-	FV -1205-
Location	OWA, 1ST FL. 15FT. EAST 50 MURRAY ST. ENTRANCE				
Activity	PRE ABATEMENT				
Personal					
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	12/05/01	12/05/01	12/05/01	12/05/01	12/05/01
Time On	03:01P				
Time Off	05:21P				
Tot Time	140 min				
Tot Vol	980 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.005				
Fibr Cnt Fibr Per CC	< 0.0028				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/05/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 79 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/08/01		

Sample	FV -1205-19	FV -1205-20	FV -1205-21	FV -1205-22	FV -1205-23
Location	OWA, 1ST FL. 25FT. WEST 50 MURRAY ST. ENTRANCE	IWA, 11TH FL. EAST ELEV. BANK	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	PRE ABATEMENT	PRE ABATEMENT	Other	Other	Other
Personal			- -	- -	- -
Avg Flow	7.0	7.0	0.0	0.0	0.0
Cal Date	12/05/01	12/05/01	12/05/01	12/05/01	12/05/01
Time On	03:02P	04:15P			
Time Off	05:22P	05:15P			
Tot Time	140 min	60 min			
Tot Vol	980 ltr	420 ltr	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.005	.045	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	< 0.0028	< 0.0064			
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK
ENVIRONMENTAL
CORP

Date: 12/05/01
AIR SAMPLING RESULTS

Proj Num: 01-1212

Page: 80

Code: FV

--Types of Project--

Address: LIONS HEAD

110 DEVELOPEMENT LLC

110 CHURCH STREET

State:

Zip:

Date Analyzed: 12/08/01

Sample	FV -1205-24	FV -1205-	FV -1205-	FV -1205-	FV -1205-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/05/01	12/05/01	12/05/01	12/05/01	12/05/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt					
Fibr					
Per Fld	BDL				
Fibr Cnt					
Fibr					
Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

12/6/01
31 < 8(+)
23(-) Pem

AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 81 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip: Date Analyzed: 12/16/01			
Sample	FV -1206-01	FV -1206-02	FV -1206-03	FV -1206-04	FV -1206-05
Location	OWA, CLEAN RM PERSON. DECON 50 MURRAY ST. ENT. 1ST FL.	OWA, 1ST FL. 15FT. EAST FROM MURRAY ST. ENTRANCE	OWA, 1ST FL. 20 FT. WEST 50 MURRAY ST. ENTRANCE	IWA, 1ST FL. WEST ELEVATOR BANK ADJ. TO ELEVATOR ENT.	IWA, 11TH FL. SOUTH CENTER SIDE OF THE FLOOR
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal	- -				
Avg Flow	6.0	6.0	6.0	6.0	6.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	07:04A	07:05A	07:06A	07:20A	07:45A
Time Off	11:44A	11:45A	11:46A	12:00P	11:45A
Tot Time	280 min	280 min	280 min	280 min	240 min
Tot Vol	1680 ltr	1680 ltr	1680 ltr	1680 ltr	1440 ltr
AV Cnt Fibr Per Fld	.07	.055	.04	.15	.21
Fibr Cnt Fibr Per CC	0.0020	0.0016	< 0.0016	0.0044	0.0072
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/06/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 82 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH STREET State: Zip:		
Date Analyzed: 12/16/01		

Sample	FV -1206-06	FV -1206-	FV -1206-	FV -1206-	FV -1206-
Location	IWA, 10TH FL. SE SIDE OF THE FLOOR				
Activity	PRE ABATEMENT				
Personal					
Avg Flow	6.0	0.0	0.0	0.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	07:48A				
Time Off	11:48A				
Tot Time	240 min				
Tot Vol	1440 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.10				
Fibr Cnt Fibr Per CC	0.0034				
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 83 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110-120 CHURCH STREET State: Zip: Date Analyzed: 12/16/01			
Sample	FV -1206-07	FV -1206-08	FV -1206-09	FV -1206-10	FV -1206-11
Location	IWA, 9TH FLOOR CENTER SIDE OF THE FLOOR	IWA, 8TH FLOOR SOUTH CENTER SIDE OF THE FLOOR	OWA, CLEAN RM PERSON. DECON 50 MURRAY ST. ENT. 1ST FL.	OWA, 1ST FL. 15FT. EAST 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 20FT. WEST 50 MURRAY ST. ENTRANCE
Activity	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT	PRE ABATEMENT
Personal					
Avg Flow	6.0	6.0	6.0	6.0	6.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	07:52A	07:56A	11:44A	11:45A	11:46A
Time Off	11:52A	11:56A	03:04P	03:05P	03:06P
Tot Time	240 min	240 min	200 min	200 min	200 min
Tot Vol	1440 ltr	1440 ltr	1200 ltr	1200 ltr	1200 ltr
AV Cnt Fibr Per Fld	.06	.11	.05	.04	.045
Fibr Cnt Fibr Per CC	0.0020	0.0037	< 0.0022	< 0.0022	< 0.0022
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 84 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110-120 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	FV -1206-12	FV -1206-	FV -1206-	FV -1206-	FV -1206-
Location	IWA, 1ST FLOOR WEST ELEVATOR BANK ADJ. TO ELEVATOR ENT.				
Activity	PRE ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	01:15P				
Time Off	05:17P				
Tot Time	242 min				
Tot Vol	1210 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.20				
Fibr Cnt Fibr Per CC	0.0081				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 12/06/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 85 Code: FV
--Types of Project--		Date Analyzed: 12/16/01
Address: LION HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		

Sample	FV -1206-13	FV -1206-14	FV -1206-15	FV -1206-16	FV -1206-17
Location	IWA, 8TH FLOOR STAIRWAY ENT. MAIN CORRIDOR	IWA, 7TH FLOOR STAIRWAY ENT. MAIN CORRIDOR	IWA, 6TH FLOOR STAIRWAY ENT. MAIN CORRIDOR	IWA, 5TH FLOOR STAIRWAY ENT. MAIN CORRIDOR	OWA, 50 MURRAY ST. ENT. 1ST FL. CLEAN RM PERSON. DECON
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	5.0	5.0	5.0	5.0	6.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	01:20P	01:25P	01:30P	01:35P	03:04P
Time Off	05:22P	05:28P	05:33P	05:39P	05:09P
Tot Time	242 min	243 min	243 min	244 min	125 min
Tot Vol	1210 ltr	1215 ltr	1215 ltr	1220 ltr	750 ltr
AV Cnt Fibr Per Fld	.30	.35	.27	.10	.05
Fibr Cnt Fibr Per CC	0.0122	0.0141	0.0109	0.0040	< 0.0036
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/06/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 86 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01		

Sample	FV -1206-18	FV -1206-	FV -1206-	FV -1206-	FV -1206-
Location	OWA, 1ST 15FT. EAST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	6.0	0.0	0.0	0.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	03:05P				
Time Off	05:10P				
Tot Time	125 min				
Tot Vol	750 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.04				
Fibr Cnt Fibr Per CC	< 0.0036				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 87 Code: FV	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	FV -1206-19	FV -1206-20	FV -1206-21	FV -1206-22	FV -1206-23
Location	OWA, 1ST FL. 20FT. WEST OF 50 MURRAY ST. ENTRANCE	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	DURING ABATEMENT	Other	Other	Other	Other
Personal		- -	- -	- -	- -
Avg Flow	6.0	0.0	0.0	0.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	03:06P				
Time Off	05:11P				
Tot Time	125 min				
Tot Vol	750 ltr	0000000000	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.05	BDL	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	< 0.0036				
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 183 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1206-01	TJ -1206-02	TJ -1206-03	TJ -1206-04	TJ -1206-05
Location	ADJ, 50 MURRAY ST. ENT. 1ST FL. CLEAN RM PERSON, DECON	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 25FT. WEST OF 50 MURRAY ST. ENTRANCE	IWA, 1ST FL. 20FT. FROM DECON ELEVATOR ENT.	IWA, 3RD FL. STAIRWAY ENT. MAIN CORRIDOR
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	07:15A	07:16A	07:19A	07:22A	07:28A
Time Off	10:20A	10:22A	10:25A	10:27A	10:33A
Tot Time	185 min	186 min	186 min	185 min	185 min
Tot Vol	925 ltr	930 ltr	930 ltr	925 ltr	925 ltr
AV Cnt Fibr Per Fld	.05	.03	.04	.25	.21
Fibr Cnt Fibr Per CC	< 0.0029	< 0.0029	< 0.0029	0.0133	0.0111
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 184 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1206-06	TJ -1206-	TJ -1206-	TJ -1206-	TJ -1206-
Location	IWA, 4TH FL. STAIRWAY ENT. MAIN CORRIDOR				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	07:36A				
Time Off	10:41A				
Tot Time	185 min				
Tot Vol	925 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.20				
Fibr Cnt Fibr Per CC	0.0106				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 185 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1206-07	TJ -1206-08	TJ -1206-09	TJ -1206-10	TJ -1206-11
Location	IWA, 5TH FL. STAIRWAY ENT. MAIN CORRIDOR	IWA, 2ND FL. CENTER	ADJ. 1ST FL. 50 MURRAY ST ENT. CLEAN RM PERSON. DECON	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 25FT. WEST OF MURRAY STREET ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	7.0	5.0	5.0	5.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	07:41A	09:58A	10:21A	10:24A	10:26A
Time Off	10:46A	12:02P	01:21P	01:25P	01:28P
Tot Time	185 min	124 min	180 min	181 min	182 min
Tot Vol	925 ltr	868 ltr	900 ltr	905 ltr	910 ltr
AV Cnt Fibr Per Fld	.07	.15	.145	.08	.06
Fibr Cnt Fibr Per CC	0.0037	0.0085	0.0079	0.0043	0.0032
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/06/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 186 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/16/01		

Sample	TJ -1206-12	TJ -1206-	TJ -1206-	TJ -1206-	TJ -1206-
Location	IWA,1ST FL. 20FT. FROM DECON ELEV. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	10:28A				
Time Off	01:30P				
Tot Time	182 min				
Tot Vol	910 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.17				
Fibr Cnt Fibr Per CC	0.0092				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 187 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1206-13	TJ -1206-14	TJ -1206-15	TJ -1206-16	TJ -1206-17
Location	IWA,3RD FL. STAIRWAY ENT. MAIN CORRIDOR	IWA,4TH FL. STAIRWAY ENT. MAIN CORRIDOR	IWA,5TH FL. STAIRWAY ENT. MAIN CORRIDOR	ADJ.1ST FL. 50 MURRAY ST. ENT. CLEAN RM PERSON. DECON	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	10:34A	10:42A	10:47A	01:22P	01:26P
Time Off	01:39P	01:48P	01:53P	04:24P	04:27P
Tot Time	185 min	186 min	186 min	182 min	181 min
Tot Vol	925 ltr	930 ltr	930 ltr	910 ltr	905 ltr
AV Cnt Fibr Per Fld	.41	.45	.10	.11	.07
Fibr Cnt Fibr Per CC	0.0217	0.0237	0.0053	0.0059	0.0038
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 188 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1206-18	TJ -1206-	TJ -1206-	TJ -1206-	TJ -1206-
Location	OWA, 1ST FL. 25FT. WEST 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	01:29P				
Time Off	04:28P				
Tot Time	179 min				
Tot Vol	895 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.08				
Fibr Cnt Fibr Per CC	0.0044				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 189 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1206-19	TJ -1206-20	TJ -1206-21	TJ -1206-22	TJ -1206-23
Location	IWA, 1ST FL. 20 FT. FROM DECON ELEV. ENTRANCE	IWA, 3RD FL. STAIRWAY ENT. MAIN CORRIDOR	IWA, 4TH FL. STAIRWAY ENT. MAIN CORRIDOR	IWA, 5TH FL. STAIRWAY ENT. MAIN CORRIDOR	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	Other
Personal	- -				- -
Avg Flow	5.0	5.0	5.0	5.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On	01:31P	01:40P	01:49P	01:54P	
Time Off	04:33P	04:42P	04:51P	04:55P	
Tot Time	182 min	182 min	182 min	181 min	
Tot Vol	910 ltr	910 ltr	910 ltr	905 ltr	0000000000
AV Cnt Fibr Per Fld	.20	.19	.43	.075	BDL
Fibr Cnt Fibr Per CC	0.0108	0.0102	0.0232	0.0041	
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/06/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 190 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1206-24	TJ -1206-25	TJ -1206-26	TJ -1206-	TJ -1206-
Location	FIELD BLANK	FIELD BLANK	FIELD BLANK		
Activity	Other	Other	Other		
Personal	- -	- -	- -		
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/06/01	12/06/01	12/06/01	12/06/01	12/06/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0000000000	0	0
AV Cnt Fibr Per Fld	BDL	BDL	BDL		
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

12/8/01 pcm
30 alc(-)

ATC Associates Inc.104 E. 25th St., 10th Floor, New York, NY 10010-2917
(212) 353-8280 Fax (212) 353-8306**Air Samples Phase Contrast Microscopy (PCM) Results**

Client Name : Airtex Environmental Corp.
 Client No. : 15495
 Project Name : EM&CA/Lions Head Develop.
 Project No. : 15495-3041
 Project Address: Lions Head Development
 110 Church Street, LLC

Page : 1
 ELAP No. : 10879
 NVLAP No. : 1187
 Microscope #: NYC0643
 Method : NIOSH 7400/A Rules
 Revision #3

Sample No.	Batch No.	Analyzed by	Sample Location			Type	Collect Date	Total Time	Flow Rate	Total Volume	Results
			Work Area	In/Out	Location						
01	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
02	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
03	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
04	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
05	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
06	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, N side	Final	12/08/01	120	15.00	1800	<0.003
07	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, N center side	Final	12/08/01	120	15.00	1800	<0.003
08	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, NW side	Final	12/08/01	120	15.00	1800	<0.003
09	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, SE side	Final	12/08/01	120	15.00	1800	<0.003
10	6817	DK	Basement, 1-2 fls, 22 fl	OSWA	2nd fl, S side	Final	12/08/01	120	15.00	1800	<0.003
11	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, D center side	Final	12/08/01	120	15.00	1800	<0.003
12	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, within 10' from E elevator	Final	12/08/01	120	15.00	1800	<0.003
13	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, E elevator bank	Final	12/08/01	120	15.00	1800	<0.003
14	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, W elevator bank	Final	12/08/01	120	15.00	1800	<0.003
15	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, W side of floor	Final	12/08/01	120	15.00	1800	<0.003
16	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, SE side of floor	Final	12/08/01	120	15.00	1800	<0.003
17	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, S center side	Final	12/08/01	120	15.00	1800	<0.003
18	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, E side	Final	12/08/01	120	15.00	1800	<0.003
19	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, E center side	Final	12/08/01	120	15.00	1800	<0.003
20	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, hoist motor room	Final	12/08/01	120	15.00	1800	<0.003
21	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, N side	Final	12/08/01	120	15.00	1800	<0.003
22	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, N center side	Final	12/08/01	120	15.00	1800	<0.003
23	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, NW side	Final	12/08/01	120	15.00	1800	<0.003
24	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, SE side	Final	12/08/01	120	15.00	1800	<0.003
25	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, S side	Final	12/08/01	120	15.00	1800	<0.003
26	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Basement, NW side	Final	12/08/01	120	15.00	1800	<0.003
27	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Basement, W side	Final	12/08/01	120	15.00	1800	<0.003
28	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Basement, W side	Final	12/08/01	120	15.00	1800	<0.003

LEGEND

- OSWA - Outside Work Area
- ISWA - Inside Work Area
- Min. - Time in Minutes
- c.c. - Cubic Centimeter
- L - Liters
- F - Fibers
- PEL - Permissible Exposure Limit

*Results are in actual Fibers/c.c. or as limit of quantitation whichever is higher.

Note - Action criteria for area samples is 0.01 fibers/c.c.
 - For personal samples, PEL(OSHA) is 0.1 fibers/c.c.


 Laboratory Director / Approved Signatory

ATC Associates Inc.

104 E. 25th St., 10th Floor, New York, NY 10010-2817
(212) 363-8280 Fax (212) 363-8306

Air Samples Phase Contrast Microscopy (PCM) Results

Client Name : Airtex Environmental Corp.
Client No. : 15495
Project Name : EMCA/Lions Head Develop.
Project No. : 15495-3041
Project Address: Lions Head Development
110 Church Street, LLC

Page : 2
ELAP No. : 10879
NVLAP No. : 1187
Microscope #: NYC0643
Method : NIOSH 7400 /A Rules
Revision # 3

Sample No.	Batch No.	Analyzed by	Sample Location		Type	Collect Date	Total Time Min.	Flow Rate L/min	Total Volume Liters	Results F/c.c.
			Work Area	In/Out						
23	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Final	12/08/01	120	15.00	1800	<0.003
30	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Final	12/08/01	120	15.00	1800	<0.003

LEGEND

- OSWA - Outside Work Area
- ISWA - Inside Work Area
- Bas. - Basements
- o.c. - Outside Contaminator
- L - Litter
- F - Fibers
- PCL - Permissible Exposure Limit

**Results are in actual Fibers/c.c. or as limit of quantitation whichever is higher.
Note - Action criteria for area samples is 0.01 fibers/c.c.
- For personal samples, PEL(OSHA) is 0.1 fibers/c.c.

Laboratory Director / Approved Signatory

ATC Associates Inc.

104 E 26th St., 10th Floor, New York, NY 10010-2817
(212) 363-8280 Fax (212) 363-8306

Air Samples Phase Contrast Microscopy (PCM) Results

Client Name : Airtek Environmental Corp.
Client No. : 15495
Project Name : EMCA/Lions Head Develop.
Project No. : 15495-3041
Project Address: Lions Head 110 Development LLC
110 Church Street

Page : 1
ELAP No. : 10879
NVLAP No. : 1187
Microscope #: NYC0643
Method : NIOSH 7400/A
Revision #3

Sample No.	Batch No.	Analyzed by	Sample Location		Type	Collect Date	Total Time Min.	Flow Rate L/Min.	Total Volume Liters	Results F/c.c.
			Work Area	In/Out						
31	6818	DK	110 Church St./various locations	ISWA	Basement, NE side	12/08/01	120	15.00	1800	<0.003
32	6818	DK	110 Church St./various locations	ISWA	Basement, E side	12/08/01	120	15.00	1800	<0.003
33	6818	DK	110 Church St./various locations	ISWA	Basement, SE side	12/08/01	120	15.00	1800	<0.003
34	6818	DK	110 Church St./various locations	ISWA	Basement, S side	12/08/01	120	15.00	1800	<0.003
35	6818	DK	110 Church St./various locations	ISWA	Basement, S side	12/08/01	120	15.00	1800	<0.003
36	6818	DK	110 Church St./various locations	ISWA	1st fl, stairway	12/08/01	120	15.00	1800	<0.003
37	6818	DK	110 Church St./various locations	ISWA	6th fl, stairway	12/08/01	120	15.00	1800	<0.003
38	6818	DK	110 Church St./various locations	ISWA	11th fl, stairway	12/08/01	120	15.00	1800	<0.003
39	6818	DK	110 Church St./various locations	ISWA	16th fl, stairway	12/08/01	120	15.00	1800	<0.003
40	6818	DK	110 Church St./various locations	ISWA	21st fl, stairway	12/08/01	120	15.00	1800	<0.003
41	6818	DK	110 Church St./various locations	ISWA	Sub-basement, S side	12/08/01	120	15.00	1800	<0.003
42	6818	DK	110 Church St./various locations	ISWA	Sub-basement, SE side	12/08/01	119	15.00	1785	<0.003
43	6818	DK	110 Church St./various locations	ISWA	Sub-basement, S center side	12/08/01	120	15.00	1800	<0.003
44	6818	DK	110 Church St./various locations	ISWA	Sub-basement, S side	12/08/01	120	15.00	1800	<0.003
45	6818	DK	110 Church St./various locations	ISWA	Sub-basement, SW side	12/08/01	120	15.00	1800	<0.003
46	6818	DK	110 Church St./various locations	ISWA	Sub-basement, W side	12/08/01	120	15.00	1800	<0.003
47	6818	DK	110 Church St./various locations	ISWA	Sub-basement, NW side	12/08/01	120	15.00	1800	<0.003
48	6818	DK	110 Church St./various locations	ISWA	Sub-basement, N side	12/08/01	120	15.00	1800	<0.003
49	6818	DK	110 Church St./various locations	ISWA	Sub-basement, NE side	12/08/01	120	15.00	1800	<0.003
50	6818	DK	110 Church St./various locations	ISWA	Sub-basement, NW corner	12/08/01	120	15.00	1800	<0.003
51	6818	DK	110 Church St./various locations	OSWA	Sub-basement, SE corner	12/08/01	120	15.00	1800	<0.003
52	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
53	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
54	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
55	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
56	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
57	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
58	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
59	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
60	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0
61	6818	DK	110 Church St./various locations	OSWA	Blank	12/08/01	0	0.00	0	0

LEGEND

- OSWA - Outside Work Area
- ISWA - Inside Work Area
- Min. - Time in Minutes
- C.C. - Cubic Centimeter
- L - Liters
- F - Flow
- PEL - Permissible Exposure Limit


**Results are in actual Fibers/c.c. or as limit of quantitation whichever is higher.
Note - Action levels for area samples is 0.01 fibers/c.c.
- For personal samples, PEL(OSHA) is 0.1 fibers/c.c.

Laboratory Director / Approved Signatory

12-10-01
20 $\left(\begin{array}{c} 13 \\ \hline 7 \end{array} \right) + 13$

AIRTEK ENVIRONMENTAL CORP		Date: 12/10/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 88 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/12/01			
Sample	TJ -1210-01	TJ -1210-02	TJ -1210-03	TJ -1210-04	TJ -1210-05
Location	OWA, 1ST FL. 5FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 15FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. INSIDE CLEAN ROOM OF PERSON. DECON	OWA, 1ST FL. 10FT. WEST OF ELEVATOR ENTRANCE	OWA, 22ND FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal		- -	- -	- -	- -
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/10/01	12/10/01	12/10/01	12/10/01	12/10/01
Time On	07:10A	07:11A	07:13A	07:16A	07:23A
Time Off	12:10P	12:12P	12:13P	12:15P	12:21P
Tot Time	300 min	301 min	300 min	299 min	298 min
Tot Vol	1500 ltr	1505 ltr	1500 ltr	1495 ltr	1490 ltr
AV Cnt Fibr Per Fld	.465	.615	.49	.02	.195
Fibr Cnt Fibr Per CC	0.0152	0.0200	0.0160	< 0.0018	0.0064
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature 

AIRTEK ENVIRONMENTAL CORP		Date: 12/10/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 89 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/12/01			
Sample	TJ -1210-06	TJ -1210-	TJ -1210-	TJ -1210-	TJ -1210-
Location	OWA, MAIN STAIRWAY 21ST FLOOR				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/10/01	12/10/01	12/10/01	12/10/01	12/10/01
Time On	07:27A				
Time Off	12:26P				
Tot Time	299 min				
Tot Vol	1495 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.05				
Fibr Cnt Fibr Per CC	< 0.0018				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/10/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 90 Code: TJ	
--Types of Project--		Address: LION'S HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/12/01			
Sample	TJ -1210-07	TJ -1210-08	TJ -1210-09	TJ -1210-10	TJ -1210-11
Location	OWA, 20TH FL. MAIN STAIRWAY	OWA, 19TH FL. MAIN STAIRWAY	IWA, 22ND FL. 15FT. WEST OF ELEVATOR ENTRANCE	IWA, 21ST FL. 15FT. WEST OF ELEVATOR ENTRANCE	IWA, 20TH FL. WEST SIDE OF MAIN CORRIDOR
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/10/01	12/10/01	12/10/01	12/10/01	12/10/01
Time On	07:30A	07:35A	06:52A	06:55A	06:59A
Time Off	12:31P	12:34P	11:52A	11:56A	11:59A
Tot Time	301 min	299 min	300 min	301 min	300 min
Tot Vol	1505 ltr	1495 ltr	1500 ltr	1505 ltr	1500 ltr
AV Cnt Fibr Per Fld	.16	.165	.50	.365	.52
Fibr Cnt Fibr Per CC	0.0052	0.0054	0.0163	0.0119	0.0170
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/10/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 91 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/12/01			
Sample	TJ -1210-12	TJ -1210-	TJ -1210-	TJ -1210-	TJ -1210-
Location	19TH FL: ELEVATOR ENTRANCE				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/10/01	12/10/01	12/10/01	12/10/01	12/10/01
Time On	07:03A				
Time Off	12:04P				
Tot Time	301 min				
Tot Vol	1505 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.665				
Fibr Cnt Fibr Per CC	0.0217				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK
ENVIRONMENTAL
CORP

Date: 12/10/01
AIR SAMPLING RESULTS

Proj Num: 01-1212

Page: 93

Code: TJ

--Types of Project--

Address: LIONS HEAD

110 DEVELOPEMENT LLC

110 CHURCH ST.

State:

Zip:

Date Analyzed: 12/12/01

Sample	TJ -1210-18	TJ -1210-	TJ -1210-	TJ -1210-	TJ -1210-
Location	OWA, 21ST FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/10/01	12/10/01	12/10/01	12/10/01	12/10/01
Time On	12:27P				
Time Off	04:57P				
Tot Time	270 min				
Tot Vol	1350 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.605				
Fibr Cnt Fibr Per CC	0.0220				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/10/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 94 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/12/01		

Sample	TJ -1210-19	TJ -1210-20	TJ -1210-21	TJ -1210-22	TJ -1210-23
Location	OWA, 20TH FL. MAIN STAIRWAY	OWA, 19TH FL. MAIN STAIRWAY	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	Other	Other	Other
Personal			- -	- -	- -
Avg Flow	5.0	5.0	0.0	0.0	0.0
Cal Date	12/10/01	12/10/01	12/10/01	12/10/01	12/10/01
Time On	12:32P	12:36P			
Time Off	05:02P	05:06P			
Tot Time	270 min	270 min			
Tot Vol	1350 ltr	1350 ltr	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.35	.17	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	0.0127	0.0062			
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/10/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 95 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/12/01		

Sample	TJ -1210-24	TJ -1210-	TJ -1210-	TJ -1210-	TJ -1210-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/10/01	12/10/01	12/10/01	12/10/01	12/10/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt					
Fibr					
Per Fld	BDL				
Fibr Cnt					
Fibr					
Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




12-11-01 PCM

26 -6 (4)
200 →

AIRTEK ENVIRONMENTAL CORP		Date: 12/11/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 96 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1211-01	TJ -1211-02	TJ -1211-03	TJ -1211-04	TJ -1211-05
Location	ADJ, 1ST FL. 50 MURRAY ST. ENTRANCE	OWA, 1ST 10FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. CLEAN RM INSIDE PERSON DECON	OWA, 1ST FL. 15FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On	05:01A	05:02A	05:03A	05:04A	07:52A
Time Off	07:51A	07:53A	07:56A	07:59A	11:52A
Tot Time	170 min	171 min	173 min	175 min	240 min
Tot Vol	850 ltr	855 ltr	865 ltr	875 ltr	1200 ltr
AV Cnt Fibr Per Fld	.505	.49	1.01	.25	.30
Fibr Cnt Fibr Per CC	0.0291	0.0281	0.0573	0.0140	0.0123
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/11/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 97 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1211-06	TJ -1211-	TJ -1211-	TJ -1211-	TJ -1211-
Location	OWA, 1ST FL. 10FT. WEST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On	07:54A				
Time Off	11:54A				
Tot Time	240 min				
Tot Vol	1200 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.24				
Fibr Cnt Fibr Per CC	0.0098				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/11/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 98 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01		

Sample	TJ -1211-07	TJ -1211-08	TJ -1211-09	TJ -1211-10	TJ -1211-11
Location	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 15FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA,21ST FL. MAIN STAIRWAY	OWA,20TH FL. MAIN STAIRWAY	OWA,19TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				- -
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On	07:57A	08:01A	08:05A	08:10A	08:12A
Time Off	11:56A	12:02P	12:06P	12:10P	12:13P
Tot Time	239 min	241 min	241 min	240 min	241 min
Tot Vol	1195 ltr	1205 ltr	1205 ltr	1200 ltr	1205 ltr
AV Cnt Fibr Per Fld	.29	.20	.21	.195	.20
Fibr Cnt Fibr Per CC	0.0119	0.0081	0.0085	0.0080	0.0081
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/11/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 99 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1211-12	TJ -1211-	TJ -1211-	TJ -1211-	TJ -1211-
Location	OWA, 18TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On	08:15A				
Time Off	12:16P				
Tot Time	241 min				
Tot Vol	1205 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.19				
Fibr Cnt Fibr Per CC	0.0077				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/11/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 100 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1211-13	TJ -1211-14	TJ -1211-15	TJ -1211-16	TJ -1211-17
Location	OWA,17TH FL. MAIN STAIRWAY	OWA,16TH FL. MAIN STAIRWAY	OWA,15TH FL. MAIN STAIRWAY	ADJ,1ST FL. 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 10FT. WEST OF 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On	08:17A	08:20A	08:24A	11:53A	11:55A
Time Off	12:18P	12:20P	12:25P	04:43P	04:45P
Tot Time	241 min	240 min	241 min	290 min	290 min
Tot Vol	1205 ltr	1200 ltr	1205 ltr	1450 ltr	1450 ltr
AV Cnt Fibr Per Fld	.175	.18	.17	.23	.25
Fibr Cnt Fibr Per CC	0.0071	0.0074	0.0069	0.0078	0.0085
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/11/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 101 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1211-18	TJ -1211-	TJ -1211-	TJ -1211-	TJ -1211-
Location	OWA, 1ST FL. CLEAN RM PERSON. DECON				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On	11:57A				
Time Off	04:50P				
Tot Time	293 min				
Tot Vol	1465 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.26				
Fibr Cnt Fibr Per CC	0.0087				
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/11/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 102 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1211-19	TJ -1211-20	TJ -1211-21	TJ -1211-22	TJ -1211-23
Location	OWA, 1ST FL. 15FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA, 21ST FL. MAIN STAIRWAY	OWA, 20TH FL. MAIN STAIRWAY	OWA, 19TH FL. MAIN STAIRWAY	OWA, 18TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On	12:03P	12:07P	12:11P	12:14P	12:17P
Time Off	04:53P	04:56P	04:59P	05:07P	05:11P
Tot Time	290 min	289 min	288 min	293 min	294 min
Tot Vol	1450 ltr	1445 ltr	1440 ltr	1465 ltr	1470 ltr
AV Cnt Fibr Per Fld	.22	.21	.205	.15	.23
Fibr Cnt Fibr Per CC	0.0074	0.0071	0.0070	0.0050	0.0077
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




Authorized Signature

NYC-WTC_000098258

AIRTEK ENVIRONMENTAL CORP		Date: 12/11/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 104 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1211-25	TJ -1211-26	TJ -1211-27	TJ -1211-28	TJ -1211-29
Location	OWA, 16TH FL. MAIN STAIRWAY	OWA, 15TH FL. MAIN STAIRWAY	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	Other	Other	Other
Personal	- -		- -	- -	- -
Avg Flow	5.0	5.0	0.0	0.0	0.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On	12:21P	12:26P			
Time Off	05:23P	05:29P			
Tot Time	302 min	303 min			
Tot Vol	1510 ltr	1515 ltr	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.30	.31	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	0.0097	0.0100			
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/11/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 105 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1211-30	TJ -1211-	TJ -1211-	TJ -1211-	TJ -1211-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 12/11/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 106 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01		

Sample	TJ -1211-31	TJ -1211-32	TJ -1211-	TJ -1211-	TJ -1211-
Location	FIELD BLANK	FIELD BLANK			
Activity	Other	Other			
Personal	- -	- -			
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/11/01	12/11/01	12/11/01	12/11/01	12/11/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0	0	0
AV-Cnt Fibr Per Fld	BDL	BDL			
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature


12-12-01

245 11 (+)
13 (-)

AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 107 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-01	TJ -1212-02	TJ -1212-03	TJ -1212-04	TJ -1212-05
Location	OWA,1ST FL. 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 5FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 15FT. FROM WASTE DECON	OWA,1ST FL. 20FT. WEST OF 50 MURRAY ST. ENTRANCE	ADJ,1ST FL. 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -	- -			
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On	04:26P	04:29P	04:31P	04:33P	07:39P
Time Off	07:38P	07:40P	07:42P	07:45P	11:45P
Tot Time	192 min	191 min	191 min	192 min	246 min
Tot Vol	960 ltr	955 ltr	955 ltr	960 ltr	1230 ltr
AV Cnt Fibr Per Fld	.205	.15	.30	.19	.31
Fibr Cnt Fibr Per CC	0.0105	0.0077	0.0154	0.0097	0.0124
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 108 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-06	TJ -1212-	TJ -1212-	TJ -1212-	TJ -1212-
Location	OWA, 1ST FL. 5FT. EAST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On	07:41P				
Time Off	11:47P				
Tot Time	246 min				
Tot Vol	1230 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.18				
Fibr Cnt Fibr Per CC	0.0072				
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 109 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-07	TJ -1212-08	TJ -1212-09	TJ -1212-10	TJ -1212-11
Location	OWA, 1ST FL. 15FT. FROM WASTE DECON	OWA, 1ST FL. 20FT. WEST OF 50 MURRAY ST.	OWA, 16TH FL. MAIN STAIRWAY	OWA, 15TH FL. MAIN STAIRWAY	OWA, 14TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On	07:43P	07:46P	08:01P	08:04P	08:06P
Time Off	11:50P	11:53P	12:17A	12:19A	12:23A
Tot Time	247 min	247 min	256 min	255 min	257 min
Tot Vol	1235 ltr	1235 ltr	1280 ltr	1275 ltr	1285 ltr
AV Cnt Fibr Per Fld	.40	.25	.505	.45	.06
Fibr Cnt Fibr Per CC	0.0159	0.0099	0.0193	0.0173	0.0023
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 110 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-12	TJ -1212-	TJ -1212-	TJ -1212-	TJ -1212-
Location	OWA, 13TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On	08:09P				
Time Off	12:26A				
Tot Time	257 min				
Tot Vol	1285 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.47				
Fibr Cnt Fibr Per CC	0.0179				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 111 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-13	TJ -1212-14	TJ -1212-15	TJ -1212-16	TJ -1212-17
Location	OWA,12TH FL. MAIN STAIRWAY	OWA,11TH FL. MAIN STAIRWAY	ADJ,1ST FL. 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 5FT. EAST OF 50 MURRAY ST.	OWA,1ST FL. 15FT. FROM WASTE DECON
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On	08:12P	08:15P	11:46P	11:48P	11:51P
Time Off	12:30A	12:32A	04:15A	04:18A	04:21A
Tot Time	258 min	257 min	269 min	270 min	270 min
Tot Vol	1290 ltr	1285 ltr	1345 ltr	1350 ltr	1350 ltr
AV Cnt Fibr Per Fld	.21	.10	.22	.25	.20
Fibr Cnt Fibr Per CC	0.0080	0.0038	0.0080	0.0091	0.0073
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 112 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-18	TJ -1212-	TJ -1212-	TJ -1212-	TJ -1212-
Location	OWA, 1ST FL. 20FT. WEST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On	11:54P				
Time Off	04:24A				
Tot Time	270 min				
Tot Vol	1350 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.19				
Fibr Cnt Fibr Per CC	0.0069				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 113 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-19	TJ -1212-20	TJ -1212-21	TJ -1212-22	TJ -1212-23
Location	OWA,16TH FL. MAIN STAIRWAY	OWA,15TH FL. MAIN STAIRWAY	OWA,14TH FL. MAIN STAIRWAY	OWA,13TH FL. MAIN STAIRWAY	OWA,12TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On	12:18P	12:20P	12:24P	12:27P	12:31P
Time Off	04:46A	04:48A	04:53A	04:55A	04:58A
Tot Time	268 min	268 min	269 min	268 min	267 min
Tot Vol	1340 ltr	1340 ltr	1345 ltr	1340 ltr	1335 ltr
AV Cnt Fibr Per Fld	.055	.18	.50	.51	.49
Fibr Cnt Fibr Per CC	0.0020	0.0066	0.0182	0.0187	0.0180
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 114 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-24	TJ -1212-	TJ -1212-	TJ -1212-	TJ -1212-
Location	OWA, 11TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On	12:33P				
Time Off	05:01A				
Tot Time	268 min				
Tot Vol	1340 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.40				
Fibr Cnt Fibr Per CC	0.0146				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/12/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 115 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1212-25	TJ -1212-26	TJ -1212-27	TJ -1212-28	TJ -1212-29
Location	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	Other	Other	Other	Other	Other
Personal	- -	- -	- -	- -	- -
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/12/01	12/12/01	12/12/01	12/12/01	12/12/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	BDL	BDL	BDL	BDL	BDL
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



12-13-01
25 < 6(+)
19(-)

AIRTEK ENVIRONMENTAL CORP		Date: 12/13/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 116 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1213-01	TJ -1213-02	TJ -1213-03	TJ -1213-04	TJ -1213-05
Location	ADJ, 1ST FL. 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 10FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. INSIDE CLEAN ROOM/ PERSON. DECON	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -	- -	- -	- -	- -
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/13/01	12/13/01	12/13/01	12/13/01	12/13/01
Time On	04:15A	04:17A	04:20A	04:22A	07:38A
Time Off	07:37A	07:39A	07:41A	07:43A	12:40P
Tot Time	202 min	202 min	201 min	201 min	302 min
Tot Vol	1010 ltr	1010 ltr	1005 ltr	1005 ltr	1510 ltr
AV Cnt Fibr Per Fld	.26	.29	.22	.21	.35
Fibr Cnt Fibr Per CC	0.0126	0.0141	0.0107	0.0102	0.0114
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/13/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 117 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1213-06	TJ -1213-	TJ -1213-	TJ -1213-	TJ -1213-
Location	ADJ, 1ST FL. 10FT. WEST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/13/01	12/13/01	12/13/01	12/13/01	12/13/01
Time On	07:40A				
Time Off	12:42P				
Tot Time	302 min				
Tot Vol	1510 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.30				
Fibr Cnt Fibr Per CC	0.0097				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

NYC-WTC_000098275

AIRTEK ENVIRONMENTAL CORP	Date: 12/13/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 119 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01		

Sample	TJ -1213-12	TJ -1213-	TJ -1213-	TJ -1213-	TJ -1213-
Location	ADJ,1ST FL. 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/13/01	12/13/01	12/13/01	12/13/01	12/13/01
Time On	12:41P				
Time Off	01:52P				
Tot Time	71 min				
Tot Vol	355 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.06				
Fibr Cnt Fibr Per CC	0.0083				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/13/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 120 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/16/01		

Sample	TJ -1213-13	TJ -1213-14	TJ -1213-15	TJ -1213-16	TJ -1213-17
Location	OWA,1ST FL. 10FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,11TH FL. MAIN STAIRWAY	OWA,10TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/13/01	12/13/01	12/13/01	12/13/01	12/13/01
Time On	12:43P	12:48P	12:50P	02:31P	02:29P
Time Off	01:54P	01:56P	01:58P	05:09P	05:07P
Tot Time	71 min	68 min	68 min	158 min	158 min
Tot Vol	355 ltr	340 ltr	340 ltr	790 ltr	790 ltr
AV Cnt Fibr Per Fld	.07	.055	.06	.15	.14
Fibr Cnt Fibr Per CC	0.0097	0.0079	0.0087	0.0093	0.0087
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/13/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 121 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/16/01		

Sample	TJ -1213-18	TJ -1213-	TJ -1213-	TJ -1213-	TJ -1213-
Location	OWA, 9TH FLOOR MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/13/01	12/13/01	12/13/01	12/13/01	12/13/01
Time On	02:25P				
Time Off	05:06P				
Tot Time	161 min				
Tot Vol	805 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.10				
Fibr Cnt Fibr Per CC	0.0061				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/13/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 122 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1213-19	TJ -1213-20	TJ -1213-21	TJ -1213-22	TJ -1213-23
Location	ADJ, 1ST FL. 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 10FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. CLEAN RM PERSON. DECON	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. STAIRWAY ENT. TO BASEMENT
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	7.0
Cal Date	12/13/01	12/13/01	12/13/01	12/13/01	12/13/01
Time On	01:53P	01:55P	01:57P	01:59P	02:39P
Time Off	04:50P	04:53P	04:55P	04:58P	05:19P
Tot Time	177 min	178 min	178 min	179 min	160 min
Tot Vol	885 ltr	890 ltr	890 ltr	895 ltr	1120 ltr
AV Cnt Fibr Per Fld	.11	.095	.08	.09	.07
Fibr Cnt Fibr Per CC	0.0061	0.0052	0.0044	0.0049	0.0031
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/13/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 123 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1213-24	TJ -1213-	TJ -1213-	TJ -1213-	TJ -1213-
Location	OWA, MAIN STAIRWAY BTWN BASEMENT & 1ST FL.				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	12/13/01	12/13/01	12/13/01	12/13/01	12/13/01
Time On	02:47P				
Time Off	05:23P				
Tot Time	156 min				
Tot Vol	1092 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.055				
Fibr Cnt Fibr Per CC	0.0025				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/13/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 124 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1213-25	TJ -1213-26	TJ -1213-27	TJ -1213-28	TJ -1213-29
Location	OWA, BASEMENT STAIRWAY ENTRANCE TO 1FT FLOOR	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	DURING ABATEMENT	Other	Other	Other	Other
Personal		- -	- -	- -	- -
Avg Flow	7.0	0.0	0.0	0.0	0.0
Cal Date	12/13/01	12/13/01	12/13/01	12/13/01	12/13/01
Time On	02:52P				
Time Off	05:28P				
Tot Time	156 min				
Tot Vol	1092 ltr	0000000000	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.06	BDL	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	0.0027				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

12-14-01
28< 14(+)
14(-)

AIRTEK ENVIRONMENTAL CORP		Date: 12/14/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 126 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1214-01	TJ -1214-02	TJ -1214-03	TJ -1214-04	TJ -1214-05
Location	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. INSIDE WASTE DECON	OWA,1ST FL. 30FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. CLEAN RM PERSON. DECON
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On	04:00P	04:01P	04:02P	04:03P	07:20P
Time Off	06:30P	06:31P	06:32P	06:33P	10:07P
Tot Time	150 min	150 min	150 min	150 min	167 min
Tot Vol	750 ltr	750 ltr	750 ltr	750 ltr	835 ltr
AV Cnt Fibr Per Fld	.10	.15	.07	.08	.20
Fibr Cnt Fibr Per CC	0.0065	0.0098	0.0046	0.0052	0.0117
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/14/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 127 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01		

Sample	TJ -1214-06	TJ -1214-	TJ -1214-	TJ -1214-	TJ -1214-
Location	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On	07:22P				
Time Off	10:10P				
Tot Time	168 min				
Tot Vol	840 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.21				
Fibr Cnt Fibr Per CC	0.0123				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 12/14/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 128 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01		

Sample	TJ -1214-07	TJ -1214-08	TJ -1214-09	TJ -1214-10	TJ -1214-11
Location	OWA,1ST FL. 20FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 30FT. WEST OF ELEVATOR	OWA,10TH FL. MAIN STAIRWAY	OWA,9TH FL. MAIN STAIRWAY	OWA,8TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On	07:24P	07:26P	07:43P	07:47P	07:50P
Time Off	10:12P	10:14P	10:33P	10:37P	10:40P
Tot Time	168 min	168 min	170 min	170 min	170 min
Tot Vol	840 ltr	840 ltr	850 ltr	850 ltr	850 ltr
AV Cnt Fibr Per Fld	.31	.35	.03	.10	.15
Fibr Cnt Fibr Per CC	0.0181	0.0204	< 0.0032	0.0058	0.0087
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/14/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 129 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01		

Sample	TJ -1214-12	TJ -1214-	TJ -1214-	TJ -1214-	TJ -1214-
Location	OWA, 7TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On	07:54P				
Time Off	10:44P				
Tot Time	170 min				
Tot Vol	850 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.30				
Fibr Cnt Fibr Per CC	0.0173				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/14/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 130 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01		

Sample	TJ -1214-13	TJ -1214-14	TJ -1214-15	TJ -1214-16	TJ -1214-17
Location	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 20FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 30FT. WEST OF ELEVATOR	OWA,10TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On	10:08P	10:11P	10:13P	10:17P	10:34P
Time Off	01:23A	01:25A	01:27A	01:30A	01:43A
Tot Time	195 min	194 min	194 min	193 min	189 min
Tot Vol	975 ltr	970 ltr	970 ltr	965 ltr	945 ltr
AV Cnt Fibr Per Fld	.19	.20	.195	.185	.04
Fibr Cnt Fibr Per CC	0.0096	0.0101	0.0099	0.0094	< 0.0029
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/14/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 131 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/16/01		

Sample	TJ -1214-18	TJ -1214-	TJ -1214-	TJ -1214-	TJ -1214-
Location	OWA, 9TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On	10:38P				
Time Off	01:46A				
Tot Time	188 min				
Tot Vol	940 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.055				
Fibr Cnt Fibr Per CC	0.0029				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/14/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 133 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1214-24	TJ -1214-	TJ -1214-	TJ -1214-	TJ -1214-
Location	OWA, 1ST FL. 30FT. WEST OF ELEVATOR				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On	01:31A				
Time Off	04:55A				
Tot Time	204 min				
Tot Vol	1020 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.24				
Fibr Cnt Fibr Per CC	0.0115				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/14/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 134 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1214-25	TJ -1214-26	TJ -1214-27	TJ -1214-28	TJ -1214-29
Location	OWA, 10TH FL. MAIN STAIRWAY	OWA, 9TH FL. MAIN STAIRWAY	OWA, 8TH FL. MAIN STAIRWAY	OWA, 7TH FL. MAIN STAIRWAY	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	Other
Personal					- -
Avg Flow	5.0	5.0	5.0	5.0	0.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On	01:44A	01:47A	01:50A	01:53A	
Time Off	05:06A	05:08A	05:10A	05:13A	
Tot Time	202 min	201 min	200 min	200 min	
Tot Vol	1010 ltr	1005 ltr	1000 ltr	1000 ltr	0000000000
AV Cnt Fibr Per Fld	.25	.04	.10	.21	BDL
Fibr Cnt Fibr Per CC	0.0121	< 0.0027	0.0049	0.0103	
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/14/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 135 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/16/01			
Sample	TJ -1214-30	TJ -1214-	TJ -1214-	TJ -1214-	TJ -1214-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/14/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 136 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/16/01		

Sample	TJ -1214-31	TJ -1214-32	TJ -1214-33	TJ -1214-	TJ -1214-
Location	FIELD BLANK	FIELD BLANK	FIELD BLANK		
Activity	Other	Other	Other		
Personal	- -	- -	- -		
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/14/01	12/14/01	12/14/01	12/14/01	12/14/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0000000000	0	0
AV Cnt					
Fibr					
Per Fld	BDL	BDL	BDL		
Fibr Cnt					
Fibr					
Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



12-17-01
28 < 14 (+)
14 (-)

AIRTEK ENVIRONMENTAL CORP		Date: 12/17/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 137 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01			
Sample	TJ -1217-01	TJ -1217-02	TJ -1217-03	TJ -1217-04	TJ -1217-05
Location	ADJ,1ST FL. 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 30FT. WEST OF 50 MURRAY ST.	ADJ,1ST FL. 50 MURRAY ST.
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -	- -	- -		
Avg Flow	6.0	6.0	6.0	6.0	5.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	04:32A	04:33A	04:35A	04:37A	07:21A
Time Off	06:15A	06:17A	06:18A	06:20A	10:26A
Tot Time	103 min	104 min	103 min	103 min	185 min
Tot Vol	618 ltr	624 ltr	618 ltr	618 ltr	925 ltr
AV Cnt Fibr Per Fld	.345	.235	.165	.085	.225
Fibr Cnt Fibr Per CC	0.0274	0.0185	0.0131	0.0067	0.0119
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/17/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 138 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01			
Sample	TJ -1217-06	TJ -1217-	TJ -1217-	TJ -1217-	TJ -1217-
Location	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	07:22A				
Time Off	10:27A				
Tot Time	185 min				
Tot Vol	925 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.215				
Fibr Cnt Fibr Per CC	0.0114				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/17/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 139 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01			
Sample	TJ -1217-07	TJ -1217-08	TJ -1217-09	TJ -1217-10	TJ -1217-11
Location	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 30FT. WEST OF 50 MURRAY ST.	OWA,10TH FL. MAIN STAIRWAY	OWA,9TH FL. MAIN STAIRWAY	OWA,8TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	07:23A	07:25A	07:38A	07:41A	07:42A
Time Off	10:29A	10:30A	10:43A	10:46A	10:49A
Tot Time	186 min	185 min	185 min	185 min	187 min
Tot Vol	930 ltr	925 ltr	925 ltr	925 ltr	935 ltr
AV Cnt Fibr Per Fld	.165	.18	.51	.005	.225
Fibr Cnt Fibr Per CC	0.0087	0.0095	0.0270	< 0.0029	0.0118
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/17/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 140 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01		

Sample	TJ -1217-12	TJ -1217-	TJ -1217-	TJ -1217-	TJ -1217-
Location	OWA, 7TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	07:46A				
Time Off	10:53A				
Tot Time	187 min				
Tot Vol	935 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.13				
Fibr Cnt Fibr Per CC	0.0068				
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/17/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 141 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01			
Sample	TJ -1217-13	TJ -1217-14	TJ -1217-15	TJ -1217-16	TJ -1217-17
Location	ADJ, 1ST FL. 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. CLEAN RM PERSON. DECON	OWA, 1ST FL. 30FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA, 10TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	10:32A	10:33A	10:34A	10:36A	10:44A
Time Off	01:23P	01:26P	01:28P	01:30P	01:41P
Tot Time	171 min	173 min	174 min	174 min	177 min
Tot Vol	855 ltr	865 ltr	870 ltr	870 ltr	885 ltr
AV Cnt Fibr Per Fld	.14	.12	.475	.29	.195
Fibr Cnt Fibr Per CC	0.0080	0.0068	0.0268	0.0163	0.0108
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature 

AIRTEK ENVIRONMENTAL CORP	Date: 12/17/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 142 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01		

Sample	TJ -1217-18	TJ -1217-	TJ -1217-	TJ -1217-	TJ -1217-
Location	OWA, 9TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	10:47A				
Time Off	01:43P				
Tot Time	176 min				
Tot Vol	880 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.005				
Fibr Cnt Fibr Per CC	< 0.0031				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/17/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 143 Code: TJ
--Types of Project--		Date Analyzed: 12/21/01
Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		

Sample	TJ -1217-19	TJ -1217-20	TJ -1217-21	TJ -1217-22	TJ -1217-23
Location	OWA, 8TH FL. MAIN STAIRWAY	OWA, 7TH FL. MAIN STAIRWAY	ADJ, 1ST FL. 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. CLEAN ROOM OF PERSONAL DECON
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	10:50A	10:55A	01:24P	01:27P	01:29P
Time Off	01:46P	01:49P	04:39P	04:41P	04:42P
Tot Time	176 min	174 min	195 min	194 min	193 min
Tot Vol	880 ltr	870 ltr	975 ltr	970 ltr	965 ltr
AV Cnt Fibr Per Fld	.18	.005	.155	.235	.19
Fibr Cnt Fibr Per CC	0.0100	< 0.0031	0.0078	0.0119	0.0097
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/17/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 144 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01			
Sample	TJ -1217-24	TJ -1217-	TJ -1217-	TJ -1217-	TJ -1217-
Location	OWA, 1ST FL. 30FT. WEST OF 50 MURRAY ST				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	01:32P				
Time Off	04:44P				
Tot Time	192 min				
Tot Vol	960 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.125				
Fibr Cnt Fibr Per CC	0.0064				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/17/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 145 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01			
Sample	TJ -1217-25	TJ -1217-26	TJ -1217-27	TJ -1217-28	TJ -1217-29
Location	OWA,10TH FL. MAIN STAIRWAY	OWA,9TH FL. MAIN STAIRWAY	OWA,8TH FL. MAIN STAIRWAY	OWA,7TH FL. MAIN STAIRWAY	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	Other
Personal	- -				- -
Avg Flow	5.0	5.0	5.0	5.0	0.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On	01:42P	01:44P	01:47P	01:50P	
Time Off	04:53P	04:55P	04:58P	05:01P	
Tot Time	191 min	191 min	191 min	191 min	
Tot Vol	955 ltr	955 ltr	955 ltr	955 ltr	0000000000
AV Cnt Fibr Per Fld	.45	.005	.425	.01	BDL
Fibr Cnt Fibr Per CC	0.0231	< 0.0028	0.0218	< 0.0028	
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/17/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 146 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:			
Date Analyzed: 12/21/01					

Sample	TJ -1217-30	TJ -1217-	TJ -1217-	TJ -1217-	TJ -1217-
Location	FIELD BLANK				
Activity	Other				
Personal	- - -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt					
Fibr					
Per Fld	BDL				
Fibr Cnt					
Fibr					
Per CC					
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/17/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 147 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/21/01			
Sample	TJ -1217-31	TJ -1217-32	TJ -1217-33	TJ -1217-	TJ -1217-
Location	FIELD BLANK	FIELD BLANK	FIELD BLANK		
Activity	Other	Other	Other		
Personal	- -	- -	- -		
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/17/01	12/17/01	12/17/01	12/17/01	12/17/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0000000000	0000000000	0	0
AV Cnt Fibr Per Fld	BDL	BDL	BDL		
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature 

12-18-01
31 < 20 (+)
11 (-)

AIRTEK ENVIRONMENTAL CORP	Date: 12/18/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 148 Code: FV
--Types of Project--		Date Analyzed: 12/22/01
Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		

Sample	FV -1218-01	FV -1218-02	FV -1218-03	FV -1218-04	FV -1218-05
Location	OWA,CLEAN RM PERSON. DECON 1ST FL. 50 MURRAY ST.ENT	OWA,WASTE RM 1ST FL. 50 MURRAY ST. ENTRANCE	OWA,1ST FL. WITHIN 20FT. WEST FROM 50 MURRAY ST.ENT	OWA,1ST FL. WITHIN 15FT. EAST FROM 50 MURRAY ST.ENT	ADJ.1ST FL. 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -	- -	- -		
Avg Flow	9.0	10.0	10.0	10.0	5.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	04:20P	04:22P	04:24P	04:26P	07:27P
Time Off	07:00P	06:32P	06:34P	06:36P	10:24P
Tot Time	160 min	130 min	130 min	130 min	177 min
Tot Vol	1440 ltr	1300 ltr	1300 ltr	1300 ltr	885 ltr
AV Cnt Fibr Per Fld	.005	.015	.03	.005	.16
Fibr Cnt Fibr Per CC	< 0.0019	< 0.0021	< 0.0021	< 0.0021	0.0089
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/18/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 149 Code: FV
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/22/01		

Sample	FV -1218-06	FV -1218-	FV -1218-	FV -1218-	FV -1218-
Location	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	07:29P				
Time Off	10:26P				
Tot Time	177 min				
Tot Vol	885 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.015				
Fibr Cnt Fibr Per CC	< 0.0030				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/18/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 150 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1218-07	TJ -1218-08	TJ -1218-09	TJ -1218-10	TJ -1218-11
Location	OWA, 1ST FL. CLEAN RM PERSON. DECON	OWA, 1ST FL. 20FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA, 7TH FL. MAIN STAIRWAY	OWA, 6TH FL. MAIN STAIRWAY	OWA, 5TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	07:30P	07:31P	07:40P	07:43A	07:47P
Time Off	10:29P	10:31P	10:39P	10:44A	10:48P
Tot Time	179 min	180 min	179 min	181 min	181 min
Tot Vol	895 ltr	900 ltr	895 ltr	905 ltr	905 ltr
AV Cnt Fibr Per Fld	.215	.125	.35	.215	.38
Fibr Cnt Fibr Per CC	0.0118	0.0068	0.0192	0.0117	0.0206
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK
ENVIRONMENTAL
CORP

Date: 12/18/01
AIR SAMPLING RESULTS

Proj Num: 01-1212

Page: 151

Code: TJ

--Types of Project--

Address: LIONS HEAD

110 DEVELOPEMENT LLC

110 CHURCH ST.

State:

Zip:

Date Analyzed: 12/22/01

Sample	TJ -1218-12	TJ -1218-	TJ -1218-	TJ -1218-	TJ -1218-
Location	OWA, 4TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	07:52P				
Time Off	10:54P				
Tot Time	182 min				
Tot Vol	910 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.415				
Fibr Cnt Fibr Per CC	0.0224				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/18/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 152 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip:		
Date Analyzed: 12/22/01		

Sample	TJ -1218-13	TJ -1218-14	TJ -1218-15	TJ -1218-16	TJ -1218-17
Location	OWA,3RD FL. MAIN STAIRWAY	ADJ.1ST FL. 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. CLEAN RM PERSON.DECON	OWA,1ST FL. 20FT.WEST OF 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	07:56P	10:25P	10:27P	10:30P	10:32P
Time Off	10:58P	01:31A	01:33A	01:35A	01:38A
Tot Time	182 min	186 min	186 min	185 min	186 min
Tot Vol	910 ltr	930 ltr	930 ltr	925 ltr	930 ltr
AV Cnt Fibr Per Fld	.395	.005	.285	.48	.14
Fibr Cnt Fibr Per CC	0.0213	< 0.0029	0.0150	0.0254	0.0074
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK
ENVIRONMENTAL
CORP

Date: 12/18/01
AIR SAMPLING RESULTS

Proj Num: 01-1212

Page: 153

Code: TJ

--Types of Project--

Address: LIONS HEAD

110 DEVELOPEMENT LLC

110 CHURCH ST.

State:


Zip:

Date Analyzed: 12/22/01

Sample	TJ -1218-18	TJ -1218-	TJ -1218-	TJ -1218-	TJ -1218-
Location	OWA, 7TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	10:41P				
Time Off	01:49A				
Tot Time	188 min				
Tot Vol	940 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.32				
Fibr Cnt Fibr Per CC	0.0167				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK
ENVIRONMENTAL
CORP

Date: 12/18/01
AIR SAMPLING RESULTS

Proj Num: 01-1212

Page: 154

Code: TJ

--Types of Project--

Address: LIONS HEAD

110 DEVELOPEMENT LLC

110 CHURCH ST.

State:


Zip:

Date Analyzed: 12/22/01

Sample	TJ -1218-19	TJ -1218-20	TJ -1218-21	TJ -1218-22	TJ -1218-23
Location	OWA, 6TH FL. MAIN STAIRWAY	OWA, 5TH FL. MAIN STAIRWAY	OWA, 4TH FL. MAIN STAIRWAY	OWA, 3RD FL. MAIN STAIRWAY	ADJ, 1ST. FL. 50 MURRAY ST. ENTRANCE
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	10:45P	10:50P	10:55P	11:00P	01:32A
Time Off	01:55A	01:59A	02:02A	02:05A	05:03A
Tot Time	190 min	189 min	187 min	185 min	211 min
Tot Vol	950 ltr	945 ltr	935 ltr	925 ltr	1055 ltr
AV Cnt Fibr Per Fld	.20	.61	.29	.53	.01
Fibr Cnt Fibr Per CC	0.0103	0.0317	0.0152	0.0281	< 0.0026
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/18/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 155 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1218-24	TJ -1218-	TJ -1218-	TJ -1218-	TJ -1218-
Location	OWA, 1ST. FL 15FT. EAST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	01:34A				
Time Off	05:04A				
Tot Time	210 min				
Tot Vol	1050 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.15				
Fibr Cnt Fibr Per CC	0.0070				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/18/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 156 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	TJ -1218-25	TJ -1218-26	TJ -1218-27	TJ -1218-28	TJ -1218-29
Location	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 20FT. WEST OF 50 MURRAY ST.	OWA,7TH FL. MAIN STAIRWAY	OWA,6TH FL. MAIN STAIRWAY	OWA,5TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	01:36A	01:39A	01:51A	01:56A	02:00A
Time Off	05:05A	05:06A	05:14A	05:17A	05:21A
Tot Time	209 min	207 min	203 min	201 min	201 min
Tot Vol	1045 ltr	1035 ltr	1015 ltr	1005 ltr	1005 ltr
AV Cnt Fibr Per Fld	.275	.245	.465	.55	.365
Fibr Cnt Fibr Per CC	0.0129	0.0116	0.0225	0.0268	0.0178
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/18/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 157 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	TJ -1218-30	TJ -1218-	TJ -1218-	TJ -1218-	TJ -1218-
Location	OWA, 4TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	02:03A				
Time Off	05:24A				
Tot Time	201 min				
Tot Vol	1005 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.34				
Fibr Cnt Fibr Per CC	0.0166				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/18/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 158 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1218-31	TJ -1218-32	TJ -1218-33	TJ -1218-34	TJ -1218-35
Location	OWA, 3RD FL. MAIN STAIRWAY	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	DURING ABATEMENT	Other	Other	Other	Other
Personal		- -	- -	- -	- -
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On	02:07A				
Time Off	05:28A				
Tot Time	201 min				
Tot Vol	1005 ltr	0000000000	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.705	BDL	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	0.0344				
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/18/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 159 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1218-36	TJ -1218-	TJ -1218-	TJ -1218-	TJ -1218-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/18/01	12/18/01	12/18/01	12/18/01	12/18/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt Fibr Per Fld	BDL				
Fibr Cnt Fibr Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



12-19-01

25 < 9(+)
16(-)

AIRTEK ENVIRONMENTAL CORP		Date: 12/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 160 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1219-01	TJ -1219-02	TJ -1219-03	TJ -1219-04	TJ -1219-05
Location	OWA, 1ST FL. CLEAN RM. PERSON. DECON	OWA, 1ST FL. 25FT. WEST OF 50 MURRAY ST.	OWA, 1ST FL. 50 MURRAY ST.	OWA, 1ST FL. 15FT. EAST OF 50 MURRAY ST.	OWA, 1ST FL. CLEAN RM PERSON. DECON
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	03:28A	03:29A	03:30A	03:31A	07:04A
Time Off	07:03A	07:05A	07:07A	07:09A	10:26A
Tot Time	215 min	216 min	217 min	218 min	202 min
Tot Vol	1075 ltr	1080 ltr	1085 ltr	1090 ltr	1010 ltr
AV Cnt Fibr Per Fld	.11	.135	.23	.14	.175
Fibr Cnt Fibr Per CC	0.0050	0.0061	0.0104	0.0063	0.0085
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/19/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 161 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	TJ -1219-06	TJ -1219--	TJ -1219--	TJ -1219--	TJ -1219--
Location	OWA, 1ST FL. 25FT. WEST OF 50 MURRAY ST. ENTRANCE				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	07:06A				
Time Off	10:28A				
Tot Time	202 min				
Tot Vol	1010 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.085				
Fibr Cnt Fibr Per CC	0.0041				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 162 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1219-07	TJ -1219-08	TJ -1219-09	TJ -1219-10	TJ -1219-11
Location	OWA, 1ST FL. 50 MURRAY ST. ENTRANCE	OWA, 1ST FL. 15FT. EAST OF ENTRANCE	OWA, 3RD FL. MAIN STAIRWAY	OWA, 4TH FL. MAIN STAIRWAY	OWA, 12TH FL. ELEVATOR LOBBY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	07:08A	07:10A	07:17A	07:21A	07:30A
Time Off	10:30A	10:32A	10:39A	10:42A	10:48A
Tot Time	202 min	202 min	202 min	201 min	198 min
Tot Vol	1010 ltr	1010 ltr	1010 ltr	1005 ltr	990 ltr
AV Cnt Fibr Per Fld	.095	.06	.165	.005	.53
Fibr Cnt Fibr Per CC	0.0046	0.0029	0.0080	< 0.0027	0.0263
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 163 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1219-12	TJ -1219-	TJ -1219-	TJ -1219-	TJ -1219-
Location	OWA, 1ST FL. CLEAN RM PERSON. DECON				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	10:27A				
Time Off	01:43P				
Tot Time	196 min				
Tot Vol	980 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.20				
Fibr Cnt Fibr Per CC	0.0100				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 12/19/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 164 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	TJ -1219-13	TJ -1219-14	TJ -1219-15	TJ -1219-16	TJ -1219-17
Location	OWA,1ST FL. 25FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 50 MURRAY ST.	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,3RD FL. MAIN STAIRWAY	OWA,4TH FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	10:29A	10:31A	10:33A	10:40A	10:43A
Time Off	01:45P	01:47P	01:49P	01:54P	01:57P
Tot Time	196 min	196 min	196 min	194 min	194 min
Tot Vol	980 ltr	980 ltr	980 ltr	970 ltr	970 ltr
AV Cnt Fibr Per Fld	.19	.105	.025	.395	.18
Fibr Cnt Fibr Per CC	0.0095	0.0053	< 0.0028	0.0200	0.0091
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK
ENVIRONMENTAL
CORP

Date: 12/19/01
AIR SAMPLING RESULTS

Proj Num: 01-1212

Page: 165

Code: TJ

--Types of Project--

Address: LIONS HEAD

110 DEVELOPEMENT LLC

110 CHURCH ST.

State:


Zip:

Date Analyzed: 12/22/01

Sample	TJ -1219-18	TJ -1219-	TJ -1219-	TJ -1219-	TJ -1219-
Location	OWA, 12TH FL. ELEVATOR LOBBY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	10:50A				
Time Off	02:06P				
Tot Time	196 min				
Tot Vol	980 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.225				
Fibr Cnt Fibr Per CC	0.0113				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/19/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 166 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	TJ -1219-19	TJ -1219-20	TJ -1219-21	TJ -1219-22	TJ -1219-23
Location	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 25FT. WEST OF 50 MURRAY ST.	OWA,1ST FL. 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	OWA,3RD FL. MAIN STAIRWAY
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	5.0	5.0	5.0	5.0	5.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	01:44P	01:46P	01:48P	01:50P	01:55P
Time Off	05:45P	05:49P	05:53P	05:55P	05:58P
Tot Time	241 min	243 min	245 min	245 min	243 min
Tot Vol	1205 ltr	1215 ltr	1225 ltr	1225 ltr	1215 ltr
AV Cnt Fibr Per Fld	.17	.255	.19	.115	.325
Fibr Cnt Fibr Per CC	0.0069	0.0103	0.0076	0.0046	0.0117
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 167 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1219-24	TJ -1219-	TJ -1219-	TJ -1219-	TJ -1219-
Location	OWA, 4TH FL. MAIN STAIRWAY				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	01:58P				
Time Off	06:06P				
Tot Time	248 min				
Tot Vol	1240 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.30				
Fibr Cnt Fibr Per CC	0.0119				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

AIRTEK ENVIRONMENTAL CORP		Date: 12/19/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 168 Code: TJ	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	TJ -1219-25	TJ -1219-26	TJ -1219-27	TJ -1219-28	TJ -1219-29
Location	OWA, 12TH FL. ELEVATOR LOBBY	FIELD BLANK	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	DURING ABATEMENT	Other	Other	Other	Other
Personal	- -	- -	- -	- -	- -
Avg Flow	5.0	0.0	0.0	0.0	0.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On	02:07P				
Time Off	06:14P				
Tot Time	247 min				
Tot Vol	1235 ltr	0000000000	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.835	BDL	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	0.0332				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/19/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 169 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	TJ -1219-30	TJ -1219-	TJ -1219-	TJ -1219-	TJ -1219-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/19/01	12/19/01	12/19/01	12/19/01	12/19/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt					
Fibr					
Per Fld	BDL				
Fibr Cnt					
Fibr					
Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



12-20-01

4 ~~1~~ 14
3(-)

AIRTEK ENVIRONMENTAL CORP	Date: 12/20/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 170 Code: TJ
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	TJ -1220-01	TJ -1220-02	TJ -1220-03	TJ -1220-04	TJ -1220-05
Location	OWA,1ST FL. 50 MURRAY ST. ENTRANCE	OWA,1ST FL. CLEAN RM PERSON. DECON	OWA,1ST FL. 25FT. WEST OF 50 MURRAY ST. ENTRANCE	OWA,1ST FL. 15FT. EAST OF 50 MURRAY ST. ENTRANCE	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	Other
Personal	- -				- -
Avg Flow	6.0	6.0	6.0	6.0	0.0
Cal Date	12/20/01	12/20/01	12/20/01	12/20/01	12/20/01
Time On	03:28P	03:29P	03:30P	03:32P	
Time Off	07:28P	07:29P	07:30P	07:32P	
Tot Time	240 min	240 min	240 min	240 min	
Tot Vol	1440 ltr	1440 ltr	1440 ltr	1440 ltr	0000000000
AV Cnt Fibr Per Fld	.02	.015	.12	.355	BDL
Fibr Cnt Fibr Per CC	< 0.0019	< 0.0019	0.0041	0.0121	
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

12/21/01
32 < 2(+) 3(-)

AIRTEK ENVIRONMENTAL CORP		Date: 12/21/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 171 Code: JG	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	JG -1221-01	JG -1221-02	JG -1221-03	JG -1221-04	JG -1221-05
Location	IWA, ADJ. TO TRANSFORMER RM ON 16TH FL. 120 CHURCH	IWA, ADJ. TO TRANSFORMER RM ON 16TH FL. 120 CHURCH	IWA, RIGHTSIDE OF TRANSFORMER RM ON 18TH FL	IWA, IN FRONT OF TRANSFORMER ON 18TH FL.	IWA, 14TH FL. ADJ. TO TRANSFORMER RM 120 CHURCH
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				- -
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	07:45P	07:46P	08:35P	08:35P	08:40P
Time Off	09:45P	09:46P	10:35P	10:35P	10:40P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.005	.015	.345	.01	.30
Fibr Cnt Fibr Per CC	< 0.0015	< 0.0015	0.0094	< 0.0015	0.0082
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PGM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/21/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 172 Code: JG	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	JG -1221-06	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 14TH FL. TRANSFORMER RM 120 CHURCH				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	08:40P				
Time Off	10:40P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.215				
Fibr Cnt Fibr Per CC	0.0059				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/21/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 173 Code: JG	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	JG -1221-07	JG -1221-08	JG -1221-09	JG -1221-10	JG -1221-11
Location	IWA,12TH FL. TRANSFORMER RM W.SIDE OF RM 110 CHURCH	IWA,12TH FL. TRANSFORMER RM W.SIDE OF RM 110 CHURCH	IWA,12TH FL. E.SIDE TRANSFORMER RM 120 CHURCH	IWA,12TH FL. ADJ. TO EAST SIDE TRANSF. ROOM	IWA,14TH FL. E.SIDE TRANSF 110 CHURCH
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	08:50P	08:50P	08:52P	08:52P	09:00P
Time Off	10:50P	10:50P	10:52P	10:52P	11:00P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.025	.505	.06	.24	.215
Fibr Cnt Fibr Per CC	< 0.0015	0.0138	0.0016	0.0065	0.0059
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 174 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-12	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 14TH FL. E. SIDE TRANSE. 110 CHURCH				
Activity	DURING ABATEMENT				
Personal	- -				
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	09:00P				
Time Off	11:00P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.095				
Fibr Cnt Fibr Per CC	0.0026				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/21/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 175 Code: JG	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	JG -1221-13	JG -1221-14	JG -1221-15	JG -1221-16	JG -1221-17
Location	IWA,16TH FL. 110 CHURCH ST TRANSF. ROOM	IWA,16TH FL. 110 CHURCH ST TRANSF. ROOM	IWA,10TH FL. 110 CHURCH ST TRANSF. ROOM	IWA,10TH FL. 110 CHURCH ST TRANSF. ROOM	IWA,10TH FL. 120 CHURCH ST TRANSF. ROOM
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal	- -				
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	11:10A	11:10A	11:20A	11:20A	11:22A
Time Off	01:10P	01:10P	01:20P	01:20P	01:22P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.12	.13	.405	.035	.285
Fibr Cnt Fibr Per CC	0.0033	0.0035	0.0110	< 0.0015	0.0078
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature




AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 176 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-18	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 10TH FL. 120 CHURCH ST TRANSF. RM				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	11:22A				
Time Off	01:22P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.115				
Fibr Cnt Fibr Per CC	0.0031				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/21/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 177 Code: JG	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	JG -1221-19	JG -1221-20	JG -1221-21	JG -1221-22	JG -1221-23
Location	IWA, 8TH FL. 110 CHURCH ST TRANSF. ROOM	IWA, 8TH FL. 110 CHURCH ST TRANSF. ROOM	IWA, 8TH FL. 120 CHURCH ST TRANSF. ROOM	IWA, 8TH FL. 120 CHURCH ST TRANSF. ROOM	IWA, 6TH FL. 110 CHURCH ST TRANSF. ROOM
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	12:10P	12:10P	12:15P	12:15P	12:30P
Time Off	02:10P	02:10P	02:15P	02:15P	02:30P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.045	.045	.005	.03	.005
Fibr Cnt Fibr Per CC	< 0.0015	< 0.0015	< 0.0015	< 0.0015	< 0.0015
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK
ENVIRONMENTAL
CORP

Date: 12/21/01
AIR SAMPLING RESULTS

Proj Num: 01-1212
Page: 178
Code: JG

--Types of Project--

Address: LIONS HEAD

110 DEVELOPEMENT LLC
110 CHURCH ST.

State:

Zip:

Date Analyzed: 12/22/01

Sample	JG -1221-24	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 6TH FL. 110 CHURCH ST TRANSF. ROOM				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	12:30P				
Time Off	02:30P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.075				
Fibr Cnt Fibr Per CC	0.0020				
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/21/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 179 Code: JG	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	JG -1221-25	JG -1221-26	JG -1221-27	JG -1221-28	JG -1221-29
Location	IWA, 6TH FL. 120 CHURCH ST TRANSF. ROOM	IWA, 6TH FL. 120 CHURCH ST TRANSF. ROOM	IWA, 4TH FL. 110 CHURCH ST TRANSF. ROOM	IWA, 4TH FL. 110 CHURCH ST TRANSF. ROOM	IWA, 4TH FL. 120 CHURCH ST TRANSF. ROOM
Activity	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT	DURING ABATEMENT
Personal					
Avg Flow	15.0	15.0	15.0	15.0	15.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	01:00P	01:00P	01:10P	01:10P	01:15P
Time Off	03:00P	03:00P	03:10P	03:10P	03:15P
Tot Time	120 min	120 min	120 min	120 min	120 min
Tot Vol	1800 ltr	1800 ltr	1800 ltr	1800 ltr	1800 ltr
AV Cnt Fibr Per Fld	.015	.04	.075	.11	.02
Fibr Cnt Fibr Per CC	< 0.0015	< 0.0015	0.0020	0.0030	< 0.0015
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM


Authorized Signature

AIRTEK ENVIRONMENTAL CORP	Date: 12/21/01 AIR SAMPLING RESULTS	Proj Num: 01-1212 Page: 180 Code: JG
--Types of Project-- Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01		

Sample	JG -1221-30	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	IWA, 4TH FL. 120 CHURCH ST TRANSF. ROOM				
Activity	DURING ABATEMENT				
Personal					
Avg Flow	15.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	01:15P				
Time Off	03:15P				
Tot Time	120 min				
Tot Vol	1800 ltr	0	0	0	0
AV Cnt Fibr Per Fld	.015				
Fibr Cnt Fibr Per CC	< 0.0015				
Comments					


ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature



AIRTEK ENVIRONMENTAL CORP		Date: 12/21/01 AIR SAMPLING RESULTS		Proj Num: 01-1212 Page: 181 Code: JG	
--Types of Project--		Address: LIONS HEAD 110 DEVELOPEMENT LLC 110 CHURCH ST. State: Zip: Date Analyzed: 12/22/01			
Sample	JG -1221-31	JG -1221-32	JG -1221-33	JG -1221-34	JG -1221-35
Location	IWA, 3RD FL. 110 CHURCH ST TRANSF. ROOM	IWA, 3RD FL. 110 CHURCH ST TRANSF. ROOM	FIELD BLANK	FIELD BLANK	FIELD BLANK
Activity	DURING ABATEMENT	DURING ABATEMENT	Other	Other	Other
Personal			- -	- -	- -
Avg Flow	15.0	15.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On	01:30P	01:30P			
Time Off	03:30P	03:30P			
Tot Time	120 min	120 min			
Tot Vol	1800 ltr	1800 ltr	0000000000	0000000000	0000000000
AV Cnt Fibr Per Fld	.015	.065	BDL	BDL	BDL
Fibr Cnt Fibr Per CC	< 0.0015	0.0018			
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature 

AIRTEK
ENVIRONMENTAL
CORP

Date: 12/21/01
AIR SAMPLING RESULTS

Proj Num: 01-1212
Page: 182
Code: JG

--Types of Project--

Address: LIONS HEAD
110 DEVELOPEMENT LLC
110 CHURCH ST.

State:

Zip:

Date Analyzed: 12/22/01

Sample	JG -1221-36	JG -1221-	JG -1221-	JG -1221-	JG -1221-
Location	FIELD BLANK				
Activity	Other				
Personal	- -				
Avg Flow	0.0	0.0	0.0	0.0	0.0
Cal Date	12/21/01	12/21/01	12/21/01	12/21/01	12/21/01
Time On					
Time Off					
Tot Time					
Tot Vol	0000000000	0	0	0	0
AV Cnt					
Fibr					
Per Fld	BDL				
Fibr Cnt					
Fibr					
Per CC					
Comments					

ANALYSIS: NIOSH 7400 METHOD, A RULES - NIKON LABOPHOT - PCM

Authorized Signature

