

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

118 & 120 Nassau Street, New York, NY

Received: 6/26/02

9:15:00 PM

ATC Group #: 8297

Analysis Date: 6/27/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.3µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
01 8297 -1	1560.00	0.0562	0	None Detected	0	0	0.0044 <17.79 <0.0044	
02 8297 -2	1560.00	0.0562	0	CHRYSTOLE	0	1	0.0044 17.79 0.0044	
03 8297 -3	1560.00	0.0562	0	None Detected	0	0	0.0044 <17.79 <0.0044	
04 8297 -4	1560.00	0.0562	0	None Detected	0	0	0.0044 <17.79 <0.0044	
05 8297 -5	1560.00	0.0562	0	None Detected	0	0	0.0044 <17.79 <0.0044	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

PAGE 1 OF 1

o.
e.

CLIENT: NYCDEP
W&P FILE #: 1079.01.02
LABORATORY: _____
CONTACT: _____

LABORATORY:

ANALYSIS METHOD:	PCM	TEM	TEM
circle one	7400	AHERA	EPA LEVEL II

TECHNICIAN: L. S. JO

[illegible]

COMMENTS:

Beich #8297

SAMPLE BY: Louis Soto DATE: 6-26-02
SIGNATURE: [Signature]
RELEASED BY: Louis Soto DATE: 6-26-02
SIGNATURE: [Signature]
RECEIVED BY: ATC Lab DATE: 06/26/02
SIGNATURE: [Signature] 2115

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Thursday, June 27, 2002

Time: 1:56:39 AM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8299

Client Project: NYC-DEP W & P File #: 1079.01.02
47 Ann Street

Number of Pages: 3
(including cover page)



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8297

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
118 & 120 Nassau Street, New York, NY

Date: Thursday, June 27, 2002

Time: 1:55:07 AM

Comments:

Number of Pages: 3
(including cover page)