

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 6/24/02 9:00:00 PM
 ATC Group #: 8260
 Analysis Date: 6/25/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 116 Nassau Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µ	5µ		(S/mm ²)	(S/cc)	
03 8260 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
04 8260 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
05 8260 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
06 8260 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
07 8260 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-C, NY State ELAP #10679

18

2228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0830

WARREN & PANZER ENGINEERS, P. C.
ENGINEERING & CONSTRUCTION OF SUPERCHAIN-OF-CUSTODY FORM

०३

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

W&P FILE #: 1079-01-02

CONTACT:

CLIENT N.Y.C.D.E.P.

PROJECT: 116 NASSAU ST NY, NY

LOCATION: N. Wm / N.W.-Wm.

LABORATORY: ATC 120V-1004

ANALYSIS METHOD: circle one
PCM TEM AHERA EPA LEVEL II
7400

SHOULD BE
1-00-CE BEE

TECHNICIAN: Lawrence Bate

DATE

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME		TOTAL TIME	VOLUME (liters)	CONCENTRATION (lb/cc.)
				START	STOP	ON	OFF			
-01	FIELD Blank	1	—	—	—	0905	—	—	—	—
-02	FIELD Blank	1	—	—	—	0906	—	—	—	—
-03	CURTAIN ROOM NEAR	3	02	3.0	3.0	0910	1716	480	1940	—
-04	ROOF NOT- DAP	3	11	3.0	3.0	0912	1712	480	1940	—
-05	6TH FL WINDOW WEST	3	16	3.0	3.0	0914	1715	480	1940	—
-06	6TH FL WINDOW EAST	3	09	3.0	3.0	0916	1716	480	1940	—
-07	5TH FL WINDOW WEST	3	48	3.0	3.0	0920	1720	480	1940	—
-08	CURTAIN BLANK	1	—	—	—	—	—	—	—	—

COMMENTS:

COMMENTS:

DATE: 6/24/02
MONDAY

SAMPLE BY: LAWRENCE BOER
SIGNATURE: *Lawrence Boer*
RELEASED BY: _____
SIGNATURE: _____
RECEIVED BY: _____
SIGNATURE: _____

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Tuesday, June 25, 2002

Time: 1:39:19 AM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8260

Client Project: NYC-DEP W & P File #: 1079.01.02
116 Nassau Street, New York, NY

Number of Pages: 3
(including cover page)

n