

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017


Fax: (212) 922-0630 Phone: (212) 922-0077

Received: 6/27/02 8:00:00 AM
 ATC Group #: 8305
 Analysis Date: 6/27/02

Project: 116 Nassau Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8305 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8305 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8305 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
06 8305 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
07 8305 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

MARK PEYSAKHOVAnalyzed by: **MICHAEL A. GORYCKI, Ph.D.**

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-0, NY State ELAP #10879

Page 1 of 1

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-4630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

P.O.

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1019-01-02

CONTACT: ALICE NOLA

LABORATORY: ATE LAB

LLW#:

ANALYSIS METHOD: PCM

SCA JOB#:

circle one

TEM
AHERA
EPA LEVEL II

TECHNICIAN: LAURENCE BAE

CLIENT: N.Y.C.D.E.P. 8305

PROJECT: 116 WASHINGTON ST

LOCATION: WEST SIDE WAREHOUSE + LOBBY
vacant

SAMPLE NO.	SAMPLE TYPE	FLOW RATE GPM	START	STOP	TIME ON	TIME OFF	TOTAL TIME	CONCENTRATION (µg/m ³)
-01	Field Blank	—	—	—	1045	—	—	—
-02	Field Blank	—	—	—	1046	—	—	—
-03	Clear Room DECON	02	5.0	5.0	1048	1648	360	1800
-04	6th Floor WEST (N)	01	5.0	5.0	1050	1650	360	1800
-05	6th Floor WEST (S)	05	5.0	5.0	1052	1652	360	1800
-06	8th Floor WEST	11	5.0	5.0	1055	1655	360	1800
-07	2nd Floor S. WAREHOUSE	09	5.0	5.0	1057	1657	360	1800
-08	CAPPED Blank	—	—	—	—	—	—	—

COMMENTS:

SAMPLE BY: <u>LAURENCE BAE</u>	DATE: <u>6/24/02</u>
SIGNATURE: <u>Laurence Bae</u>	<u>Wednesday</u>
RELEASED BY: _____	DATE: _____
SIGNATURE: _____	DATE: <u>6/27/02</u>
RECEIVED BY: <u>ATE</u>	DATE: <u>6/27/02</u>
SIGNATURE: <u>JP</u>	DATE: <u>8am</u>

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)	7 - Personal	8 - Background
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement			
4 - During Glove Bag Removal			

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8305

Date: Thursday, June 27, 2002

Client Project:

116 Nassau Street

Time: 2:51:16 PM

Number of Pages: 3
(including cover page)

Comments: