

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

116 Nassau Street

Received: 6/27/02

8:00:00 PM

ATC Group #: 8314

Analysis Date: 6/28/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µm	5µ		(S/mm ²)	(S/cc)	
01 8314 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
02 8314 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
03 8314 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
04 8314 -4	1440.00	0.1686	0	CHRYSTILE	2	1	0.0048	53.38	0.0143	
05 8314 -5	1440.00	0.0562	0	CHRYSTILE	0	1	0.0048	17.79	0.0048	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a (12 hr⁺/a) 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

8219
CLIENT: Dep
W&P FILE #: 1075 01 02
LABORATORY: A7C

CONTACT:

PROJECT: ROOF CLEAR
LOCATION: NO MASS AUG-87 -6-

7400 ANHERA EPA LEVEL II

TECHNICIAN:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb/cc.)
114	01 @ DECCA 240 FAN	3		6	14 00 18 00	240	1940	
116	02 PERIMETER EAST - SOUTH END	↑		6	14 05 18 05	↑	↑	
116	03 PERIMETER EAST NORTH	↓		6	14 07 18 07	↓	↓	
116	04 PERIMETER WEST 240 -			6	14 09 18 09			
116	05 PERIMETER WEST NORTH	3		6	14 11 18 11	240	1940	
116	06 FIELD BLANK	1						
116	07 FIELD BLANK	1						

COMMENTS:

SAMPLE BY: _____	DATE: _____
SIGNATURE: _____	
RELEASED BY: _____	DATE: _____
SIGNATURE: _____	
RECEIVED BY: _____	DATE: _____
SIGNATURE: _____	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background