

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/13/02

8:00:00 PM

ATC Group #: 8092

Analysis Date: 6/14/02

Project: NYC-DEP W & P File #: 1079.01.02

116 Nassau Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
03 8092 -1	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
04 8092 -2	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
05 8092 -3	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
06 8092 -4	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
07 8092 -5	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/13/02

8:00:00 PM

ATC Group #: 8092

Analysis Date: 6/14/02

Project: NYC-DEP W & P File #: 1079.01.02

160 Nassau Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8092 -1	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
04 8092 -2	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
05 8092 -3	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
06 8092 -4	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
07 8092 -5	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10379

220 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF

8092

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

CLIENT: N.Y.C.D.E.P.
PROJECT: 160 NASSAU STREET NY, N.Y.
LOCATION: LOUCCS S. ROOF -

W&P FILE #: 1079-01-02

LABORATORY: ATC Corp.

ANALYSIS METHOD: PCM
circle one 7400 AHERA EPA LEVEL II

CONTACT: Mike P. (p.c.)

TECHNICIAN: LAWRENCE BAER

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
-01	FRESH BULK	1	—	—	—	1330	—	—	—	—
-02	FRESH BULK	1	—	—	—	1331	—	—	—	—
-03	CURVED ROOF DECK	3	03	5.0	5.0	1335	1805	270	1350	—
-04	C.E.T. PANEL 3RD FLOOR	3	12	5.0	5.0	1338	1808	270	1350	—
-05	ANT. FIRE STAIR EAST 3RD FL.	3	08	5.0	5.0	1340	1810	270	1350	—
-06	LOWER ROOF SOUTH	3	09	5.0	5.0	1343	1813	270	1350	—
-07	3RD FLOOR SOUTH	3	14	5.0	5.0	1345	1815	270	1350	—
-08	CURVED BULK	1	—	—	—	—	—	—	—	—

COMMENTS:

SAMPLE BY: LAWRENCE BAER
SIGNATURE: Lawrence Baer
RELEASED BY: LAWRENCE BAER
SIGNATURE: Lawrence Baer
RECEIVED BY: 11/13
SIGNATURE: 20/1000

DATE: 6/10/02

THURSDAY

DATE:

DATE: 6/13

20/1000

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION