

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

116 Nassau Street, New York, NY

Received: 6/20/02

8:00:00 PM

ATC Group #: 8197

Analysis Date: 6/21/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical		Asbestos		Notes
						Sensitivity (S/cc)		Concentration (S/mm ³)	(S/cc)	
03 8197 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
04 8197 -2	1800.00	0.0450	0	CHRYSTILE	1	0	0.0048	22.24	0.0048	
05 8197 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
06 8197 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
07 8197 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 35% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8197 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8197 -2	1800.00	0.0450	0	CHRYSTOLE	1	0	0.0048	22.24	0.0048
05 8197 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
06 8197 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
07 8197 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

220 East 43rd Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 7

8197

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a P.O.

CLIENT: N.Y.C.D.E.P.

PROJECT: 116 Nassau St. N.Y.C.

LOCATION: South Wall To Street (Avenue St)

W&P FILE #: 1079-01-02

LABORATORY: ATC ENV. CORP.

ANALYSIS METHOD: PCM circle one
circle one

TECHNICIAN: Lawrence Boer

CONTACT: MIKE NOLAN

LLW#:

SCA JOB#:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
-01	FIELD Blank	1	—	—	—	0802	—	—	—	—
-02	FIELD Blank	1	—	—	—	0803	—	—	—	—
-03	CLIM ROOM DECK (REMOTE)	3	02	3.0	3.0	0805	1805	600	1800	—
-04	3RD FL WINDOW - STREET	3	11	3.0	3.0	0808	1808	600	1800	—
-05	ENTR. 3RD FL. FIRE STAIR	3	06	3.0	3.0	0810	1810	600	1800	—
-06	MID ROOF SOUTH ADJ. WALL	3	57	3.0	3.0	0814	1814	600	1800	—
-07	MID ROOF SOUTH BATTERY WALL	3	09	3.0	3.0	0818	1818	600	1800	—
-08	CORNER BLANK	2-1	—	—	—	—	—	—	—	—

COMMENTS:

SAMPLE BY: <u>Lawrence Boer</u>	DATE: <u>6/20/02</u>
SIGNATURE: <u>Lawrence Boer</u>	THURSDAY
RELEASED BY: <u>Lawrence Boer</u>	DATE: <u>6/20/02</u>
SIGNATURE: <u>Lawrence Boer</u>	THURSDAY
RECEIVED BY: <u>ASCO</u>	DATE: <u>6/20/02</u>
SIGNATURE: <u>ASCO</u>	DATE: <u>6/20/02</u>

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION