

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warten & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

116 Nassau Street, New York, NY

Received: 6/21/02

9:00:00 PM

ATC Group #: 8218

Analysis Date: 6/22/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
03 8218 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8218 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8218 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
06 8218 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
07 8218 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
09 8218 -6	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
10 8218 -7	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0080

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

P.O.

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1079-01-03

CONTACT: MIKE NELSON

CLIENT: N.Y.C. D.D.E.P.

LABORATORY: ATE ENV. CORP.

PROJECT: 116 W 42nd St. 24. N.Y.

ANALYSIS METHOD: PCM TEM
circle one AHERA EPA LEVEL II

LOCATION: JURY FACES ON NEW ST. / ROOFS

TECHNICIAN: LAWRENCE BAKER

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (lb./cc.)
01	Field Blank	1	—	—	—	0903	—	—	—	—
02	Field Blank	1	—	—	—	0909	—	—	—	—
03	CURTAIN FROM DECK (REMOVED)	3	02	3.0	3.0	0906	1906	600	1800	—
04	ENTR. TO EMER. ESC. COURTYARD	3	04	3.0	3.0	0908	1908	600	1800	—
05	MID ROOF SURF. ADJ. CLUT	3	11	3.0	3.0	0911	1911	600	1800	—
06	MID ROOF NORTH ADJ. COURTYARD	3	14	3.0	3.0	0914	1914	600	1800	—
07	INSIDE 2nd Fl. WINDOW ADJ. HALLWAY	3	09	3.0	3.0	0916	1916	600	1800	—
08	CORRIDOR BLANK	1	—	—	—	—	—	—	—	—
09	STAIRWELL ADJ. ST.	3	16	4.0	4.0	1305	1905	260	1440	—
10	BOTTOM STAIR CO. WINDING	3	23	4.0	4.0	1315	1915	260	1440	—

COMMENTS:

SAMPLE BY: LAWRENCE BAKER DATE: 6/21/02
SIGNATURE: Lawrence Baker
RELEASED BY: Lawrence Baker DATE: 6/21/02
SIGNATURE: Lawrence Baker
RECEIVED BY: H. Gentry DATE: 6/21/02
SIGNATURE: H. Gentry

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8218

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
116 Nassau Street, New York, NY

Date: Saturday, June 22, 2002

Time: 5:30:20 AM

Comments:

Number of Pages: 3
(including cover page)