

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

116 Nassau Street, New York, NY

Received: 6/24/02

9:00:00 PM

ATC Group #: 8260

Analysis Date: 6/25/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8260 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
04 8260 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
05 8260 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
06 8260 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
07 8260 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

18

2228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0830

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

(212) 922-0077
Fax (212) 922-0830

24 hr⁺/a
12 hr⁺/a
6 hr⁺/a
3 hr⁺/a
immediate /a

W&P FILE #: 1079-01-02

CONTACT: MIKE WILKINSON

CLIENT: N.Y.C.D.C.P.

PROJECT: 116 NASSAU ST. N.Y. NY

LOCATION: N. W. 40 / N. 14 - 6000

Estimate Power. 6/25/46.

LABORATORY: ATC ENVY-CORP.

LABORATORY: 715	ANALYSIS METHOD: PCM	TEMP	TEMP
-----------------	----------------------	------	------

ANALYSIS METHOD: PCM TEM TEM
7400 AHERA EPA LEVEL II

[illegible]

TECHNICIAN: Chapman Bae

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb/cc.)
				START	STOP					
-01	FIELD BRACK	1	—	—	—	0905	—	—	—	—
-02	FIELD BRACK	1	—	—	—	0906	—	—	—	—
-03	CLEAR RAMPY NISSED	3	02	3.0	3.0	0910	1710	480	1540	—
-04	REF DOT-DRIP	3	11	3.0	3.0	0912	1712	480	1440	—
-05	6TH FL WINDOW WEST	3	16	3.0	3.0	0914	1714	480	1440	—
-06	6TH FL WINDOW EAST	3	09	3.0	3.0	0916	1716	480	1440	—
-07	5TH FL WINDOW WEST	3	40	3.0	3.0	0920	1720	480	1440	—
-08	CORNER BRACK	1	—	—	—	—	—	—	—	—

COMMENTS:

COMMENTS:

SAMPLE BY: AWRINE BOE DATE: 6/24/08

SIGNATURE: L. J. P. P.

SIGNATURE: *[Signature]* DATE: _____

RELEASED BY: _____
SIGNATURE: _____

SIGNAL HQ. DATE:

RECEIVED BY: _____

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8260

Date: Tuesday, June 25, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
116 Nassau Street, New York, NY

Time: 1:39:19 AM

Number of Pages: 3

(including cover page)

Comments:

n