

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/28/02

7:30:00 PM

ATC Group #: 8329

Analysis Date: 6/29/02

Project: NYC-DEP W & P File #: 1079.01.02

116 Nassau Street, NY NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8329 -1	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
04 8329 -2	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
05 8329 -3	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
06 8329 -4	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
07 8329 -5	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

38

Page 1 of 1

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

8329

24 hr³/a 12 hr³/a 6 hr³/a 3 hr³/a Immediate ¹/a

PAGE 1 OF 1

P.O.

W&P FILE #: 1079-01-02

CONTACT: MIKE NOLAN

CLIENT: N.Y.C. D.E.P.

LABORATORY: ATC EVO, GRL

LLW#:

PROJECT: 116 HAWARD ST. N.Y.C.

ANALYSIS METHOD: PCM 7400

TEM

AHERA EPA LEVEL II

SCA JOB#:

LOCATION: MID ROOF SOUTH

TECHNICIAN: LAWRENCE BAER

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./sec.)
-01	Floor Black	1	—	—	—	0901	—	—	—	—
-02	Floor Black	1	—	—	—	0902	—	—	—	—
-03	Ceiling Rany Metal	3	02	3.0	3.0	0905	1805	540	1620	—
-04	MID HALL ROOF S1	3	05	3.0	3.0	0907	1807	540	1620	—
-05	Spec Fl. window DIST. CWA	3	11	3.0	3.0	0909	1809	540	1620	—
-06	Exit To Roof CWA	3	09	3.0	3.0	0912	1812	540	1620	—
-07	2nd Fl. window Floor	3	16	3.0	3.0	0914	1814	540	1620	—
-08	COVERED BLACK	1	—	—	—	—	—	—	—	—

COMMENTS:

SAMPLE BY: LAWRENCE BAER DATE: 6/28/02
SIGNATURE: *Lawrence Baer*
RELEASED BY: LAWRENCE BAER DATE: 6/28/02
SIGNATURE: *Lawrence Baer*
RECEIVED BY: *H. Baer* DATE: 6/28/02
SIGNATURE: *H. Baer*

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8329

Date: Saturday, June 29, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
116 Nassau Street, NY NY

Time: 12:45:31 PM

Comments:

Number of Pages: 3
(including cover page)

34